



*Louisville and Jefferson County Metropolitan Sewer District
700 West Liberty Street
Louisville Kentucky 40203-1911
502-540-6000
www.msdlouky.org*

March 25, 2013

Ms. Cheryl Edwards
Kentucky Division of Water
200 Fair Oaks Lane
Frankfort, Kentucky 40601

RE: Derek Guthrie WQTC, KPDES No: KY0078956
Discharge Monitoring Report
February 2013

Dear Ms. Cheryl Edwards:

Attached are the Discharge Monitoring Report (DMR) and the Monthly Operating Report (MOR) for the Derek Guthrie WQTC, for the month of February 2013.

There were no exceedences or bypass reports during the month of February for the Derek Guthrie WQTC.

Also included are the overflow reports for the month of February.

If you have any questions concerning the attached DMR's, please contact me at (502)540-6031.

Sincerely,

A handwritten signature in black ink, appearing to read "John Kessel", written in a cursive style.

John Kessel
Process Supervisor, West Region

JMK/West County 0213

Enclosures

cc: C. Roth
T. Singleton
R. Shaw



*Beneficial Use of Louisville's Biosolids
www.louisvillegreen.com*

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments**Attachments**

Name	Type	Size
201302DRGWQTC_Cover.pdf	pdf	12229
201302DRGWQTC_OverflowReport.pdf	pdf	67321
WCMOR022013.xlsx	xlsx	44921

Report Last Saved By

DEREK R GUTHRIE WQTC MSD

User: kessel@louisvillemsd.org

Date/Time: 2013-03-25 10:01 (Time Zone: -04:00)

Name: John Kessel

E-Mail: kessel@louisvillemsd.org



Report Selections: Excluding PPI, CSO, Excluding LAT and SSL, Result: WUS, Act Code: DISDW, DISREV

KPDES # KY0078956
 Facility ID MSD0277
 Water Quality Treatment Center DEREK R. GUTHRIE
 Receiving Stream of Treatment Center OHIO RIVER
 Region WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	14444	8126 MINOR LN		SOUTHERN DITCH	DITCH

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
DISDW: DRY WEATHER DISCHARGE	1648156	02/22/13 12:30 PM	MARINO	MARINO	REPAIRED - ISSUE RESOLVED	02/22/13	OBSTRUCTION-NOT GREASE OR ROOT	UNAUTHORIZED DISCHARGE-WATER S	02/22/13 01:00 PM	

Spot Inspections:

Discharge Amount:	200 GAL
Cause:	OBSTRUCTION IN MAIN SEWER
Clean Up:	MSD CLEANED PERSONNEL CLEANED AND SANITIZE THE IMPACTED AREA
Control Zone:	PLACED CAUTION TAPE AND DISCHARGE SIGNS AROUND IMPACTED AREA
Impact:	SEWAGE AROUND MANHOLE IN GRASS AREA AND OBSERVED SOME SEWAGE GOING IN THE CREEK
Repair:	WORK ORDERS 1648164,1648155; ROOT CUT, VACTORED THE MAIN SEWER

Notifications:

02/22/13 12:30 PM	DISPUB	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA
02/22/13 01:00 PM	DISNOT	Email notification of unauthorized discharge sent to eppc.ert@ky.gov, Sayre.Dennis@epamail.epa.gov, Charlie.Roth@ky.gov

Total Facilities Printed: 1
 Total Work Orders Printed: 1