

*Louisville and Jefferson County Metropolitan Sewer District  
700 West Liberty Street  
Louisville Kentucky 40203-1911  
502-540-6000  
www.msdlouky.org*



October 7, 2015

Cheryl Edwards  
Kentucky Division of Water  
200 Fair Oaks Lane  
Frankfort, Kentucky 40601

**Re: MSD Metro Operations  
Bancroft WQTC; KPDES No.: KY0039021  
Discharge Monitoring Reports for September 2015.**


Dear Ms. Edwards:

Attached is the Discharge Monitoring Reports (DMRs) and the Monthly Operator Report (MOR) for the Bancroft WQTC; KPDES No.: KY0039021 for the month of September 2015.

There were no exceedances, overflow or bypass reports for this month.

If you have any questions concerning the attached DMRs, please contact me at (502)587-5856.

Sincerely,

  
Duane V. Wright  
Process Supervisor, East Region

DVW/Bancroft 08/15

Enclosures

cc: T. Singleton  
R. Shaw



*Beneficial Use of Louisville's Biosolids  
www.louisvillegreen.com*

**DMR Copy of Record**

<b>Permit</b>					
Permit #:	KY0039021	Permittee:	BANCROFT WQTC MSD	Facility:	BANCROFT WQTC MSD
Major:	No	Permittee Address:	7610 OLD ORCHARD CIR LOUISVILLE, KY 40222	Facility Location:	7610 OLD ORCHARD CIR LOUISVILLE, KY 40222
Permitted Feature:	001 External Outfall	Discharge:	001-1 SANITARY WASTEWATER		

<b>Report Dates &amp; Status</b>					
Monitoring Period:	From 09/01/15 to 09/30/15	DMR Due Date:	10/28/15	Status:	NetDMR Validated

**Considerations for Form Completion**

<b>Principal Executive Officer</b>					
First Name:	Tony	Title:	Exec. Dir	Telephone:	502-540-6000
Last Name:	Parrott				

**No Data Indicator (NODI)**  
Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type		
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample	=	7				=	7				19 - mg/L	0	01/01 - Daily 07/WD - Weekly When Discharging	GR - GRAB GR - GRAB
					Permit Req.	>=	7 INST MIN								19 - mg/L				
					Value NODI														
00400	pH	1 - Effluent Gross	0	--	Sample	=	6				=	7			12 - SU	0	01/01 - Daily 01/07 - Weekly	GR - GRAB GR - GRAB	
					Permit Req.	>=	6 MINIMUM				<=	9 MAXIMUM		12 - SU					
					Value NODI														
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	1	=	2	26 - lb/d	=	7	=	10	19 - mg/L	0	01/07 - Weekly 01/07 - Weekly	CP - COMPOS 24 - COMP24	
					Permit Req.	<=	20 MO AVG	<=	30 WKLY AVG	26 - lb/d	<=	30 MO AVG	<=	45 WKLY AVG	19 - mg/L				
					Value NODI														
00600	Nitrogen, total [as N]	1 - Effluent Gross	0	--	Sample	=					=	16	=	18	19 - mg/L	0	01/07 - Weekly 01/07 - Weekly	CP - COMPOS GR - GRAB	
					Permit Req.							Req Mon MO AVG		Req Mon WKLY AVG	19 - mg/L				
					Value NODI														
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	1	--	Sample	=	0.2	=	0.26	26 - lb/d	=	1	=	1	19 - mg/L	0	01/07 - Weekly 01/07 - Weekly	CP - COMPOS 24 - COMP24	
					Permit Req.	<=	2.67 MO AVG	<=	4.01 WKLY AVG	26 - lb/d	<=	4 MO AVG	<=	6 WKLY AVG	19 - mg/L				
					Value NODI														
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample	=					=	3	=	3	19 - mg/L	0	01/07 - Weekly 01/07 - Weekly	CP - COMPOS 24 - COMP24	
					Permit Req.							Req Mon MO AVG		Req Mon WKLY AVG	19 - mg/L				
					Value NODI														
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.023	=	0.025	03 - MGD						0	99/99 - Continuous 99/99 - Continuous	CN - CONTIN RC - Recorder (auto)	
					Permit Req.		Req Mon MO AVG		Req Mon WKLY AVG	03 - MGD									
					Value NODI														
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample						<	0.01	<	0.01	19 - mg/L	0	01/01 - Daily 01/07 - Weekly	GR - GRAB GR - GRAB	
					Permit Req.						<=	.011 MO AVG	<=	.019 WKLY AVG	19 - mg/L				
					Value NODI														
51040	E. coli	1 - Effluent Gross	0	--	Sample						=	2	=	7	13 - #/100mL	0	01/07 - Weekly 01/07 - Weekly	GR - GRAB GR - GRAB	
					Permit Req.						<=	130 30DA GEO	<=	240 7 DA GEO	13 - #/100mL				
					Value NODI														
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample	=	0.4	=	0.38	26 - lb/d	=	2	=	2	19 - mg/L	0	01/07 - Weekly 01/07 - Weekly	CP - COMPOS 24 - COMP24	
					Permit Req.	<=	16.7 MO AVG	<=	25.04 WKLY AVG	26 - lb/d	<=	25 MO AVG	<=	37.5 WKLY AVG	19 - mg/L				
					Value NODI														

**Submission Note**  
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**  
No errors.

**Comments**

<b>Attachments</b>		
Name	Type	Size
BCRFT092015_COVER.pdf	pdf	46369
Bancrft092015_MOR.pdf	pdf	25351

**Report Last Saved By**  
BANCROFT WQTC MSD

Name: Duane Wright

E-Mail: [duane.wright@louisvillemisd.org](mailto:duane.wright@louisvillemisd.org)

<b>Bancroft</b>		Report for		<b>Sep-15</b>		Tot. Exc.=		0						
Tot. Flow=		0.70303		Concentrations		Pounds								
Date	Flow	TSS	BOD	NH3	Ecoli	TSS	BOD	NH3	Tot. Phos.	D.O.	p.H.	TRC	Tot. N	
9/1/15	0.020	5	2	1.10		0.826	0.331	0.182	2.56	8	6.2	0.01	13.16	
9/2/15	0.021				1					7.6	6.1	0.01		
9/3/15	0.026									7.7	6.3	0.01		
9/4/15	0.021									8	6.4	0.01		
9/5/15	0.020									7.9	6.4	0.01		
9/6/15	0.020									7.9	6.3	0.01		
9/7/15	0.045									7.2	6	0.01		
9/8/15	0.022	6	2	1.40		1.116	0.372	0.260	2.55	7.5	6.1	0.01	17.76	
9/9/15	0.022				7					7.4	6.2	0.01		
9/10/15	0.020									7.4	6.2	0.01		
9/11/15	0.021									7.8	6.1	0.01		
9/12/15	0.022									7.9	6.6	0.01		
9/13/15	0.022									7.8	6.5	0.01		
9/14/15	0.023									7.5	6.1	0.01		
9/15/15	0.020	10	2	1.20		1.694	0.339	0.203	2.95	7.4	6.2	0.01	18.36	
9/16/15	0.021				1					7.4	6.2	0.01		
9/17/15	0.019									7.5	6	0.01		
9/18/15	0.018									7.5	6	0.01		
9/19/15	0.022									7.6	6	0.01		
9/20/15	0.026									7.6	6	0.01		
9/21/15	0.025									7.5	6.1	0.01		
9/22/15	0.023	5	2	0.81		0.943	0.377	0.153	1.91	7.5	6.1	0.01	13.56	
9/23/15	0.021				1					7.6	6	0.01		
9/24/15	0.019									7.5	6.1	0.01		
9/25/15	0.019									7.3	6.2	0.01		
9/26/15	0.022									7.5	6.2	0.01		
9/27/15	0.023									7.7	6.1	0.01		
9/28/15	0.020									7.7	6.1	0.01		
9/29/15	0.045									7.7	6.1	0.01		
9/30/15	0.034									7.8	6.4	0.01		
10/1/15														
Average	0.023	7	2.00	1.00	1.63	1	0.355	0.20	2.5	7.61	6	0.01	15.71	
Maximum	0.045	10	2.00	1.40	7.00	2	0.377	0.26	3.0	8.00	7	0.01	18.36	
Exceed.	0	0	0	0.00	0	0	0	0	0					