



MSD

*Louisville and Jefferson County Metropolitan Sewer District
700 West Liberty Street
Louisville Kentucky 40203-1911
502-540-6000
www.msdlouky.org*

February 23, 2009

Ms. Carolena Bentley
DMR Coordinator
200 Fair Oaks Lane
Frankfort, Kentucky 40601

**Re: MSD Metro Operations
Glenview Bluff WTP
KPDES No.: KY0044261
Discharge Monitoring Reports – January 2009**

Dear Ms. Thurman:

Attached is the Discharge Monitoring Reports (DMRs) for the Glenview Bluff WTP, KPDES No.: KY0044261 for the Fourth quarter of 2008.

If you have any questions concerning the attached DMRs, please contact me at (502)241-9093.

Sincerely,

D.J Rheinlaender
Process Supervisor, East Region

DJR/Glenview Bluff 0109

Enclosures

cc: C. Roth (DOW Louisville)
E. Brady
T. Singleton
P. Burgin
R. Shaw



*Beneficial Use of Louisville's Biosolids
www.louisvillegreen.com*

NAME: GLENVIEW BLUFF STP MSD
ADDRESS: C/O CEDAR CREEK STP
8405 CEDAR CREEK RD
LOUISVILLE KY 40211
FACILITY: GLENVIEW BLUFF STP MSD
LOCATION: LOUISVILLE KY 40222
ATTN: DENNIS THOMASSON, SR METRO OPS

KY0044261
PERMIT NUMBER

001 1
DISCHARGE NUMBER

MINOR
(SUBR LV)
F - FINAL

JEFFE

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
07	01	01		07	03	31

SANITARY WASTEWATER
EFFLUENT

*** NO DISCHARGE ***

NOTE: Read Instructions before completing this form.

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE	
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS				
OXYGEN, DISSOLVED (DO)	00300 1 0 0	*****	*****		10.0	*****	*****	(19)		1/30	Grab	
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	7	*****	*****			STRLY	GRAB	
PH	00400 1 0 0	*****	*****		6.4	*****	*****	(12)		1/30	Grab	
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	5.0	*****	9.0			STRLY	GRAB	
SOLIDS, TOTAL SUSPENDED	00530 1 0 0	*****	*****	(26)	*****	*****	*****	(19)		1/30	Grab	
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	3.50	5.00	LBS/DY	30	30	60			STRLY	COMPOE	
NITROGEN, AMMONIA TOTAL (AS N)	00610 1 2 0	*****	*****	(26)	*****	*****	*****	(19)		1/30	Grab	
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	0.83	1.67	LBS/DY	10	10	20			STRLY	COMPOE	
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	50050 1 0 0	*****	*****	(03)	*****	*****	*****			1/30	Grab	
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	REPORT	REPORT	MGD	*****	*****	*****	****		WEEKLY	INSTAN	
COLIFORM, FECAL GENERAL	74055 1 0 0	*****	*****		*****	*****	*****	(13)		1/30	Grab	
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	200	200	400	*/		STRLY	GRAB	
BOD, CARBONACEOUS 05 DAY, 20C	00082 1 0 0	*****	*****	(26)	*****	*****	*****	(19)		1/30	Grab	
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	2.50	5.00	LBS/DY	30	30	60			STRLY	COMPOE	
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.				SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT			TELEPHONE		DATE		
TYPED OR PRINTED								AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

Glenview Bluff		Report for		Jan-01		Tot. Exc.=		0	
Tot. Flow= 0.025				Concentrations				Pounds	
Date	Flow	TSS	BOD	NH3	Fecal	TSS	BOD	NH3	
1/1/01	0.000102								
1/2/01									
1/3/01									
1/4/01	0.001135								
1/5/01	0.001								
1/6/01	0.000922								
1/7/01	0.000655								
1/8/01	0.000823								
1/9/01									
1/10/01									
1/11/01									
1/12/01	0.000808								
1/13/01	0.00073								
1/14/01	0.000803								
1/15/01	0.000849								
1/16/01									
1/17/01									
1/18/01	0.0015								
1/19/01	0.00094								
1/20/01	0.000796	3	3	0.67	1	0.020	0.020	0.004	
1/21/01	0.001052								
1/22/01									
1/23/01									
1/24/01									
1/25/01	0.000718								
1/26/01	0.000513								
1/27/01									
1/28/01	0.000333								
1/29/01	0.000718								
1/30/01									
1/31/01									
Average	0.001	3.00	3.00	0.67	1.00	0.02	0.02	0.00	
Maximum	0.002	3.00	3.00	0.67	1.00	0.02	0.02	0.00	
	0	0	0	0	0	0	0	0	

Minimum 0.000102 MIN. MAX
DO (min)
pH

This plant has a summer ammonia limit of 4/8 mg/L and 0.33/0.66 pounds
This plant has a winter ammonia limit of 10/20 mg/L and 0.83/1.67 pounds
Winter limits are from November - April, Summer is from May - October