



Louisville and Jefferson County Metropolitan Sewer District
700 West Liberty Street
Louisville Kentucky 40203-1911
502-540-6000
www.msdlouky.org

August 16, 2013

Cheryl Edwards
Kentucky Division of Water
200 Fair Oaks Lane
Frankfort, Kentucky 40601

Re: MSD Metro Operations
Ken Carla WQTC; KPDES No.: KY 0022497
Discharge Monitoring Reports for July 2013.

Dear Ms. Edwards:

Attached is the Discharge Monitoring Reports (DMRs) and the Monthly Operator Report (MOR) for the Ken Carla WQTC; KPDES No.: KY0022497 for the month of July 2013.

There were no exceedences, overflows or bypass reports for this month.

If you have any questions concerning the attached DMRs, please contact me at (502)587-5856.

Sincerely,

A handwritten signature in black ink that reads "Kevin Thompson". The signature is fluid and cursive, with the first name "Kevin" being more prominent than the last name "Thompson".

Kevin Thompson
Process Supervisor, East Region

KT/Ken Carla 07/13.

Enclosures

cc: T. Singleton
R. Shaw



Beneficial Use of Louisville's Biosolids
www.louisvillegreen.com

DMR Copy of Record

Permit			
Permit #:	KY0022497	Permittee:	KEN CARLA WQTC MSD
Major:	No	Permittee Address:	8701 LYNNHALL CT LOUISVILLE, KY 40059
Permitted Feature:	001 External Outfall	Discharge:	001-1 SANITARY WASTEWATER
Facility:		Facility Location:	KEN CARLA WQTC MSD 8701 LYNNHALL CT LOUISVILLE, KY 40059

Report Dates & Status			
Monitoring Period:	From 07/01/13 to 07/31/13	DMR Due Date:	10/28/13
Status:	NetDMR Validated		

Considerations for Form Completion			
Principal Executive Officer			
First Name:	Greg	Title:	Executive Director
Last Name:	Heitzman	Telephone:	502-540-6000

No Data Indicator (NODI)
Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type	
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample					=	8					19 - mg/L	01/01 - Daily	GR - GRAB
					Permit Req.					>=	2 INST MIN					19 - mg/L	01/30 - Monthly	GR - GRAB
					Value NODI													
00310	BOD, 5-day, 20 deg. C	1 - Effluent Gross	0	--	Sample	=	0.05	=	0.05	26 - lb/d	=	2	=	2	19 - mg/L	01/30 - Monthly	CP - COMPOS	
					Permit Req.	<=	2.5 30DA AVG	<=	5 DAILY MX	26 - lb/d	<=	30 30DA AVG	<=	60 DAILY MX	19 - mg/L	01/30 - Monthly	CP - COMPOS	
					Value NODI													
00400	pH	1 - Effluent Gross	0	--	Sample					=	7				12 - SU	01/01 - Daily	GR - GRAB	
					Permit Req.					>=	6 MINIMUM			<=	9 MAXIMUM	12 - SU	01/30 - Monthly	GR - GRAB
					Value NODI													
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	0.14	=	0.14	26 - lb/d	=	6	=	6	19 - mg/L	01/30 - Monthly	CP - COMPOS	
					Permit Req.	<=	2.5 30DA AVG	<=	5 DAILY MX	26 - lb/d	<=	30 30DA AVG	<=	60 DAILY MX	19 - mg/L	01/30 - Monthly	CP - COMPOS	
					Value NODI													
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	0	--	Sample	=	0.02	=	0.02	26 - lb/d	=	0.7	=	0.7	19 - mg/L	01/30 - Monthly	CP - COMPOS	
					Permit Req.	<=	1.67 30DA AVG	<=	3.34 DAILY MX	26 - lb/d	<=	20 30DA AVG	<=	40 DAILY MX	19 - mg/L	01/30 - Monthly	CP - COMPOS	
					Value NODI													
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample					=	0.2	=	0.2	19 - mg/L	01/30 - Monthly	CP - COMPOS		
					Permit Req.							Req Mon 30DA AVG		Req Mon DAILY MX	19 - mg/L	01/30 - Monthly	CP - COMPOS	
					Value NODI													
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.003	=	0.009	03 - MGD						99/99 - Continuous	CN - CONTIN	
					Permit Req.		Req Mon 30DA AVG		Req Mon INST MAX	03 - MGD						05/07 - Weekdays	IN - INSTAN	
					Value NODI													
74055	Coliform, fecal general	1 - Effluent Gross	0	--	Sample					=	2	=	2	13 - #/100mL	01/30 - Monthly	GR - GRAB		
					Permit Req.					<=	200 30DA GEO	<=	400 7 DA GEO	13 - #/100mL	01/30 - Monthly	GR - GRAB		
					Value NODI													

Submission Note
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors
No errors.

Comments

Attachments		
Name	Type	Size
KenCarla072013_Coverletter.pdf	pdf	14206
KenCarla072013_MOR.pdf	pdf	6028

Report Last Saved By
KEN CARLA WQTC MSD

User:	kevin.thompson@louisvillemsd.org	Date/Time:	2013-08-27 14:22 (Time Zone: -04:00)
Name:	Kevin Thompson		
E-Mail:	kevin.thompson@louisvillemsd.org		

Ken Carla		Report for		Jul-13		Tot. Exc.=		0				
Tot. Flow=	0.090717	Concentrations				Pounds						
Date	Flow	TSS	BOD	NH3	Fecal	TSS	BOD	NH3	Tot. Phos.	D.O.	p.H.	TRC
7/1/13	0.003									8.5	7.7	
7/2/13	0.003	6	2	0.67		0.141	0.047	0.016	0.178	8	7.5	
7/3/13	0.003				2					8.3	7.6	
7/4/13	0.009									8	7.5	
7/5/13	0.003									8.2	7.7	
7/6/13	0.007									8.4	7.5	
7/7/13	0.002									8.6	7.5	
7/8/13	0.003									8.5	7.5	
7/9/13	0.003									8.3	7.4	
7/10/13	0.005									8	7.6	
7/11/13	0.003									8.1	7.4	
7/12/13	0.001									8	7.5	
7/13/13	0.002									8	7.6	
7/14/13	0.002									7.9	7.3	
7/15/13	0.002									9.2	8.4	
7/16/13	0.002									7.9	7.3	
7/17/13	0.002									8.6	7.4	
7/18/13	0.003									8.4	7.6	
7/19/13	0.003									8.3	7.4	
7/20/13	0.002									8.6	7.4	
7/21/13	0.003									9.1	7.6	
7/22/13	0.006									8.2	7.6	
7/23/13	0.002									8.5	7.5	
7/24/13	0.002									8.6	7.3	
7/25/13	0.003									8.4	7.3	
7/26/13	0.001									8.4	7.3	
7/27/13	0.002									7.7	8	
7/28/13	0.002									8.4	7.6	
7/29/13	0.002									8.4	7.6	
7/30/13	0.002									8.6	7.7	
7/31/13	0.002								0.172	8.5	7.5	
Average	0.003	6	2	0.7	2.00	0.141	0.047	0.02	0.2	8.34	8	0.00
Maximum	0.009	6	2	0.7	2.00	0.141	0.047	0.02	0.2	9.20	8	0.00
Exceed.	0	0	0	0	0	0	0	0				