

# MSD

Metropolitan Sewer District

Louisville and Jefferson County Metropolitan Sewer District  
700 West Liberty Street  
Louisville Kentucky 40203-1911  
502-540-6000  
www.msdlouky.org

May 15, 2014

Cheryl Edwards  
DMR Coordinator  
200 Fair Oaks Lane  
Frankfort, Kentucky 40601

**Re: MSD Metro Operations  
Timber Lake WQTC; KPDES No.: KY 0043087  
Discharge Monitoring Report for April 2014**

Dear Ms. Edwards:

Attached are the Discharge Monitoring Reports (DMRs) and the Monthly Operator Report (MOR) for the Timber Lake WQTC; KPDES No.: KY0043087 for the month of April 2014

There were no exceedences, bypasses or overflows to report.

If you have any questions concerning the attached DMRs, please contact me at (502) 587-5832.

Sincerely,



Richard Mills  
Process Supervisor of Metro Operations

RM/ Timber Lake 04/14

Enclosures

CC T. Singleton  
R. Shaw



Beneficial Use of Louisville's Biosolids  
www.louisvillegreen.com



51040	E. coli	Gross	0	--	Req.							<=	130 30DA GEO	<=	240 7 DA GEO	#/100mL	0	01/07 - Weekly	GR - GRAB
					Value NODI														
					Sample	=	2.3	=	3	26 - lb/d		=	3	=	5	19 - mg/L		01/07 - Weekly	CP - COMPOS
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Permit Req.	<=	16.7 30DA AVG	<=	25 DAILY MX	26 - lb/d		<=	10 30DA AVG	<=	15 DAILY MX	19 - mg/L	0	01/07 - Weekly	24 - COMP24
					Value NODI														

**Submission Note**

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**

No errors.

**Comments**

**Attachments**

Name	Type	Size
201404TimberLake_CoverLetter.pdf	pdf	17941
201404TimberLake_MOR.pdf	pdf	9506

**Report Last Saved By**

**TIMBERLAKE WQTC MSD**

User: kevin.thompson@louisvillemsd.org | Date/Time: 2014-12-15 12:09 (Time Zone: -05:00)  
Name: Kevin Thompson  
E-Mail: kevin.thompson@louisvillemsd.org

