



700 West Liberty Street | Louisville, KY 40203-1911
Phone: 502.540.6000 | LouisvilleMSD.org

January 20th, 2023

Crystal Dennis
300 Sower Blvd., 3rd Floor
Frankfort, Kentucky 40601

**RE: Hillview #3 STP, KPDES No: KY0034177
Discharge Monitoring Report for December 2022.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) for the Hillview #3 STP, for the month December 2022.

There were no overflows, bypasses

There were two exceedances for the month of December. Total Suspended Solids Monthly Average of 30.0 mg/l with a result of 32.0 mg/l and Total Suspended Solids Maximum Weekly Average limit of 45.0 mg/l with a result of 57.0 mg/l. These were a result of the Snow/ Ice that our area received in late December causing issues with the plant clarifier collector drive.

If you have any questions concerning the attached DMR's, please contact me at (502)587-5858.

Sincerely,

Joseph Shaun Smith
Process Supervisor

JSS/ HV#3 12/22.

Cc: V. Teague/B. Tinnell

DMR Copy of Record

Permit		Permit #: KY0034177		Permittee: Louisville and Jefferson County MSD		Facility: BCSD HILLVIEW #3	
Major: No		Permittee Address: 700 W Liberty St Louisville, KY 40203		Facility Location: 12325 WESTERN RD HILLVIEW, KY 40129			
Permitted Feature: 001 External Outfall		Discharge: 001-1 Domestic Wastewater					

Report Dates & Status			
Monitoring Period: From 12/01/22 to 12/31/22	DMR Due Date: 01/28/23	Status:	NetDMR Validated

Considerations for Form Completion

Principal Executive Officer			
First Name: James	Title: Executive Director	Telephone: 502-540-6000	
Last Name: Parrott			

No Data Indicator (NODI)			
Form NODI: --			

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type			
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units	
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample						=	7.22					19 - mg/L	01/07 - Weekly	GR - GRAB	
					Permit Req.					>=	7.0 INST MIN						19 - mg/L	01/07 - Weekly	GR - GRAB	
					Value NODI															
00400	pH	1 - Effluent Gross	0	--	Sample						=	6.8			=	8.65	12 - SU	01/07 - Weekly	GR - GRAB	
					Permit Req.					>=	6.0 MINIMUM			<=	9.0 MAXIMUM	12 - SU	01/07 - Weekly	GR - GRAB		
					Value NODI															
X 00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample						=	32.0			=	57.0	19 - mg/L	01/07 - Weekly	CP - COMPOS	
					Permit Req.					<=	30.0 MO AVG			<=	45.0 MX WK AV	19 - mg/L	01/07 - Weekly	CP - COMPOS		
					Value NODI															
00600	Nitrogen, total [as N]	1 - Effluent Gross	0	--	Sample						=	23.5			=	30.0	19 - mg/L	01/07 - Weekly	CP - COMPOS	
					Permit Req.															
					Value NODI															
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	2	--	Sample						=	0.43			=	0.6	19 - mg/L	01/07 - Weekly	CP - COMPOS	
					Permit Req.					<=	10.0 MO AVG			<=	15.0 DAILY MX	19 - mg/L	01/07 - Weekly	CP - COMPOS		
					Value NODI															
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample						=	3.06			=	5.0	19 - mg/L	01/07 - Weekly	CP - COMPOS	
					Permit Req.															
					Value NODI															
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.126	=	0.519	03 - MGD								99/99 - Continuous	RC - Recorder (auto)	
					Permit Req.															
					Value NODI															
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample						<	0.01			<	0.01	19 - mg/L	01/07 - Weekly	GR - GRAB	
					Permit Req.															
					Value NODI															
51040	E. coli	1 - Effluent Gross	0	--	Sample						=	91.0			=	6.0	13 - #/100mL	01/07 - Weekly	GR - GRAB	
					Permit Req.															
					Value NODI															
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample						=	12.0			=	14.0	19 - mg/L	01/07 - Weekly	CP - COMPOS	
					Permit Req.															
					Value NODI															

Submission Note
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors						
Code	Parameter Name	Monitoring Location	Field	Type	Description	Acknowledge
00530	Solids, total suspended	1 - Effluent Gross	Quality or Concentration Sample Value 3	Soft	The provided sample value is outside the permit limit. Please verify that the value you have provided is correct.	Yes
00530	Solids, total suspended	1 - Effluent Gross	Quality or Concentration Sample Value 2	Soft	The provided sample value is outside the permit limit. Please verify that the value you have provided is correct.	Yes

Comments

Attachments

Name	Type	Size
HV3Coverletter.pdf	pdf	38327.0

Report Last Saved By

Louisville and Jefferson County MSD

User: JOSEPH.SMITH@LOUISVILLEMSD.ORG
Name: Joseph Smith
E-Mail: joseph.smith@louisvillemmsd.org
Date/Time: 2023-01-23 09:51 (Time Zone: -05:00)

Report Last Signed By

User: JOSEPH.SMITH@LOUISVILLEMSD.ORG
Name: Joseph Smith
E-Mail: joseph.smith@louisvillemmsd.org
Date/Time: 2023-01-23 09:51 (Time Zone: -05:00)