



700 West Liberty Street | Louisville, KY 40203-1911  
Phone: 502.540.6000 | LouisvilleMSD.org

April 12th, 2023

Crystal Dennis  
300 Sower Blvd., 3rd Floor  
Frankfort, Kentucky 40601

**RE: Country Village STP, KPDES No: KY0060577  
Discharge Monitoring Report for March 2023.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) for the Country Village STP, for the month March 2023.

There were no overflows, exceedances or bypasses.

If you have any questions concerning the attached DMR's, please contact me at (502)587-5858.

Sincerely,

Curt Otto  
Process Supervisor

CEO/ AA 03/23.

Cc: V. Teague, B. Tinnel

DMR Copy of Record

<b>Permit</b>		<b>Permit #:</b> KY0060577		<b>Permittee:</b> Louisville and Jefferson County MSD		<b>Facility:</b> COUNTRY VILLAGE WWTP	
<b>Major:</b> No		<b>Permittee Address:</b> 700 W Liberty St Louisville, KY 40203		<b>Facility Location:</b> 4619 TIMOTHY WAY CRESTWOOD, KY 40014			
<b>Permitted Feature:</b> 001 External Outfall		<b>Discharge:</b> 001-1 Domestic Wastewater					

<b>Report Dates &amp; Status</b>			
<b>Monitoring Period:</b> From 03/01/23 to 03/31/23	<b>DMR Due Date:</b> 04/28/23	<b>Status:</b>	<b>NetDMR Validated</b>

**Considerations for Form Completion**

<b>Principal Executive Officer</b>			
<b>First Name:</b> James	<b>Title:</b> Executive Director	<b>Telephone:</b> 502-540-6000	
<b>Last Name:</b> Parrot			

**No Data Indicator (NODI)**  
Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type			
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units	
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample						=	11.2					19 - mg/L	01/30 - Monthly	GR - GRAB	
					Permit Req.						>=	7.0 INST MIN						19 - mg/L	01/30 - Monthly	GR - GRAB
					Value NODI															
00400	pH	1 - Effluent Gross	0	--	Sample						=	8.38			=	8.38	12 - SU	01/30 - Monthly	GR - GRAB	
					Permit Req.						>=	6.0 MINIMUM			<=	9.0 MAXIMUM	12 - SU	01/30 - Monthly	GR - GRAB	
					Value NODI															
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample						=	11.0			=	11.0	19 - mg/L	01/30 - Monthly	CP - COMPOS	
					Permit Req.						<=	30.0 MO AVG			<=	45.0 MX WK AV	19 - mg/L	01/30 - Monthly	CP - COMPOS	
					Value NODI															
00600	Nitrogen, total [as N]	1 - Effluent Gross	0	--	Sample						=	12.3			=	12.3	19 - mg/L	01/30 - Monthly	GR - GRAB	
					Permit Req.															
					Value NODI															
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	2	--	Sample						=	0.6			=	0.6	19 - mg/L	01/30 - Monthly	CP - COMPOS	
					Permit Req.						<=	10.0 MO AVG			<=	15.0 DAILY MX	19 - mg/L	01/30 - Monthly	CP - COMPOS	
					Value NODI															
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample						=	2.0			=	2.0	19 - mg/L	01/30 - Monthly	GR - GRAB	
					Permit Req.															
					Value NODI															
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.052	=	0.153	03 - MGD								01/30 - Monthly	RC - Recorder (auto)	
					Permit Req.															
					Value NODI															
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample						<	0.01			<	0.01	19 - mg/L	01/30 - Monthly	GR - GRAB	
					Permit Req.						<=	0.011 MO AVG			<=	0.019 DAILY MX	19 - mg/L	01/30 - Monthly	GR - GRAB	
					Value NODI															
51040	E. coli	1 - Effluent Gross	0	--	Sample						=	49.0			=	49.0	13 - #/100mL	01/30 - Monthly	GR - GRAB	
					Permit Req.						<=	130.0 30DA GEO			<=	240.0 7 DA GEO	13 - #/100mL	01/30 - Monthly	GR - GRAB	
					Value NODI															
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample						=	5.0			=	5.0	19 - mg/L	MEASD - Measured	CP - COMPOS	
					Permit Req.						<=	25.0 MO AVG			<=	37.5 MX WK AV	19 - mg/L	MEASD - Measured	CP - COMPOS	
					Value NODI															

**Submission Note**  
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**  
No errors.

**Comments**

<b>Attachments</b>		
Name	Type	Size

CVCover.pdf	pdf	32575.0
-------------	-----	---------

**Report Last Saved By**  
**Louisville and Jefferson County MSD**

User: CURT.OTTO@LOUISVILLEMSD.ORG  
Name: Curt Otto  
E-Mail: curt.otto@louisvillemsd.org  
Date/Time: 2023-04-17 10:02 (Time Zone: -04:00)

**Report Last Signed By**

User: CURT.OTTO@LOUISVILLEMSD.ORG  
Name: Curt Otto  
E-Mail: curt.otto@louisvillemsd.org  
Date/Time: 2023-04-17 10:54 (Time Zone: -04:00)