



700 West Liberty Street | Louisville, KY 40203-1911  
Phone: 502.540.6000 | LouisvilleMSD.org

September 21, 2023

Crystal Dennis  
Permit Support Section  
Surface Water Permits Branch  
Division of Water  
300 Sower Blvd, 3rd Floor  
Frankfort, Kentucky 40601

**RE: Floyds Fork WQTC, KPDES No: KY0102784  
Discharge Monitoring Report for August 2023.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) and the Monthly Operating Report (MOR) for the Floyds Fork Water Quality Treatment Center for the month of August 2023.

There were no bypasses, overflows, or exceedances.

If you have any questions concerning the attached DMR's, please contact me at (502)540-6952.

Sincerely,

William Ford  
Process Supervisor-Operations

WEF/ Floyds Fork 09/23

Cc: V. Teague  
B. Tinnel



81011	<b>Solids, suspended percent removal</b>	K - Percent Removal	0	--	Sample	=	100.0							23 - %	01/30 - Monthly	CA - CALCTD
					Permit Req.	>=	85.0 MO AV MN							23 - %	01/30 - Monthly	CA - CALCTD
					Value NODI											

**Submission Note**

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**

No errors.

**Comments**

**Attachments**

Name	Type	Size
FFCoverletter082023.pdf	pdf	34607.0
FFMOR082023.pdf	pdf	186366.0

**Report Last Saved By**

**Floyds Fork WQTC MSD**

User: WILLIAM.FORD@LOUISVILLEMSD.ORG  
 Name: William Ford  
 E-Mail: william.ford@louisvillemmsd.org  
 Date/Time: 2023-09-21 15:08 (Time Zone: -04:00)

**Report Last Signed By**

User: WILLIAM.FORD@LOUISVILLEMSD.ORG  
 Name: William Ford  
 E-Mail: william.ford@louisvillemmsd.org  
 Date/Time: 2023-09-21 15:08 (Time Zone: -04:00)



NAME OF TREATMENT PLANT    Floyds Fork

COUNTY    Jefferson

Month of:                    August        2023

Avg. Flow:                    2.97

		Sludge Disposal	
Date	Rainfall	in Gallons	Remarks
1		63000	
2		69300	
3		63000	
4		44100	
5		0	
6		0	
7		69300	
8		63000	
9		56700	
10		41000	
11		31300	
12		0	
13		0	
14		63000	
15		63000	
16		63000	
17		63000	
18		63000	
19		0	
20		0	
21		63000	
22		63000	
23		63000	
24		63000	
25		63000	
26		0	
27		0	
28		63000	
29		63000	
30		107100	
31		157500	