



700 West Liberty Street | Louisville, KY 40203-1911
Phone: 502.540.6000 | LouisvilleMSD.org

December 18, 2023

Crystal Dennis
300 Sower Blvd., 3rd Floor
Frankfort, Kentucky 40601

**RE: Hillview #1 STP, KPDES No: KY0034151
Discharge Monitoring Report for November 2023.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) for the Hillview #1 STP, for the month of November 2023.

There were no overflows, exceedances, discharges, or bypasses.

If you have any questions concerning the attached DMR's, please contact me at (502)587-5858.

Sincerely,

Jon Baldrige
Process Supervisor

JSS/ HV#1 11/23.

Cc: V. Teague / B. Tinnell

DMR Copy of Record

Permit			
Permit #:	KY0034151	Permittee:	Louisville and Jefferson County MSD
Major:	No	Permittee Address:	700 W Liberty St Louisville, KY 40203
Permitted Feature:	001 External Outfall	Discharge:	001-1 SANITARY WASTEWATER
Facility:		Facility Location:	BCSD HILLVIEW SEWER SYSTEM PLT #1 4998 LEES LN HILLVIEW, KY 40129

Report Dates & Status			
Monitoring Period:	From 11/01/23 to 11/30/23	DMR Due Date:	12/28/23
Status:	NetDMR Validated		

Considerations for Form Completion

Principal Executive Officer			
First Name:	James A.	Title:	Executive Director
Last Name:	Parrott	Telephone:	502-540-6000

No Data Indicator (NODI)
Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type		
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample	=	7.0				=	7.0				19 - mg/L	0	01/07 - Weekly	GR - GRAB
					Permit Req.	>=	7.0 MINIMUM								19 - mg/L	01/07 - Weekly		GR - GRAB	
					Value NODI														
00400	pH	1 - Effluent Gross	0	--	Sample	=	6.7				=	7.2			12 - SU	0	01/07 - Weekly	GR - GRAB	
					Permit Req.	>=	6.0 MINIMUM								12 - SU		01/07 - Weekly	GR - GRAB	
					Value NODI														
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	21.4	=	47.4	26 - lb/d	=	26.0	=	43.0	19 - mg/L	0	01/07 - Weekly	CP - COMPOS	
					Permit Req.	<=	57.7 MO AVG	<=	86.6 MX WK AV	26 - lb/d	<=	30.0 MO AVG	<=	45.0 MX WK AV	19 - mg/L		01/07 - Weekly	CP - COMPOS	
					Value NODI														
00600	Nitrogen, total [as N]	1 - Effluent Gross	0	--	Sample						=	27.0	=	44.2	19 - mg/L	0	01/07 - Weekly	GR - GRAB	
					Permit Req.										19 - mg/L		01/07 - Weekly	GR - GRAB	
					Value NODI														
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	2	--	Sample	=	4.0	=	14.0	26 - lb/d	=	4.08	=	12.7	19 - mg/L	0	01/07 - Weekly	CP - COMPOS	
					Permit Req.	<=	19.2 MO AVG	<=	28.8 MX WK AV	26 - lb/d	<=	10.0 MO AVG	<=	15.0 DAILY MX	19 - mg/L		01/07 - Weekly	CP - COMPOS	
					Value NODI														
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample						=	27.0	=	44.2	19 - mg/L	0	01/07 - Weekly	GR - GRAB	
					Permit Req.										19 - mg/L		01/07 - Weekly	GR - GRAB	
					Value NODI														
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.125	=	0.18	03 - MGD						0	99/99 - Continuous	IN - INSTAN	
					Permit Req.												99/99 - Continuous	IN - INSTAN	
					Value NODI														
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample						<	0.01	<	0.01	19 - mg/L	0	01/07 - Weekly	GR - GRAB	
					Permit Req.												19 - mg/L	01/07 - Weekly	GR - GRAB
					Value NODI														
51040	E. coli	1 - Effluent Gross	0	--	Sample						=	1.8	<	11.0	13 - #/100mL	0	01/07 - Weekly	GR - GRAB	
					Permit Req.												13 - #/100mL	01/07 - Weekly	GR - GRAB
					Value NODI														
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample	=	8.1	=	12.1	26 - lb/d	=	12.0	=	15.0	19 - mg/L	0	01/07 - Weekly	CP - COMPOS	
					Permit Req.	<=	28.8 MO AVG	<=	43.2 MX WK AV	26 - lb/d	<=	15.0 MO AVG	<=	22.5 MX WK AV	19 - mg/L		01/07 - Weekly	CP - COMPOS	
					Value NODI														

Submission Note
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors
No errors.

Comments

Attachments

Name	Type	Size
------	------	------

hillview1cover(2).pdf

pdf

33842.0

Report Last Saved By

Louisville and Jefferson County MSD

User: JON.BALDRIDGE@LOUISVILLEMSD.ORG
Name: Jonathan Baldrige
E-Mail: jon.baldrige@louisvillemmsd.org
Date/Time: 2023-12-18 11:34 (Time Zone: -05:00)

Report Last Signed By

User: JON.BALDRIDGE@LOUISVILLEMSD.ORG
Name: Jonathan Baldrige
E-Mail: jon.baldrige@louisvillemmsd.org
Date/Time: 2023-12-18 11:38 (Time Zone: -05:00)