



700 West Liberty Street | Louisville, KY 40203-1911  
Phone: 502.540.6000 | LouisvilleMSD.org

June 18th, 2023

Crystal Dennis  
300 Sower Blvd., 3rd Floor  
Frankfort, Kentucky 40601

**RE: Hillview #2 STP, KPDES No: KY00034169  
Discharge Monitoring Report for May 2023.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) for the Hillview #2 WQTC, for the month May 2023.

There were no overflows.

During the Month of May we had one exceedance, the Nitrogen Ammonia Daily Maximum limit of 6.0 mg/l with a result of 10.7 mg/l. This was caused by a faulty blower shutting down due to heat, the problem has been corrected.

Also Attached is the Monthly Discharge Report

If you have any questions concerning the attached DMR's, please contact me at (502)587-5858.

Sincerely,

Joseph Shaun Smith  
Treatment Facilities Manager

JSS/ HV#2 05/23.

Cc: V. Teague /B. Tinnell

DMR Copy of Record

<b>Permit</b>			
Permit #:	KY0034169	Permittee:	Hillview Sewer System Plant 2
Major:	No	Permittee Address:	PO Box 818 Hillview, KY 40129
Permitted Feature:	001 External Outfall	Discharge:	001-1 Domestic Wastewater
Facility:	BCSD HILLVIEW #2	Facility Location:	376 NORWOOD WAY HILLVIEW, KY 40229

<b>Report Dates &amp; Status</b>			
Monitoring Period:	From 05/01/23 to 05/31/23	DMR Due Date:	06/28/23
Status:	NetDMR Validated		

**Considerations for Form Completion**

<b>Principal Executive Officer</b>			
First Name:	James	Title:	Executive Director
Last Name:	Parrott	Telephone:	502-540-6000

**No Data Indicator (NODI)**  
Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type			
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units	
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample					=	7.8					19 - mg/L	01/07 - Weekly	GR - GRAB		
					Permit Req.					>=	7.0 INST MIN					19 - mg/L	01/07 - Weekly	GR - GRAB		
					Value NODI															
00400	pH	1 - Effluent Gross	0	--	Sample					=	6.89			=	7.42	12 - SU	01/07 - Weekly	GR - GRAB		
					Permit Req.					>=	6.0 MINIMUM			<=	9.0 MAXIMUM	12 - SU	01/07 - Weekly	GR - GRAB		
					Value NODI															
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample					=	24.0			=	39.0	19 - mg/L	01/07 - Weekly	CP - COMPOS		
					Permit Req.					<=	30.0 MO AVG			<=	45.0 MX WK AV	19 - mg/L	01/07 - Weekly	CP - COMPOS		
					Value NODI															
00600	Nitrogen, total [as N]	1 - Effluent Gross	0	--	Sample					=	20.3			=	23.8	19 - mg/L	01/07 - Weekly	GR - GRAB		
					Permit Req.															
					Value NODI															
X 00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	1	--	Sample					=	4.0			=	10.7	19 - mg/L	01/07 - Weekly	CP - COMPOS		
					Permit Req.					<=	4.0 MO AVG			<=	6.0 DAILY MX	19 - mg/L	01/07 - Weekly	CP - COMPOS		
					Value NODI															
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample					=	2.71			=	3.92	19 - mg/L	01/07 - Weekly	GR - GRAB		
					Permit Req.															
					Value NODI															
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample		0.226		0.47									01/07 - Weekly	IN - INSTAN	
					Permit Req.															
					Value NODI															
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample					<	0.01			<	0.01	19 - mg/L	01/07 - Weekly	GR - GRAB		
					Permit Req.															
					Value NODI															
51040	E. coli	1 - Effluent Gross	0	--	Sample					=	1.0			=	1.0	13 - #/100mL	01/07 - Weekly	GR - GRAB		
					Permit Req.															
					Value NODI															
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample					=	11.0			=	18.0	19 - mg/L	01/07 - Weekly	CP - COMPOS		
					Permit Req.															
					Value NODI															

**Submission Note**  
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

<b>Edit Check Errors</b>						
Code	Parameter Name	Monitoring Location	Field	Type	Description	Acknowledge
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	Quality or Concentration Sample Value 3	Soft	The provided sample value is outside the permit limit. <b>Please verify that the value you have provided is correct.</b>	Yes

**Comments**

**Attachments**

Name	Type	Size
HV2Coverletter0523.pdf	pdf	36640.0
05_May_discharge_report_all_service_fin.pdf	pdf	42543.0

**Report Last Saved By**

**Hillview Sewer System Plant 2**

User: JOSEPH.SMITH@LOUISVILLEMSD.ORG  
Name: Joseph Smith  
E-Mail: joseph.smith@louisvillemsd.org  
Date/Time: 2023-06-16 07:50 (Time Zone: -04:00)

**Report Last Signed By**

User: JOSEPH.SMITH@LOUISVILLEMSD.ORG  
Name: Joseph Smith  
E-Mail: joseph.smith@louisvillemsd.org  
Date/Time: 2023-06-16 07:50 (Time Zone: -04:00)



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0102784	MSD0294	FLOYDS FORK	FLOYDS FORK	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	107166	2400 ARNOLD PALMER BLVD	FLOYDS FORK	FLOYD FORK	GROUND

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISDW: DRY WEATHER DISCHARGE	3649027		5/10/2023 7:40:00 PM	BOWLIN JR		REPAIRED - ISSUE RESOLVED	5/11/2023 12:00:00 AM	OBSTRUCTION-NOT GREASE / ROOTS	UNAUTHORIZED DISCHARGE-WATERS	05/11/23 02:00 PM	MAIN

**Discharge Reporting:**

Discharge Amount:	800 GAL
Cause:	OBSTRUCITON IN THE MAIN SEWER.
Clean Up:	MSD PERSONNEL CLEANED THE IMPACTED AREA.
Control Zone:	PLACED TEMPORARY DISCHARGE SIGNAGE AROUND IMPACTED AREA.
Impact:	SEWAGE / DEBRIS AROUND CLEANOUT.
Repair:	REFERRED TO THE AREA SUPERVISOR FOR REPAIRS.
Public Notification:	ADVISED ON SITE.

**Notifications:**

5/11/23 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
5/11/23 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



**IMSAST0004  
Overflow Report  
5/1/2023 12:00:00 AM to 5/31/2023 12:00:00 AM**

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Treatment Plant	MSD0278	4522 ALGONQUIN PKY	MORRIS FORMAN	OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISDW: DRY WEATHER DISCHARGE	3643700		5/1/2023 9:16:00 AM	BURDIN		REPAIRED - ISSUE RESOLVED	5/1/2023 12:00:00 AM	BYPASS AT WQTC	UNAUTHORIZED DISCHARGE- WATERS	05/01/23 10:30 PM	

**Discharge Reporting:**

Discharge Amount:	45,000,000 GAL
Cause:	BYPASS AT TREATMENT PLANT. HYPO VALVE NOT OPENED CORRECTLY. NO DISINFECTION OCCURRED FOR 45 MG.
Clean Up:	NA- DISCHARGED TO RIVER.
Control Zone:	NA.
Impact:	NA.
Repair:	VALVE FAILURE FIXED.
Public Notification:	PERMANENT SIGNS.

**Notifications:**

5/2/23 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
----------------	--------	---



**IMSAST0004  
Overflow Report  
5/1/2023 12:00:00 AM to 5/31/2023 12:00:00 AM**

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Treatment Plant	MSD0278	4522 ALGONQUIN PKY	MORRIS FORMAN	OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISDW: DRY WEATHER DISCHARGE	3657576		5/25/2023 5:10:00 PM	BURDIN		REPAIRED - ISSUE RESOLVED	5/1/2023 12:00:00 AM	MECHANICAL FAILURE	UNAUTHORIZED DISCHARGE- WATERS	05/23/23 05:20 PM	

**Discharge Reporting:**

Discharge Amount:	3,000 GAL
Cause:	PARSHALL FLUME MUD VALVE OPEN.
Clean Up:	PIPE DISCHARGE SUBMERGED- NO CLEANUP.
Control Zone:	PIPE DISCHARGE SUBMERGED- NO CONTROL ZONE.
Impact:	NA
Repair:	CLOSED VALVE.
Public Notification:	NA

**Notifications:**

5/25/23 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
-----------------	--------	---



**IMSAST0004**  
**Overflow Report**  
**5/1/2023 12:00:00 AM to 5/31/2023 12:00:00 AM**

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0034169	MSD0507	BCSD HILLVIEW #2	BROOKS RUN	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Treatment Plant	MSD0507	8405 CEDAR CREEK RD	BCSD HILLVIEW #2	BROOKS RUN	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3648675		5/8/2023 2:18:00 PM	SMITH		DOCUMENTED	12/6/2021 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	05/11/23 09:02 AM	

**Discharge Reporting:**

Discharge Amount:	3,050 GAL
Cause:	ELEVATED FLOW FROM RAIN EVENT.
Clean Up:	DEBRIS FROM CONCRETE DITCH.
Control Zone:	INSIDE PLANT.
Impact:	INF DISCHARGING TO CONCRETE DITCH.
Repair:	FLOW DECREASED ALLOWING PUMPS TO CATCH UP.
Public Notification:	TEMP SIGN NEAR FENCE.

**Notifications:**

5/9/23 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
5/9/23 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



**IMSAST0004**  
**Overflow Report**  
**5/1/2023 12:00:00 AM to 5/31/2023 12:00:00 AM**

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0034177	MSD0508	BCSD HILLVIEW #3	BROOKS RUN	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Treatment Plant	MSD0508	8405 CEDAR CREEK RD	BCSD HILLVIEW #3	BROOKS RUN	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3649362		5/14/2023 2:17:00 PM	ROY	FIELDS	QUEUED FOR INVESTIGATION / REPAIR	3/28/2023 12:00:00 AM	ELECTRICAL PROBLEMS AT MSD	UNAUTHORIZED DISCHARGE-WATERS	05/17/23 08:34 AM	

**Discharge Reporting:**

Discharge Amount:	1,500 GAL
Cause:	LEVEL SENSOR IN WET WELL MOVED AND NOT CALLING FOR INFLUENT PUMPS TO COME ON.
Clean Up:	NONE
Control Zone:	NONE
Impact:	NONE
Repair:	OPERATOR CLEANED AND REINSTALLED SENSOR AND THE PUMPS CAME ON.
Public Notification:	NONE

**Notifications:**

5/15/23 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
5/15/23 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION





**IMSAST0004**  
**Overflow Report**  
**5/1/2023 12:00:00 AM to 5/31/2023 12:00:00 AM**

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0034177	MSD0508	BCSD HILLVIEW #3	BROOKS RUN	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Treatment Plant	MSD0508	8405 CEDAR CREEK RD	BCSD HILLVIEW #3	BROOKS RUN	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3649791		5/17/2023 1:46:00 PM	SMITH		QUEUED FOR INVESTIGATION / REPAIR	3/28/2023 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	05/19/23 11:51 AM	

**Discharge Reporting:**

Discharge Amount:	750 GAL
Cause:	ELEVATED FLOW FROM RAIN AND POWER OUTAGE DUE TO A SQUIRREL GETTING INTO A LG&E LINE JACK.
Clean Up:	NONE NEEDED.
Control Zone:	ON PLANT.
Impact:	INF TO DISCHARGE MANHOLE.
Repair:	LG&E RESTORED POWER.
Public Notification:	TEMP SIGN.

**Notifications:**

5/18/23 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
5/18/23 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



**IMSAST0004**  
**Overflow Report**  
**5/1/2023 12:00:00 AM to 5/31/2023 12:00:00 AM**

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0034185	MSD0512	PIONEER VILLAGE #1	BROOKS RUN	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Treatment Plant	MSD0512	8405 CEDAR CREEK RD	PIONEER VILLAGE #1	BROOKS RUN	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3649792		5/17/2023 1:52:00 PM	SMITH		QUEUED FOR INVESTIGATION / REPAIR	3/7/2023 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	05/19/23 11:55 AM	

**Discharge Reporting:**

Discharge Amount:	450 GAL
Cause:	ELEVATED FLOW,#2 INF PUMP K/O DUE TO ELECTRICAL SHORT.
Clean Up:	NONE NEEDED.
Control Zone:	ON PLANT.
Impact:	INF DISCHARGING TO EFF MANHOLE.
Repair:	PUMP RESET, BACK UP PUMP INSTALLED.
Public Notification:	TEMP SIGN NEAR FENCE.

**Notifications:**

5/18/23 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
5/18/23 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



**IMSAST0004**  
**Overflow Report**  
**5/1/2023 12:00:00 AM to 5/31/2023 12:00:00 AM**

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0034185	MSD0512	PIONEER VILLAGE #1	BROOKS RUN	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Lift Station	MSD2021-PS	8405 CEDAR CREEK RD	PIONEER VILLAGE #1	BROOKS RUN	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3646383		5/7/2023 1:30:00 PM	SMITHER	SMITHER	DOCUMENTED	12/21/2022 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	05/11/23 09:00 PM	

**Discharge Reporting:**

Discharge Amount:	463,600 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	CLEANUP NOT POSSIBLE DUE AT THIS TIME.
Control Zone:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	SEWAGE/DEBRIS/SOLIDS/PERSONAL HYGIENE PRODUCTS FOUND IN THE STREAM.
Repair:	A SOLUTION FOR THIS LOCATION IS BEING WORKED ON.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.

**Notifications:**

5/8/23 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
5/8/23 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



**IMSAST0004**  
**Overflow Report**  
**5/1/2023 12:00:00 AM to 5/31/2023 12:00:00 AM**

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0034185	MSD0512	PIONEER VILLAGE #1	BROOKS RUN	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Lift Station	MSD2021-PS	8405 CEDAR CREEK RD	PIONEER VILLAGE #1	BROOKS RUN	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3649664		5/16/2023 2:16:00 PM	BUTLER	BUTLER	DOCUMENTED	12/21/2022 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	05/17/23 10:00 PM	

**Discharge Reporting:**

Discharge Amount:	212,900 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	CLEANUP NOT POSSIBLE DUE AT THIS TIME.
Control Zone:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	SEWAGE/DEBRIS/SOLIDS/PERSONAL HYGIENE PRODUCTS FOUND IN THE STREAM.
Repair:	A SOLUTION FOR THIS LOCATION IS BEING WORKED ON.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.

**Notifications:**

5/17/23 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
5/17/23 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0034185	MSD0512	PIONEER VILLAGE #1	BROOKS RUN	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Lift Station	MSD2021-PS	8405 CEDAR CREEK RD	PIONEER VILLAGE #1	BROOKS RUN	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3656957		5/20/2023 5:00:00 AM	BUTLER	BUTLER	DOCUMENTED	12/21/2022 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	05/23/23 12:15 PM	

**Discharge Reporting:**

Discharge Amount:	266,800 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	CLEANUP NOT POSSIBLE DUE AT THIS TIME.
Control Zone:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	SEWAGE/DEBRIS/SOLIDS/PERSONAL HYGIENE PRODUCTS FOUND IN THE STREAM.
Repair:	A SOLUTION FOR THIS LOCATION IS BEING WORKED ON.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.

**Notifications:**

5/20/23 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
5/20/23 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION