



700 West Liberty Street | Louisville, KY 40203-1911
Phone: 502.587.0603 | Fax: 502.540.6106 | louisvillemsd.org

August 18th, 2023

Crystal Dennis
300 Sower Blvd., 3rd Floor
Frankfort, Kentucky 40601

**RE: Hite Creek WQTC, KPDES No: KY0022420
Discharge Monitoring Report for July 2023.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) and the Monthly Operator Report (MOR) for the Hite Creek WQTC, for the month of July 2023.

There were no bypasses, overflows or exceedances.

If you have any questions concerning the attached DMR's, please contact me at (502)587-5858.

Sincerely,

Curt Otto
Process Supervisor

CEO/ Hite Creek. 7/23.

Cc: V. Teague
K. Robinson
M. Saylor

80091	BOD, carb-5 day, 20 deg C, percent removal	K - Percent Removal	0	--	Sample	=	97.0						23 - %	01/30 - Monthly	CA - CALCTD
					Permit Req.	>=	85.0 MO AV MN					23 - %	0	01/30 - Monthly	CA - CALCTD
					Value NODI										
81011	Solids, suspended percent removal	K - Percent Removal	0	--	Sample	=	97.0						23 - %	01/30 - Monthly	CA - CALCTD
					Permit Req.	>=	85.0 MO AV MN					23 - %	0	01/30 - Monthly	CA - CALCTD
					Value NODI										

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

Name	Type	Size
HiteCreekCover7_23.pdf	pdf	35210.0
HCMOR072023.xls	xls	335360.0

Report Last Saved By

Hite Creek WQTC MSD

User: staci.huber@louisvillemmsd.org
 Name: Staci Huber
 E-Mail: staci.huber@louisvillemmsd.org
 Date/Time: 2023-08-18 11:22 (Time Zone: -04:00)

Report Last Signed By

User: CURT.OTTO@LOUISVILLEMSD.ORG
 Name: Curt Otto
 E-Mail: curt.otto@louisvillemmsd.org
 Date/Time: 2023-08-21 08:21 (Time Zone: -04:00)