



700 West Liberty Street | Louisville, KY 40203-1911
Phone: 502.540.6000 | LouisvilleMSD.org

January 19th, 2023

Crystal Dennis
300 Sower Blvd., 3rd Floor
Frankfort, Kentucky 40601

**RE: Lockwood STP, KPDES No: KY0054674
Discharge Monitoring Report for December 2023.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) for the Lockwood STP, for the month December 2023.

There were no overflows, exceedances, or bypasses.

If you have any questions concerning the attached DMR's, please contact me at (502) 264-2804.

Sincerely,

Alex Smither
Process Supervisor

CAS/LO 12/23.

Cc: V. Teague, B. Tinnel

80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample	=	0.681	=	3.403	26 - lb/d	=	17.0	=	17.0	19 - mg/L	01/30 - Monthly	CP - COMPOS
					Permit Req.	<=	9.38 MO AVG	<=	14.07 MX WK AV	26 - lb/d	<=	25.0 MO AVG	<=	37.5 MX WK AV	19 - mg/L	01/30 - Monthly	CP - COMPOS
					Value NODI												

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

Name	Type	Size
Lockwood_Cover_12_23.pdf	pdf	37970.0

Report Last Saved By

Louisville and Jefferson County MSD

User: ALEX.SMITHER@LOUISVILLEMSD.ORG
 Name: Charles Smither
 E-Mail: alex.smither@louisvillemmsd.org
 Date/Time: 2024-01-19 09:31 (Time Zone: -05:00)

Report Last Signed By

User: ALEX.SMITHER@LOUISVILLEMSD.ORG
 Name: Charles Smither
 E-Mail: alex.smither@louisvillemmsd.org
 Date/Time: 2024-01-19 09:31 (Time Zone: -05:00)