



700 West Liberty Street | Louisville, KY 40203-1911  
Phone: 502.540.6000 | LouisvilleMSD.org

November 22nd, 2023

Crystal Dennis  
300 Sower Blvd., 3rd Floor  
Frankfort, Kentucky 40601

**RE: Ohio River STP, KPDES No: KY0106143  
Discharge Monitoring Report for October 2023.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) for the Ohio River STP, for the month October 2023.

There were no overflows or bypasses.

There was one exceedance, TSS weekly average limit of 45.0 with a result of 51.0.

If you have any questions concerning the attached DMR's, please contact me at (502) 264-2804.

Sincerely,

Alex Smither  
Process Supervisor

CAS/OR 8/23.

Cc: V. Teague, B. Tinnel



