



700 West Liberty Street | Louisville, KY 40203-1911
Phone: 502.540.6000 | LouisvilleMSD.org

January 19th, 2024

Crystal Dennis
300 Sower Blvd., 3rd Floor
Frankfort, Kentucky 40601

**RE: Ohio River STP, KPDES No: KY0106143
Discharge Monitoring Report for December 2023.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) for the Ohio River STP, for the month December 2023.

There were no overflows or bypasses. There was one exceedance for TSS effluent gross monthly average, with a result of 34.0 mg/L, the permit limit is 30.0 mg/L.

If you have any questions concerning the attached DMR's, please contact me at (502) 264-2804.

Sincerely,

Alex Smither
Process Supervisor

CAS/OR 12/23.

Cc: V. Teague, B. Tinnel



700 West Liberty Street | Louisville, KY 40203-1911
Phone: 502.540.6000 | LouisvilleMSD.org

January 19th, 2024

Crystal Dennis
300 Sower Blvd., 3rd Floor
Frankfort, Kentucky 40601

**RE: Ohio River STP, KPDES No: KY0106143
4th Quarter Biomonitoring for December 2023.**

Dear Ms. Dennis:

Attached is 4th quarter biomonitoring for the Ohio River STP, for the month December 2023.

If you have any questions concerning the attached testing, please contact me at (502) 264-2804.

Sincerely,

Alex Smither
Process Supervisor

CAS/ AA 12/23.

Cc: V. Teague, B. Tinnel



