



700 West Liberty Street | Louisville, KY 40203-1911
Phone: 502.540.6000 | LouisvilleMSD.org

February 21, 2023

Crystal Dennis
300 Sower Blvd., 3rd Floor
Frankfort, Kentucky 40601

**RE: SORF STP, KPDES No: KY0111716
Discharge Monitoring Report for January 2023.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) for the SORF STP, for the month January 2023.

There were no overflows, exceedances or bypasses.

If you have any questions concerning the attached DMR's, please contact me at (502)540-6004.

Sincerely,

Curt Otto
Process Supervisor

CEO/ AA 01/23.

Cc: V. Teague, B. Tinnel

80082	BOD, carbonaceous [5 day, 20 C]	G - Raw Sewage Influent	0	--	Sample	=	110.0	=	141.0	19 - mg/L	01/07 - Weekly	24 - COMP24	
					Permit Req.					Req Mon MO AVG	Req Mon MX WK AV	01/07 - Weekly	24 - COMP24
					Value NODI								
80091	BOD, carb-5 day, 20 deg C, percent removal	K - Percent Removal	0	--	Sample	=	96.0			23 - %	01/30 - Monthly	CA - CALCTD	
					Permit Req.	>=	85.0 MO AV MN			23 - %	01/30 - Monthly	CA - CALCTD	
					Value NODI								
81011	Solids, suspended percent removal	K - Percent Removal	0	--	Sample	=	92.0			23 - %	01/30 - Monthly	CA - CALCTD	
					Permit Req.	>=	85.0 MO AV MN			23 - %	01/30 - Monthly	CA - CALCTD	
					Value NODI								

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

Name	Type	Size
JAN23SORFCover.pdf	pdf	32214.0

Report Last Saved By

Louisville and Jefferson County MSD

User: CURT.OTTO@LOUISVILLEMSD.ORG
 Name: Curt Otto
 E-Mail: curt.otto@louisvillemssd.org
 Date/Time: 2023-02-21 12:23 (Time Zone: -05:00)

Report Last Signed By

User: CURT.OTTO@LOUISVILLEMSD.ORG
 Name: Curt Otto
 E-Mail: curt.otto@louisvillemssd.org
 Date/Time: 2023-02-21 12:24 (Time Zone: -05:00)