



700 West Liberty Street | Louisville, KY 40203-1911
Phone: 502.540.6000 | LouisvilleMSD.org

March 16, 2023,

Crystal Dennis
300 Sower Blvd., 3rd Floor
Frankfort, Kentucky 40601

**RE: SORF STP, KPDES No: KY0111716
Discharge Monitoring Report for February 2023.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) for the SORF STP, for the month February 2023.

There were no overflows, or bypasses.

There were Three Exceedances,
Phosphorus Daily maximum limit 3.0 mg/L with a result of 3.85 mg/L.
Total Suspended Solids maximum weekly average 45.0mg/L with a result 47.0
Solids Suspended percent removal 85% with a result 72%

We have since replaced a phosphorus chemical pump.

Higher than anticipated flows and numerous rain events this month have caused our SBR to go into storm mode. We did not meet required removal of solids.

If you have any questions concerning the attached DMR's, please contact me at (502)540-6004.

Sincerely,

Curt Otto
Process Supervisor

CEO/ SORF 02/23.

Cc: V. Teague, B. Tinnel



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	02933	7900 SHELBYVILLE RD	MORRIS FORMAN	MIDDLE FORK BEARGRASS CREEK	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3611826		2/16/2023 12:00:00 PM	DAVIS BROWN	FIELDS	DOCUMENTED	3/4/2008 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	02/17/23 08:20 AM	MAIN

Discharge Reporting:

Discharge Amount:	100,000 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	WO#3612393.
Control Zone:	CAUTION TAPE, TEMPORARY DISCHARGE SIGNS, AND BARRICADE PLACED AROUND THE IMPACTED AREA.
Impact:	MANHOLE DISCHARGING.
Repair:	LOCATION INCLUDED IN IOAP.
Public Notification:	PUBLIC NOTIFIED THROUGH TEMPORARY SIGNS AT DISCHARGE SITE TO AVOID CONTACT WITH DISCHARGED CONTENT.

Notifications:

2/16/23 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
2/16/23 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



IMSAST0004
Overflow Report
2/1/2023 12:00:00 AM to 2/28/2023 12:00:00 AM

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	08935-SM	1001 BRECKENRIDGE LN	MORRIS FORMAN	MIDDLE FORK BEARGRASS CREEK	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3611850		2/16/2023 9:30:00 AM	DAVIS BROWN	FIELDS	DOCUMENTED	11/29/2001 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	02/17/23 08:23 PM	MAIN

Discharge Reporting:

Discharge Amount:	2,300,000 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	NO CLEAN UP PERFORMED – PIPE DISCHARGING UNDERWATER, DIRECTLY INTO STREAM.
Control Zone:	NO CONTROL ZONE WAS SET– PIPE DISCHARGING UNDERWATER, DIRECTLY INTO STREAM.
Impact:	NONE OBSERVED, OVERFLOW NOTIFICATION RECEIVED FROM REMOTE DISCHARGE ALARM.
Repair:	LOCATION INCLUDED IN IOAP.
Public Notification:	PUBLIC NOTIFIED THROUGH PERMANENT OVERFLOW SIGNS TO AVOID DISCHARGED CONTENT.

Notifications:

2/16/23 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
2/16/23 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



**IMSAST0004
Overflow Report
2/1/2023 12:00:00 AM to 2/28/2023 12:00:00 AM**

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0078956	MSD0277	DEREK R. GUTHRIE	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	102339	9114 CINDERELLA LN	DEREK R. GUTHRIE	FISHPOOL CREEK	GROUND

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3611806		2/16/2023 11:39:00 AM	ROTTET JR	BROWN JR	DOCUMENTED	7/14/2015 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	02/16/23 09:00 PM	

Discharge Reporting:

Discharge Amount:	14,500 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	CLEANED AND SANITIZED THE IMPACTED AREA.
Control Zone:	PLACED TEMPORARY SIGNS AND CAUTION TAPE AROUND THE IMPACTED AREA.
Impact:	SEWAGE/DEBRIS/SOLIDS/PERSONAL HYGIENE PRODUCTS FOUND ON THE GROUND.
Repair:	SITE FOUND DURING RAIN EVENT RECON - WILL BE MONITORED AND EVALUATED FOR REPAIR.
Public Notification:	PLACED TEMPORARY SIGNS AND CAUTION TAPE AROUND THE IMPACTED AREA.

Notifications:

2/16/23 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
2/16/23 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



IMSAST0004
Overflow Report
2/1/2023 12:00:00 AM to 2/28/2023 12:00:00 AM

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0103900	MSD0515	PROLOGIS	BROOKS RUN	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Main	125673-V	8405 CEDAR CREEK RD	PROLOGIS	BROOKS RUN	DITCH

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISDW: DRY WEATHER DISCHARGE	3621457		2/28/2023 10:05:00 AM	ROTTET JR	ROTTET JR	REPAIRED - ISSUE RESOLVED	2/28/2023 12:00:00 AM	STRUCTURAL FAILURE	UNAUTHORIZED DISCHARGE- WATERS	02/28/23 10:50 AM	

Discharge Reporting:

Discharge Amount:	450 GAL
Cause:	STRUCTURAL FAILURE (FORCE MAIN BREAK).
Clean Up:	CLEANED AND SANITIZED THE IMPACTED AREA.
Control Zone:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	SEWAGE IN DITCH.
Repair:	SHUT OFF PUMPS AND HAULED STATION WHILE CONTRACTOR MADE REPAIRS.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA AND PAGE SENT OUT.

Notifications:

2/28/23 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO: DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
-----------------	--------	--



IMSAST0004
Overflow Report
2/1/2023 12:00:00 AM to 2/28/2023 12:00:00 AM

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	16649	1726 FRASER DR	MORRIS FORMAN	SOUTH FORK BEARGRASS CREEK	DITCH

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3611854		2/16/2023 7:00:00 AM	DAVIS BROWN	HENDERSON SR	DOCUMENTED	1/24/2002 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	02/17/23 07:45 PM	MAIN

Discharge Reporting:

Discharge Amount:	100,000 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	NO CLEAN UP PERFORMED – PIPE DISCHARGING UNDERWATER, DIRECTLY INTO STREAM.
Control Zone:	NO CONTROL ZONE WAS SET– PIPE DISCHARGING UNDERWATER, DIRECTLY INTO STREAM.
Impact:	NONE OBSERVED, OVERFLOW NOTIFICATION RECEIVED FROM REMOTE DISCHARGE ALARM.
Repair:	LOCATION INCLUDED IN IOAP.
Public Notification:	PUBLIC NOTIFIED THROUGH DOOR CARDS & PERMANENT OVERFLOW SIGNS TO AVOID DISCHARGED CONTENT.

Notifications:

2/16/23 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
2/16/23 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



IMSAST0004
Overflow Report
2/1/2023 12:00:00 AM to 2/28/2023 12:00:00 AM

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	27008	1044 ALTA VISTA RD	MORRIS FORMAN	MIDDLE FORK BEARGRASS CREEK	GROUND

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3611819		2/16/2023 9:45:00 AM	DAVIS BROWN	FIELDS	DOCUMENTED	7/1/2003 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	02/17/23 07:50 AM	MAIN

Discharge Reporting:

Discharge Amount:	16,500 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	WO#3612387.
Control Zone:	CAUTION TAPE, TEMPORARY DISCHARGE SIGNS, AND BARRICADE PLACED AROUND THE IMPACTED AREA.
Impact:	MANHOLE DISCHARGING.
Repair:	LOCATION INCLUDED IN IOAP.
Public Notification:	PUBLIC NOTIFIED THROUGH TEMPORARY SIGNS AT DISCHARGE SITE TO AVOID CONTACT WITH DISCHARGED CONTENT.

Notifications:

2/16/23 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
2/16/23 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



IMSAST0004
Overflow Report
2/1/2023 12:00:00 AM to 2/28/2023 12:00:00 AM

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	27012	2408 GRAY FOX RD	MORRIS FORMAN	MIDDLE FORK BEARGRASS CREEK	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3611817		2/16/2023 9:45:00 AM	DAVIS BROWN	FIELDS	DOCUMENTED	3/9/2019 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	02/17/23 07:50 AM	MAIN

Discharge Reporting:

Discharge Amount:	110,000 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	MAGNITUDE OF STORM FLUSHED SOLIDS AND DEBRIS FROM SITE.
Control Zone:	CAUTION TAPE, TEMPORARY DISCHARGE SIGNS, AND BARRICADE PLACED AROUND THE IMPACTED AREA.
Impact:	MANHOLE DISCHARGING.
Repair:	LOCATION INCLUDED IN IOAP.
Public Notification:	PUBLIC NOTIFIED THROUGH TEMPORARY SIGNS AT DISCHARGE SITE TO AVOID CONTACT WITH DISCHARGED CONTENT.

Notifications:

2/16/23 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
2/16/23 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



IMSAST0004
Overflow Report
2/1/2023 12:00:00 AM to 2/28/2023 12:00:00 AM

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	28249	3500 ST EDWARDS DR	MORRIS FORMAN	CHENOWETH RUN	DITCH

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3611833		2/16/2023 11:00:00 AM	DAVIS BROWN	BAILEY	DOCUMENTED	3/12/2006 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	02/17/23 05:20 AM	MAIN

Discharge Reporting:

Discharge Amount:	55,000 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	WO#3612314.
Control Zone:	CAUTION TAPE, TEMPORARY DISCHARGE SIGNS, AND BARRICADE PLACED AROUND THE IMPACTED AREA.
Impact:	MANHOLE DISCHARGING.
Repair:	LOCATION INCLUDED IN IOAP.
Public Notification:	PUBLIC NOTIFIED THROUGH DOOR CARDS AND TEMPORARY SIGNS AT DISCHARGE SITE TO AVOID CONTACT WITH DISCHARGED CONTENT.

Notifications:

2/16/23 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
2/16/23 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	28250	3506 CHARLANE PKY	MORRIS FORMAN	CHENOWETH RUN	DITCH

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3611957		2/16/2023 3:20:00 PM	DAVIS BROWN	BAILEY	DOCUMENTED	1/3/2005 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	02/17/23 05:15 AM	MAIN

Discharge Reporting:

Discharge Amount:	20,875 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	WO#3612318.
Control Zone:	CAUTION TAPE, TEMPORARY DISCHARGE SIGNS, AND BARRICADE PLACED AROUND THE IMPACTED AREA.
Impact:	MANHOLE DISCHARGING.
Repair:	LOCATION INCLUDED IN IOAP.
Public Notification:	PUBLIC NOTIFIED THROUGH DOOR CARDS & TEMP OVERFLOW SIGNS TO AVOID DISCHARGED CONTENT.

Notifications:

2/17/23 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
2/17/23 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	28336	3620 CHARLANE PKY	MORRIS FORMAN	CHENOWETH RUN	DITCH

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3611836		2/16/2023 11:10:00 AM	DAVIS BROWN	BAILEY	DOCUMENTED	8/30/2005 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	02/17/23 05:30 AM	MAIN

Discharge Reporting:

Discharge Amount:	137,500 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	WO#3612317.
Control Zone:	CAUTION TAPE, TEMPORARY DISCHARGE SIGNS, AND BARRICADE PLACED AROUND THE IMPACTED AREA.
Impact:	MANHOLE DISCHARGING.
Repair:	LOCATION INCLUDED IN IOAP.
Public Notification:	PUBLIC NOTIFIED THROUGH DOOR CARDS AND TEMPORARY SIGNS AT DISCHARGE SITE TO AVOID CONTACT WITH DISCHARGED CONTENT.

Notifications:

2/16/23 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
2/16/23 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	28340	3620 CHARLANE PKY	MORRIS FORMAN	CHENOWETH RUN	GROUND

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3611835		2/16/2023 11:05:00 AM	DAVIS BROWN	BAILEY	DOCUMENTED	1/3/2005 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	02/17/23 05:25 AM	MAIN

Discharge Reporting:

Discharge Amount:	110,000 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	WO#3612315.
Control Zone:	CAUTION TAPE, TEMPORARY DISCHARGE SIGNS, AND BARRICADE PLACED AROUND THE IMPACTED AREA.
Impact:	MANHOLE DISCHARGING.
Repair:	LOCATION INCLUDED IN IOAP.
Public Notification:	PUBLIC NOTIFIED THROUGH DOOR CARDS AND TEMPORARY SIGNS AT DISCHARGE SITE TO AVOID CONTACT WITH DISCHARGED CONTENT.

Notifications:

2/16/23 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
2/16/23 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	28451	3406 CHARLANE PKY	MORRIS FORMAN	CHENOWETH RUN	GROUND

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3611831		2/16/2023 10:50:00 AM	DAVIS BROWN	BAILEY	DOCUMENTED	10/28/2015 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	02/17/23 05:10 AM	MAIN

Discharge Reporting:

Discharge Amount:	27,500 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	WO#3612312.
Control Zone:	CAUTION TAPE, TEMPORARY DISCHARGE SIGNS, AND BARRICADE PLACED AROUND THE IMPACTED AREA.
Impact:	MANHOLE DISCHARGING.
Repair:	LOCATION INCLUDED IN IOAP.
Public Notification:	PUBLIC NOTIFIED THROUGH DOOR CARDS AND TEMPORARY SIGNS AT DISCHARGE SITE TO AVOID CONTACT WITH DISCHARGED CONTENT.

Notifications:

2/16/23 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
2/16/23 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	28452	3402 CHARLANE PKY	MORRIS FORMAN	CHENOWETH RUN	DITCH

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3611830		2/16/2023 10:45:00 AM	DAVIS BROWN	BAILEY	DOCUMENTED	11/30/2019 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	02/17/23 05:05 AM	MAIN

Discharge Reporting:

Discharge Amount:	27,625 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	WO#3612311.
Control Zone:	CAUTION TAPE, TEMPORARY DISCHARGE SIGNS, AND BARRICADE PLACED AROUND THE IMPACTED AREA.
Impact:	MANHOLE DISCHARGING.
Repair:	LOCATION INCLUDED IN IOAP.
Public Notification:	PUBLIC NOTIFIED THROUGH DOOR CARDS AND TEMPORARY SIGNS AT DISCHARGE SITE TO AVOID CONTACT WITH DISCHARGED CONTENT.

Notifications:

2/16/23 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
2/16/23 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



IMSAST0004
Overflow Report
2/1/2023 12:00:00 AM to 2/28/2023 12:00:00 AM

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	28453	3402 CHARLANE PKY	MORRIS FORMAN	CHENOWETH RUN	DITCH

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3611829		2/16/2023 10:40:00 AM	DAVIS BROWN	BAILEY	DOCUMENTED	10/28/2015 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	02/17/23 05:00 AM	MAIN

Discharge Reporting:

Discharge Amount:	220,000 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	WO#3612309
Control Zone:	CAUTION TAPE, TEMPORARY DISCHARGE SIGNS, AND BARRICADE PLACED AROUND THE IMPACTED AREA.
Impact:	MANHOLE DISCHARGING.
Repair:	LOCATION INCLUDED IN IOAP.
Public Notification:	PUBLIC NOTIFIED THROUGH DOOR CARDS AND TEMPORARY SIGNS AT DISCHARGE SITE TO AVOID CONTACT WITH DISCHARGED CONTENT.

Notifications:

2/16/23 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
2/16/23 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	45796	1011 ALTA CIR	MORRIS FORMAN	MIDDLE FORK BEARGRASS CREEK	DITCH

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3611820		2/16/2023 9:45:00 AM	DAVIS BROWN	FIELDS	DOCUMENTED	5/10/2014 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	02/17/23 07:55 AM	MAIN

Discharge Reporting:

Discharge Amount:	352,000 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	WO#3612388.
Control Zone:	CAUTION TAPE, TEMPORARY DISCHARGE SIGNS, AND BARRICADE PLACED AROUND THE IMPACTED AREA.
Impact:	MANHOLE DISCHARGING.
Repair:	LOCATION INCLUDED IN IOAP.
Public Notification:	PUBLIC NOTIFIED THROUGH TEMPORARY SIGNS AT DISCHARGE SITE TO AVOID CONTACT WITH DISCHARGED CONTENT.

Notifications:

2/16/23 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
2/16/23 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	47582	201 BULLITT LN	MORRIS FORMAN	MIDDLE FORK BEARGRASS CREEK	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3611824		2/16/2023 11:50:00 AM	DAVIS BROWN	FIELDS	DOCUMENTED	12/5/2011 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	02/17/23 08:20 AM	MAIN

Discharge Reporting:

Discharge Amount:	180,000 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	WO#3612392
Control Zone:	CAUTION TAPE, TEMPORARY DISCHARGE SIGNS, AND BARRICADE PLACED AROUND THE IMPACTED AREA.
Impact:	MANHOLE DISCHARGING.
Repair:	LOCATION INCLUDED IN IOAP.
Public Notification:	PUBLIC NOTIFIED THROUGH TEMPORARY SIGNS AT DISCHARGE SITE TO AVOID CONTACT WITH DISCHARGED CONTENT.

Notifications:

2/16/23 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
2/16/23 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



IMSAST0004
Overflow Report
2/1/2023 12:00:00 AM to 2/28/2023 12:00:00 AM

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	47583	202 OXMOOR LN	MORRIS FORMAN	MIDDLE FORK BEARGRASS CREEK	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3611823		2/16/2023 11:50:00 AM	DAVIS BROWN	FIELDS	DOCUMENTED	2/6/2008 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	02/17/23 08:20 AM	MAIN

Discharge Reporting:

Discharge Amount:	320,000 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	WO#3612391.
Control Zone:	CAUTION TAPE, TEMPORARY DISCHARGE SIGNS, AND BARRICADE PLACED AROUND THE IMPACTED AREA.
Impact:	MANHOLE DISCHARGING.
Repair:	LOCATION INCLUDED IN IOAP.
Public Notification:	PUBLIC NOTIFIED THROUGH TEMPORARY SIGNS AT DISCHARGE SITE TO AVOID CONTACT WITH DISCHARGED CONTENT.

Notifications:

2/16/23 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
2/16/23 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



**IMSAST0004
Overflow Report
2/1/2023 12:00:00 AM to 2/28/2023 12:00:00 AM**

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	47593	8021 CHRISTIAN CT	MORRIS FORMAN	MIDDLE FORK BEARGRASS CREEK	GROUND

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3611990		2/16/2023 5:05:00 PM	DAVIS BROWN	FIELDS	DOCUMENTED	3/19/2008 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	02/17/23 08:30 AM	MAIN

Discharge Reporting:

Discharge Amount:	30,000 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	WO#3612397.
Control Zone:	CAUTION TAPE, TEMPORARY DISCHARGE SIGNS, AND BARRICADE PLACED AROUND THE IMPACTED AREA.
Impact:	MANHOLE DISCHARGING.
Repair:	LOCATION INCLUDED IN IOAP.
Public Notification:	PUBLIC NOTIFIED THROUGH TEMP SIGNS AT DISCHARGE SITE AND PERMANENT SIGNS POSTED ALONG THE CREEK AVOID CONTACT WITH DISCHARGED CONTENT.

Notifications:

2/17/23 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
2/17/23 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



IMSAST0004
Overflow Report
2/1/2023 12:00:00 AM to 2/28/2023 12:00:00 AM

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0078956	MSD0277	DEREK R. GUTHRIE	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	60679	9114 CINDERELLA LN	DEREK R. GUTHRIE	FISHPOOL CREEK	DITCH

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3611808		2/16/2023 11:40:00 AM	ROTTET JR	BROWN JR	DOCUMENTED	12/15/2007 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	02/16/23 09:00 PM	

Discharge Reporting:

Discharge Amount:	14,500 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	CLEANED AND SANITIZED THE IMPACTED AREA.
Control Zone:	PLACED TEMPORARY SIGNS AND CAUTION TAPE AROUND THE IMPACTED AREA.
Impact:	SEWAGE/DEBRIS/SOLIDS/PERSONAL HYGIENE PRODUCTS FOUND ON THE GROUND.
Repair:	SITE FOUND DURING RAIN EVENT RECON - WILL BE MONITORED AND EVALUATED FOR REPAIR.
Public Notification:	PLACED TEMPORARY SIGNS AND CAUTION TAPE AROUND THE IMPACTED AREA.

Notifications:

2/16/23 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
2/16/23 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



IMSAST0004
Overflow Report
2/1/2023 12:00:00 AM to 2/28/2023 12:00:00 AM

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	65623	1804 ROUND RIDGE RD	MORRIS FORMAN	MUDDY FORK BEARGRASS CREEK	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3612301		2/17/2023 6:05:00 AM	DAVIS BROWN	FIELDS	QUEUED FOR INVESTIGATION / REPAIR	2/17/2023 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	02/17/23 09:00 AM	MAIN

Discharge Reporting:

Discharge Amount:	270,000 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	CLEAN UP NOT PERFORMED DUE TO INABILITY TO ACCESS DISCHARGE SITE.
Control Zone:	CONTROL ZONE WAS NOT ESTABLISHED, DUE TO INABILITY TO ACCESS DISCHARGE SITE.
Impact:	MANHOLE DISCHARGING INTO CREEK.
Repair:	LOCATION INCLUDED IN IOAP.
Public Notification:	PUBLIC NOTIFIED THROUGH PERMANENT SIGNS POSTED ALONG THE CREEK AVOID CONTACT WITH DISCHARGED CONTENT.

Notifications:

2/17/23 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
-----------------	--------	---



IMSAST0004
Overflow Report
2/1/2023 12:00:00 AM to 2/28/2023 12:00:00 AM

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	84155	7913 SHELBYVILLE RD	MORRIS FORMAN	MIDDLE FORK BEARGRASS CREEK	GROUND

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3611828		2/16/2023 12:10:00 PM	DAVIS BROWN	FIELDS	DOCUMENTED	3/10/2011 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	02/17/23 08:35 AM	MAIN

Discharge Reporting:

Discharge Amount:	80,000 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	WO#3612395.
Control Zone:	CAUTION TAPE, TEMPORARY DISCHARGE SIGNS, AND BARRICADE PLACED AROUND THE IMPACTED AREA.
Impact:	MANHOLE DISCHARGING.
Repair:	LOCATION INCLUDED IN IOAP.
Public Notification:	PUBLIC NOTIFIED THROUGH DOOR CARDS AND TEMPORARY SIGNS AT DISCHARGE SITE TO AVOID CONTACT WITH DISCHARGED CONTENT.

Notifications:

2/16/23 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
2/16/23 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



IMSAST0004
Overflow Report
2/1/2023 12:00:00 AM to 2/28/2023 12:00:00 AM

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	90700	8021 CHRISTIAN CT	MORRIS FORMAN	MIDDLE FORK BEARGRASS CREEK	CATCH BASIN

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3611989		2/16/2023 5:05:00 PM	DAVIS BROWN	FIELDS	DOCUMENTED	3/19/2008 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	02/17/23 08:25 AM	MAIN

Discharge Reporting:

Discharge Amount:	22,500 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	WO#3612396.
Control Zone:	CAUTION TAPE, TEMPORARY DISCHARGE SIGNS, AND BARRICADE PLACED AROUND THE IMPACTED AREA.
Impact:	MANHOLE DISCHARGING.
Repair:	LOCATION INCLUDED IN IOAP.
Public Notification:	PUBLIC NOTIFIED THROUGH DOOR CARDS & TEMP OVERFLOW SIGNS TO AVOID DISCHARGED CONTENT.

Notifications:

2/17/23 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
2/17/23 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



IMSAST0004
Overflow Report
2/1/2023 12:00:00 AM to 2/28/2023 12:00:00 AM

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	IS021A-SI	1201 OLD CANNONS LN	MORRIS FORMAN	MIDDLE FORK BEARGRASS CREEK	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3611849		2/16/2023 8:15:00 AM	DAVIS BROWN	FIELDS	DOCUMENTED	8/1/1969 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	02/17/23 11:00 PM	MAIN

Discharge Reporting:

Discharge Amount:	2,400,000 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	NO CLEAN UP PERFORMED – PIPE DISCHARGING UNDERWATER, DIRECTLY INTO STREAM.
Control Zone:	NO CONTROL ZONE WAS SET– PIPE DISCHARGING UNDERWATER, DIRECTLY INTO STREAM.
Impact:	NONE OBSERVED, OVERFLOW NOTIFICATION RECEIVED FROM REMOTE DISCHARGE ALARM.
Repair:	LOCATION INCLUDED IN IOAP.
Public Notification:	PUBLIC NOTIFIED THROUGH PERMANENT OVERFLOW SIGNS TO AVOID DISCHARGED CONTENT.

Notifications:

2/16/23 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
2/16/23 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



IMSAST0004
Overflow Report
2/1/2023 12:00:00 AM to 2/28/2023 12:00:00 AM

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0034151	MSD0506	BCSD HILLVIEW #1	TANYARD BRANCH	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Treatment Plant	MSD0506	8405 CEDAR CREEK RD	BCSD HILLVIEW #1	TANYARD BRANCH	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3611754		2/16/2023 10:04:00 AM	SMITH		DOCUMENTED	1/8/2022 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	02/21/23 06:27 AM	

Discharge Reporting:

Discharge Amount:	34,125 GAL
Cause:	HEAVY RAIN HIGH FLOW, LACK OF CAPACITY.
Clean Up:	DEBRIS AROUND OUTFALL.
Control Zone:	INSIDE FENCE.
Impact:	INF STATION BYPASSED TO THE EFF DISCHARGE MANHOLE.
Repair:	FLOW WENT DOWN ALLOWING PUMPS TO CATCH UP.
Public Notification:	TEMP SIGN NEAR FENCE AND OUTFALL.

Notifications:

2/16/23 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
2/16/23 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



IMSAST0004
Overflow Report
2/1/2023 12:00:00 AM to 2/28/2023 12:00:00 AM

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0034169	MSD0507	BCSD HILLVIEW #2	BROOKS RUN	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Treatment Plant	MSD0507	8405 CEDAR CREEK RD	BCSD HILLVIEW #2	BROOKS RUN	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3611750		2/16/2023 9:45:00 AM	SMITH		DOCUMENTED	12/6/2021 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	02/21/23 06:22 AM	

Discharge Reporting:

Discharge Amount:	33,250 GAL
Cause:	HEAVY RAIN--LACK OF CAPACITY.
Clean Up:	CLEAN UP DEBRIS AROUND OUTFALL IN CONCRETE DITCH.
Control Zone:	INSIDE FENCE.
Impact:	INF FLOW RAN TO CONCRETE DITCH ON PLANT.
Repair:	FLOW WENT DOWN ALLOWING PUMPS TO CATCH UP.
Public Notification:	TEMP SIGN NEAR FENCE.

Notifications:

2/16/23 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
2/16/23 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022420	MSD0202	HITE CREEK	HITE CREEK	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Lift Station	MSD1086-PS	7260 FLOYDSBURG RD	HITE CREEK	FLOYDS FORK	DITCH

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3611761		2/16/2023 10:05:00 AM	CATALANO JR	JENKINS	BEYOND APPROVED DESIGN STORM	2/16/2023 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	02/16/23 08:00 PM	

Discharge Reporting:

Discharge Amount:	8,925 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	CLEANUP NOT POSSIBLE DUE TO MAGNITUDE OF STORM.
Control Zone:	PERMANENT SIGN IN PLACE – NO ADDITIONAL CONTROL ZONE SET UP.
Impact:	SEWAGE/DEBRIS/SOLIDS/PERSONAL HYGIENE PRODUCTS FOUND AROUND WET WELL.
Repair:	SITE FOUND DURING RAIN EVENT RECON - WILL BE MONITORED AND EVALUATED FOR REPAIR.
Public Notification:	PERMANENT SIGN IN PLACE – NO ADDITIONAL CONTROL ZONE SET UP.

Notifications:

2/16/23 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
2/16/23 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



IMSAST0004
Overflow Report
2/1/2023 12:00:00 AM to 2/28/2023 12:00:00 AM

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0034169	MSD0507	BCSD HILLVIEW #2	BROOKS RUN	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Lift Station	MSD2013-PS	8405 CEDAR CREEK RD	BCSD HILLVIEW #2	BROOKS RUN	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3611793		2/16/2023 10:58:00 AM	SOSA RODRIGUEZ	SOSA RODRIGUEZ	DOCUMENTED	12/11/2021 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	02/16/23 08:38 PM	

Discharge Reporting:

Discharge Amount:	58,000 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	CLEANUP NOT POSSIBLE DUE TO ELEVATED CREEK LEVEL.
Control Zone:	TEMPORARY SIGNS HAVE BEEN POSTED.
Impact:	NO IMPACT OBSERVED – MAGNITUDE OF STORM FLUSHED SOLIDS AND DEBRIS FROM SITE.
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE INTEGRATED OVERFLOW ABATEMENT PLAN.
Public Notification:	TEMPORARY SIGNS HAVE BEEN POSTED.

Notifications:

2/16/23 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
2/16/23 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



IMSAST0004
Overflow Report
2/1/2023 12:00:00 AM to 2/28/2023 12:00:00 AM

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0034177	MSD0508	BCSD HILLVIEW #3	BROOKS RUN	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Lift Station	MSD2014-PS	8405 CEDAR CREEK RD	BCSD HILLVIEW #3	BROOKS RUN	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3611825		2/16/2023 12:06:00 PM	SOSA RODRIGUEZ	SOSA RODRIGUEZ	DOCUMENTED	12/9/2021 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	02/16/23 08:42 PM	

Discharge Reporting:

Discharge Amount:	51,600 GAL
Cause:	LACK OF SYSTEM CAPACITY - HEAVY RAIN.
Clean Up:	CLEANUP NOT POSSIBLE DUE TO MAGNITUDE OF STORM.
Control Zone:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	NO IMPACT OBSERVED – MAGNITUDE OF STORM FLUSHED SOLIDS AND DEBRIS FROM SITE.
Repair:	SITE FOUND DURING RAIN EVENT RECON - WILL BE MONITORED AND EVALUATED FOR REPAIR.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.

Notifications:

2/16/23 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
2/16/23 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



IMSAST0004
Overflow Report
2/1/2023 12:00:00 AM to 2/28/2023 12:00:00 AM

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0094307	MSD0511	WILLABROOK	BROOKS RUN	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Lift Station	MSD2019-PS	8405 CEDAR CREEK RD	WILLABROOK	BROOKS RUN	GROUND

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3611841		2/16/2023 12:26:00 PM	SOSA RODRIGUEZ	SOSA RODRIGUEZ	QUEUED FOR INVESTIGATION / REPAIR	4/6/2022 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	02/16/23 08:00 PM	

Discharge Reporting:

Discharge Amount:	121,300 GAL
Cause:	LACK OF SYSTEM CAPACITY - HEAVY RAIN.
Clean Up:	CLEANUP NOT POSSIBLE DUE TO ELEVATED CREEK LEVEL.
Control Zone:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	SEWAGE/DEBRIS/SOLIDS/PERSONAL HYGIENE PRODUCTS FOUND IN THE STREAM.
Repair:	SITE FOUND DURING RAIN EVENT RECON - WILL BE MONITORED AND EVALUATED FOR REPAIR.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.

Notifications:

2/16/23 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
2/16/23 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



IMSAST0004
Overflow Report
2/1/2023 12:00:00 AM to 2/28/2023 12:00:00 AM

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0034185	MSD0512	PIONEER VILLAGE #1	BROOKS RUN	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Lift Station	MSD2021-PS	8405 CEDAR CREEK RD	PIONEER VILLAGE #1	BROOKS RUN	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISDW: DRY WEATHER DISCHARGE	3610397		2/5/2023 9:00:00 PM	SOSA RODRIGUEZ	SOSA RODRIGUEZ	DOCUMENTED	12/21/2022 12:00:00 AM	STRUCTURAL FAILURE	UNAUTHORIZED DISCHARGE- WATERS	02/05/23 09:36 PM	

Discharge Reporting:

Discharge Amount:	7,600 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	CLEANUP NOT POSSIBLE DUE TO ELEVATED CREEK LEVEL.
Control Zone:	PLACE TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	SEWAGE PRODUCTS FOUND IN THE STREAM.
Repair:	SITE FOUND DURING RAIN EVENT RECON - WILL BE MONITORED AND EVALUATED FOR REPAIR.
Public Notification:	PLACE TEMPORARY SIGNS AROUND THE IMPACTED AREA.

Notifications:

2/6/23 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO: DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
----------------	--------	--



IMSAST0004
Overflow Report
2/1/2023 12:00:00 AM to 2/28/2023 12:00:00 AM

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0034185	MSD0512	PIONEER VILLAGE #1	BROOKS RUN	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Lift Station	MSD2021-PS	8405 CEDAR CREEK RD	PIONEER VILLAGE #1	BROOKS RUN	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3611682		2/16/2023 7:00:00 AM	CATALANO JR	CATALANO JR	DOCUMENTED	12/21/2022 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	02/21/23 10:00 PM	

Discharge Reporting:

Discharge Amount:	692,900 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	CLEANUP NOT POSSIBLE DUE TO MAGNITUDE OF STORM.
Control Zone:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	SEWAGE/DEBRIS/SOLIDS/PERSONAL HYGIENE PRODUCTS FOUND IN THE STREAM.
Repair:	SITE FOUND DURING RAIN EVENT RECON - WILL BE MONITORED AND EVALUATED FOR REPAIR.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.

Notifications:

2/16/23 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
2/16/23 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



IMSAST0004
Overflow Report
2/1/2023 12:00:00 AM to 2/28/2023 12:00:00 AM

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0034185	MSD0512	PIONEER VILLAGE #1	BROOKS RUN	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Lift Station	MSD2021-PS	8405 CEDAR CREEK RD	PIONEER VILLAGE #1	BROOKS RUN	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3618515		2/22/2023 11:00:00 PM	CATALANO JR	CATALANO JR	DOCUMENTED	12/21/2022 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	02/25/23 09:21 AM	

Discharge Reporting:

Discharge Amount:	162,400 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	CLEANUP NOT POSSIBLE DUE TO MAGNITUDE OF STORM.
Control Zone:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	SEWAGE/DEBRIS/SOLIDS/PERSONAL HYGIENE PRODUCTS FOUND IN THE STREAM.
Repair:	SITE FOUND DURING RAIN EVENT RECON - WILL BE MONITORED AND EVALUATED FOR REPAIR.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.

Notifications:

2/23/23 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
2/23/23 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0034185	MSD0512	PIONEER VILLAGE #1	BROOKS RUN	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Lift Station	MSD2021-PS	8405 CEDAR CREEK RD	PIONEER VILLAGE #1	BROOKS RUN	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3618965		2/27/2023 7:30:00 AM	SMITHER	SMITHER	DOCUMENTED	12/21/2022 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	02/27/23 01:16 PM	

Discharge Reporting:

Discharge Amount:	7,300 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	CLEANUP NOT POSSIBLE DUE TO MAGNITUDE OF STORM.
Control Zone:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	SEWAGE/DEBRIS/SOLIDS/PERSONAL HYGIENE PRODUCTS FOUND IN THE STREAM.
Repair:	SITE FOUND DURING RAIN EVENT RECON - WILL BE MONITORED AND EVALUATED FOR REPAIR.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.

Notifications:

2/27/23 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
2/27/23 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION