



700 West Liberty Street | Louisville, KY 40203-1911
Phone: 502.540.6000 | LouisvilleMSD.org

July 18, 2023

Crystal Dennis
300 Sower Blvd., 3rd Floor
Frankfort, Kentucky 40601

**RE: SORF STP, KPDES No: KY0111716
Discharge Monitoring Report for June 2023.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) for the SORF STP, for the month June 2023.

Also attached is 2nd quarter biomonitoring.

There were no overflows or bypasses.

There was two exceedance this month.

Phosphorus

Monthly average limit 1.0 mg/L with a result of 1.89mg/L.

Daily maximum limit 2.0mg/L with a result of 2.24mg/L.

We have ordered a new pump and had to reprogram the other pump. This is being monitored closely we hope to see better passing results next month.

If you have any questions concerning the attached DMR's, please contact me at (502)587-5858.

Sincerely,

A handwritten signature in black ink, appearing to read 'Curt Otto', is written over a light blue circular stamp.

Curt Otto
Process Supervisor

CEO/ AA 06/23.

Cc: V. Teague, B. Tinnel

DMR Copy of Record

Permit																					
Permit #: KY0111716		Permittee: Louisville and Jefferson County MSD					Facility: OLDHAM COUNTY ENVIRONMENTAL AUTHORITY REGIONAL WWTP														
Major: Yes		Permittee Address: 700 W Liberty St Louisville, KY 40203					Facility Location: 6115 HITT LN CRESTWOOD, KY 40241														
Permitted Feature: 001 External Outfall		Discharge: 001-2 Domestic Wastewater from Publicly Owned Treatment Works																			
Report Dates & Status																					
Monitoring Period: From 04/01/23 to 06/30/23			DMR Due Date: 07/28/23					Status: NetDMR Validated													
Considerations for Form Completion																					
Principal Executive Officer																					
First Name: James		Title: Executive Director					Telephone: 502-540-6000														
Last Name: Parrot																					
No Data Indicator (NODI)																					
Form NODI: --																					
Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Sample Permit Req. Value NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type			
						Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units	
61406	Toxicity, final conc toxicity units	1 - Effluent Gross	0	--												<	1.0	2G - tox chronic		01/90 - Quarterly	24 - COMP24
																<=	1.0 MAXIMUM	2G - tox chronic		01/90 - Quarterly	24 - COMP24
Submission Note																					
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.																					
Edit Check Errors																					
No errors.																					
Comments																					
Attachments																					
No attachments.																					
Report Last Saved By																					
Louisville and Jefferson County MSD																					
User: CURT.OTTO@LOUISVILLEMSD.ORG																					
Name: Curt Otto																					
E-Mail: curt.otto@louisvillemmsd.org																					
Date/Time: 2023-07-19 10:32 (Time Zone: -04:00)																					
Report Last Signed By																					
User: CURT.OTTO@LOUISVILLEMSD.ORG																					
Name: Curt Otto																					
E-Mail: curt.otto@louisvillemmsd.org																					
Date/Time: 2023-07-19 10:37 (Time Zone: -04:00)																					