



700 West Liberty Street | Louisville, KY 40203-1911  
Phone: 502.540.6000 | LouisvilleMSD.org

August 17th, 2023

Crystal Dennis  
300 Sower Blvd., 3rd Floor  
Frankfort, Kentucky 40601

**RE: SORF STP, KPDES No: KY0111716  
Discharge Monitoring Report for July 2023.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) for the SORF STP, for the month July 2023.

There were no overflows, exceedances, or bypasses.

If you have any questions concerning the attached DMR's, please contact me at (502)587-5858.

Sincerely,

Curt Otto  
Process Supervisor

CEO/ AA 07/23.

Cc: V. Teague, B. Tinnel



80082	BOD, carbonaceous [5 day, 20 C]	G - Raw Sewage Influent	0	--	Sample	=	165.0	=	986.0	19 - mg/L	01/07 - Weekly	24 - COMP24
					Permit Req.		Req Mon MO AVG		Req Mon MX WK AV	19 - mg/L	01/07 - Weekly	24 - COMP24
					Value NODI							
80091	BOD, carb-5 day, 20 deg C, percent removal	K - Percent Removal	0	--	Sample	=	97.1			23 - %	01/30 - Monthly	CA - CALCTD
					Permit Req.	>=	85.0 MO AV MN			23 - %	01/30 - Monthly	CA - CALCTD
					Value NODI							
81011	Solids, suspended percent removal	K - Percent Removal	0	--	Sample	=	95.7			23 - %	01/30 - Monthly	CA - CALCTD
					Permit Req.	>=	85.0 MO AV MN			23 - %	01/30 - Monthly	CA - CALCTD
					Value NODI							

**Submission Note**

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**

No errors.

**Comments**

**Attachments**

Name	Type	Size
SORFCover7_23.pdf	pdf	31459.0

**Report Last Saved By**

**Louisville and Jefferson County MSD**

User: CURT.OTTO@LOUISVILLEMSD.ORG  
 Name: Curt Otto  
 E-Mail: curt.otto@louisvillemisd.org  
 Date/Time: 2023-08-17 14:56 (Time Zone: -04:00)

**Report Last Signed By**

User: CURT.OTTO@LOUISVILLEMSD.ORG  
 Name: Curt Otto  
 E-Mail: curt.otto@louisvillemisd.org  
 Date/Time: 2023-08-17 14:58 (Time Zone: -04:00)