



700 West Liberty Street | Louisville, KY 40203-1911
Phone: 502.540.6000 | LouisvilleMSD.org

April 28, 2023

Crystal Dennis
Permit Support Section
Surface Water Permits Branch
Division of Water
200 Fair Oaks Lane, 4th floor
Frankfort, KY 40601

Subject: Top Flight Landing
KPDES Permit No. KY0105074

Dear Ms. Dennis:

Louisville Metropolitan Sewer District (MSD) has entered into a short term contract to provide operation and maintenance services for the Top Flight treatment plant, collection system, and pump station. Steve Emily with OHM advisors is our contact for the duration of this contract and will communicate with the owner of the treatment plant and collection system as needed.

In accordance with the provisions of the KPDES permit referenced above, the monthly discharge monitoring report (DMR) for the reporting period of March 1st through March 31st, 2023 are provided and submitted through KY's Net DMR. All conditions of the permit was met during this monitoring period.

Should you have any additional questions, please contact me at (502) 540-6952.

Sincerely,

William Ford
Process Supervisor-Operations

WEF / TopFlight / 03/23

cc: B. Tinnell
RecordsRequest@louisvillemsd.org
S. Emily, OHM Advisors

DMR Copy of Record

Permit			
Permit #:	KY0105074	Permittee:	Top Flight Landing
Major:	No	Permittee Address:	8105 Parkshire Court Louisville, KY 40220
Permitted Feature:	001 External Outfall	Discharge:	001-1 Domestic Wastewater
Facility:		Facility Location:	TOP FLIGHT LANDING HWY 55 S TAYLORSVILLE, KY 40071

Report Dates & Status			
Monitoring Period:	From 03/01/23 to 03/31/23	DMR Due Date:	04/28/23
Status:	NetDMR Validated		

Considerations for Form Completion

Principal Executive Officer			
First Name:	William	Title:	Process Supervisor-Operations
Last Name:	Ford	Telephone:	502-540-6000

No Data Indicator (NODI)			
Form NODI:	--		

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type							
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units					
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample						=	9.82					19 - mg/L	0	01/30 - Monthly	GR - GRAB				
					Permit Req.						>=	7.0 INST MIN					19 - mg/L		01/30 - Monthly	GR - GRAB				
					Value NODI																			
00400	pH	1 - Effluent Gross	0	--	Sample						=	6.99					12 - SU	0	01/30 - Monthly	GR - GRAB				
					Permit Req.						>=	6.0 MINIMUM					<=		9.0 MAXIMUM	12 - SU	01/30 - Monthly	GR - GRAB		
					Value NODI																			
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample								=	10.0			19 - mg/L	0	01/30 - Monthly	CP - COMPOS				
					Permit Req.							<=	30.0 MO AVG						<=	45.0 MX WK AV	19 - mg/L	01/30 - Monthly	CP - COMPOS	
					Value NODI																			
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	2	--	Sample								<	0.2			19 - mg/L	0	01/30 - Monthly	CP - COMPOS				
					Permit Req.							<=	10.0 MO AVG						<=	15.0 DAILY MX	19 - mg/L	01/30 - Monthly	CP - COMPOS	
					Value NODI																			
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample								=	4.43			19 - mg/L	0	01/30 - Monthly	CP - COMPOS				
					Permit Req.																		01/30 - Monthly	CP - COMPOS
					Value NODI																			
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.019	=	0.026	03 - MGD								0	01/30 - Monthly	IN - INSTAN				
					Permit Req.																	01/30 - Monthly	IN - INSTAN	
					Value NODI																			
51040	E. coli	1 - Effluent Gross	0	--	Sample								=	10.0			13 - #/100mL	0	01/30 - Monthly	GR - GRAB				
					Permit Req.																		01/30 - Monthly	GR - GRAB
					Value NODI																			
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample								=	12.0			19 - mg/L	0	01/30 - Monthly	CP - COMPOS				
					Permit Req.																		01/30 - Monthly	CP - COMPOS
					Value NODI																			

Submission Note
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors
No errors.

Comments

Attachments		
Name	Type	Size
TopFlightCoverletter032023.pdf	pdf	43459.0

Report Last Saved By
Top Flight Landing

User: WILLIAM.FORD@LOUISVILLEMSD.ORG
Name: William Ford

E-Mail: william.ford@louisvillemsd.org
Date/Time: 2023-04-28 09:26 (Time Zone: -04:00)

Report Last Signed By

User: WILLIAM.FORD@LOUISVILLEMSD.ORG
Name: William Ford
E-Mail: william.ford@louisvillemsd.org
Date/Time: 2023-04-28 12:14 (Time Zone: -04:00)