



700 West Liberty Street | Louisville, KY 40203-1911
Phone: 502.540.6000 | LouisvilleMSD.org

May 22, 2024

Ms. Crystal Dennis
Kentucky Division of Water
300 Sower Blvd., 3rd Floor
Frankfort, Kentucky 40601

**RE: Cedar Creek WQTC, KPDES No: KY0098540
Discharge Monitoring Report for April 2024.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) and the Monthly Operator Report (MOR) for the Cedar Creek WQTC, for the month of April 2024.

There were no bypass, overflows or exceedances to report.

If you have any questions concerning the attached DMR's, please contact me at (502)540-6031.

Sincerely,

Curt Otto
Process Supervisor

CEO/ Cedar Creek. 4/24.

Enclosures

CC: B. Tinnell
V. Graves
M. Saylor

					Value NODI														
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample = 107.0	=	133.0	26 - lb/d	=	2.0	=	3.0	19 - mg/L	0	01/07 - Weekly	CP - COMPOS			
					Permit Req. <= 626.0 MO AVG	<=	939.0 MX WK AV	26 - lb/d	<=	10.0 MO AVG	<=	15.0 MX WK AV	19 - mg/L		01/07 - Weekly	24 - COMP24			
					Value NODI														
80082	BOD, carbonaceous [5 day, 20 C]	G - Raw Sewage Influent	0	--	Sample = 89.0	=	128.0		=	89.0	=	128.0	19 - mg/L	0	01/07 - Weekly	CP - COMPOS			
					Permit Req. Req Mon MO AVG		Req Mon MX WK AV						19 - mg/L		01/07 - Weekly	24 - COMP24			
					Value NODI														
80091	BOD, carb-5 day, 20 deg C, percent removal	K - Percent Removal	0	--	Sample = 97.0								23 - %	0	01/30 - Monthly	CA - CALCTD			
					Permit Req. >= 85.0 MO AV MN								23 - %		01/30 - Monthly	CA - CALCTD			
					Value NODI														
81011	Solids, suspended percent removal	K - Percent Removal	0	--	Sample = 98.0								23 - %	0	01/30 - Monthly	CA - CALCTD			
					Permit Req. >= 85.0 MO AV MN								23 - %		01/30 - Monthly	CA - CALCTD			
					Value NODI														

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

Name	Type	Size
CoverLetter_CedarCreekApril2024.pdf	pdf	31718.0
CCMOR042024.xls	xls	334848.0

Report Last Saved By

Cedar Creek WQTC MSD

User: CURT.OTTO@LOUISVILLEMSD.ORG
Name: Curt Otto
E-Mail: curt.otto@louisvillemsd.org
Date/Time: 2024-05-22 12:37 (Time Zone: -04:00)

Report Last Signed By

User: CURT.OTTO@LOUISVILLEMSD.ORG
Name: Curt Otto
E-Mail: curt.otto@louisvillemsd.org
Date/Time: 2024-05-22 12:41 (Time Zone: -04:00)