



700 West Liberty Street | Louisville, KY 40203-1911  
Phone: 502.540.6000 | LouisvilleMSD.org

November 13, 2024

Crystal Dennis  
300 Sower Blvd., 3rd Floor  
Frankfort, Kentucky 40601

**RE: Cedar Creek WQTC, KPDES No: KY0098540  
Discharge Monitoring Report for October 2024.**

Dear Mrs. Dennis:

Attached are the Discharge Monitoring Report (DMR) and the Monthly Operator Report (MOR) for the Cedar Creek WQTC, for the month of October 2024.

There were no exceedances, bypasses or overflows to report.

If you have any questions concerning the attached DMR's, please contact me at (502)540-6000.

Sincerely,

Curt Otto  
Process Supervisor

CEO/ Cedar Creek. 10/24.

Enclosures

Cc: V. Teague  
K. Robinson  
M. Saylor



NAME OF TREATMENT PLANT Cedar Creek

COUNTY Jefferson

Month of: October 2024

Avg. Flow: 3.79

		Sludge Disposal	
Date	Rainfall	in Gallons	Remarks
1		63000000	
2		63000000	
3		75600000	
4		75600000	
5		50400000	
6		0	
7		75600000	
8		63000000	
9		75600000	
10		75600000	
11		75600000	
12		31500000	
13		0	
14		44100000	
15		37800000	
16		75600000	
17		75600000	
18		75600000	
19		50400000	
20		0	
21		75600000	
22		75600000	
23		75600000	
24		75600000	
25		75600000	
26		50400000	
27		0	
28		75600000	
29		75600000	
30		75600000	
31		0	



					Value NODI														
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample = 100.0	=	134.0	26 - lb/d		=	3.0	=	3.0	19 - mg/L	0	01/07 - Weekly	CP - COMPOS		
					Permit Req. <= 626.0 MO AVG	<=	939.0 MX WK AV	26 - lb/d		<=	10.0 MO AVG	<=	15.0 MX WK AV	19 - mg/L		01/07 - Weekly	24 - COMP24		
					Value NODI														
80082	BOD, carbonaceous [5 day, 20 C]	G - Raw Sewage Influent	0	--	Sample					=	111.0	=	183.0	19 - mg/L	0	01/07 - Weekly	CP - COMPOS		
					Permit Req.						Req Mon MO AVG		Req Mon MX WK AV	19 - mg/L		01/07 - Weekly	24 - COMP24		
					Value NODI														
80091	BOD, carb-5 day, 20 deg C, percent removal	K - Percent Removal	0	--	Sample					=	97.0			23 - %	0	01/30 - Monthly	CA - CALCTD		
					Permit Req.					>=	85.0 MO AV MN			23 - %		01/30 - Monthly	CA - CALCTD		
					Value NODI														
81011	Solids, suspended percent removal	K - Percent Removal	0	--	Sample					=	98.0			23 - %	0	01/30 - Monthly	CA - CALCTD		
					Permit Req.					>=	85.0 MO AV MN			23 - %		01/30 - Monthly	CA - CALCTD		
					Value NODI														

**Submission Note**

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**

No errors.

**Comments**

**Attachments**

Name	Type	Size
CC_CL_OCT24.pdf	pdf	36876.0
CCMOR102024.xls	xls	340480.0

**Report Last Saved By**

**Cedar Creek WQTC MSD**

User: CURT.OTTO@LOUISVILLEMSD.ORG  
 Name: Curt Otto  
 E-Mail: curt.otto@louisvillemsd.org  
 Date/Time: 2024-11-13 11:19 (Time Zone: -05:00)

**Report Last Signed By**

User: CURT.OTTO@LOUISVILLEMSD.ORG  
 Name: Curt Otto  
 E-Mail: curt.otto@louisvillemsd.org  
 Date/Time: 2024-11-13 11:21 (Time Zone: -05:00)