



700 West Liberty Street | Louisville, KY 40203-1911  
Phone: 502.540.6000 | LouisvilleMSD.org

December 13, 2024

Crystal Dennis  
300 Sower Blvd., 3rd Floor  
Frankfort, Kentucky 40601

**RE: Cedar Creek WQTC, KPDES No: KY0098540  
Discharge Monitoring Report for November 2024.**

Dear Mrs. Dennis:

Attached are the Discharge Monitoring Report (DMR) and the Monthly Operator Report (MOR) for the Cedar Creek WQTC, for the month of November 2024.

There were no exceedances, overflows or bypasses to report.

If you have any questions concerning the attached DMR's, please contact me at (502)540-6031.

Sincerely,

Staci Huber  
Process Supervisor

SH/ Cedar Creek. 11/24.

Enclosures

Cc: V. Teague  
K. Robinson  
M. Saylor





					Value NODI													
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample = 175.0	= 265.0	26 - lb/d		= 3.0	= 3.0	19 - mg/L	0	01/07 - Weekly	CP - COMPOS				
					Permit Req. <= 626.0 MO AVG	<= 939.0 MX WK AV	26 - lb/d		<= 10.0 MO AVG	<= 15.0 MX WK AV	19 - mg/L		01/07 - Weekly	24 - COMP24				
					Value NODI													
80082	BOD, carbonaceous [5 day, 20 C]	G - Raw Sewage Influent	0	--	Sample = 77.0	= 114.0			77.0	114.0	19 - mg/L	0	01/07 - Weekly	CP - COMPOS				
					Permit Req.				Req Mon MO AVG	Req Mon MX WK AV	19 - mg/L		01/07 - Weekly	24 - COMP24				
					Value NODI													
80091	BOD, carb-5 day, 20 deg C, percent removal	K - Percent Removal	0	--	Sample = 96.0						23 - %	0	01/30 - Monthly	CA - CALCTD				
					Permit Req. >= 85.0 MO AV MN						23 - %		01/30 - Monthly	CA - CALCTD				
					Value NODI													
81011	Solids, suspended percent removal	K - Percent Removal	0	--	Sample = 98.0						23 - %	0	01/30 - Monthly	CA - CALCTD				
					Permit Req. >= 85.0 MO AV MN						23 - %		01/30 - Monthly	CA - CALCTD				
					Value NODI													

**Submission Note**

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**

No errors.

**Comments**

**Attachments**

Name	Type	Size
CCMOR.pdf	pdf	133515.0
CCCoverletter.pdf	pdf	38371.0

**Report Last Saved By**

**Cedar Creek WQTC MSD**

User: CURT.OTTO@LOUISVILLEMSD.ORG  
 Name: Curt Otto  
 E-Mail: curt.otto@louisvillemsd.org  
 Date/Time: 2024-12-18 10:56 (Time Zone: -05:00)

**Report Last Signed By**

User: CURT.OTTO@LOUISVILLEMSD.ORG  
 Name: Curt Otto  
 E-Mail: curt.otto@louisvillemsd.org  
 Date/Time: 2024-12-18 11:04 (Time Zone: -05:00)