



700 West Liberty Street | Louisville, KY 40203-1911
Phone: 502.540.6000 | LouisvilleMSD.org

December 3, 2024

Crystal Dennis
300 Sower Blvd., 3rd Floor
Frankfort, Kentucky 40601

**RE: Hillview #1, KPDES No: KY0034151
Discharge Monitoring Report for November 2024.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) for Hillview #1, for the month of November 2024.

There were no exceedances, overflows.

Also attached is overflow report.

If you have any questions concerning the attached DMR's, please contact me at (502) 540-6717.

Sincerely,

Jon Baldrige
Process Supervisor

JOB/ TF 11/24.

Cc: V. Teague / B. Tinnell



					Value NODI														
50050	Flow, in conduit or thru treatment plant	G - Raw Sewage Influent	0	--	Sample	=	0.05	=	0.253	03 - MGD								99/99 - Continuous	RE - Record (manual)
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	03 - MGD							0	99/99 - Continuous	RE - Record (manual)
					Value NODI														
51040	E. coli	1 - Effluent Gross	0	--	Sample							=	2.0	=	5.0	13 - #/100mL		01/07 - Weekly	GR - GRAB
					Permit Req.						<=	130.0 30DA GEO	<=	240.0 7 DA GEO	13 - #/100mL	0	01/07 - Weekly	GR - GRAB	
					Value NODI														
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample	=	3.32	=	8.632	26 - lb/d		=	5.0	=	7.0	19 - mg/L		01/07 - Weekly	24 - COMP24
					Permit Req.	<=	12.51 MO AVG	<=	18.765 MX WK AV	26 - lb/d	<=	10.0 MO AVG	<=	15.0 MX WK AV	19 - mg/L	0	01/07 - Weekly	24 - COMP24	
					Value NODI														
80082	BOD, carbonaceous [5 day, 20 C]	G - Raw Sewage Influent	0	--	Sample							=	155.0	=	200.0	19 - mg/L		01/07 - Weekly	24 - COMP24
					Permit Req.							Req Mon MO AVG		Req Mon MX WK AV	19 - mg/L	0	01/07 - Weekly	24 - COMP24	
					Value NODI														
80091	BOD, carb-5 day, 20 deg C, percent removal	K - Percent Removal	0	--	Sample					=	96.6					23 - %		01/30 - Monthly	CA - CALCTD
					Permit Req.						>=	85.0 MO AV MN			23 - %	0	01/30 - Monthly	CA - CALCTD	
					Value NODI														
81011	Solids, suspended percent removal	K - Percent Removal	0	--	Sample					=	92.6					23 - %		01/30 - Monthly	CA - CALCTD
					Permit Req.						>=	85.0 MO AV MN			23 - %	0	01/30 - Monthly	CA - CALCTD	
					Value NODI														

Submission Note
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors
No errors.

Comments

Attachments

Name	Type	Size
11_Nov_2024_All_Service_area_fin.pdf	pdf	349813.0
Hillview1coverletter1.pdf	pdf	189184.0

Report Last Saved By
Louisville and Jefferson County MSD
User: CURT.OTTO@LOUISVILLEMSD.ORG
Name: Curt Otto
E-Mail: curt.otto@louisvillemsd.org
Date/Time: 2024-12-19 09:34 (Time Zone: -05:00)

Report Last Signed By
User: CURT.OTTO@LOUISVILLEMSD.ORG
Name: Curt Otto
E-Mail: curt.otto@louisvillemsd.org
Date/Time: 2024-12-19 09:35 (Time Zone: -05:00)



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	02933	7900 SHELBYVILLE RD	MORRIS FORMAN	MIDDLE FORK BEARGRASS CREEK	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3869598		11/14/2024 5:35:00 AM	DAVIS BROWN	MONTGOMERY	DOCUMENTED	3/4/2008 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/15/24 07:40 AM	MAIN

Discharge Reporting:

Discharge Amount:	156,000 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	WO#3869858.
Control Zone:	PLACED CAUTION TAPE, TEMPORARY DISCHARGE SIGNS, AND BARRICADE PLACED AROUND THE IMPACTED AREA.
Impact:	MANHOLE DISCHARGING.
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE INTEGRATED OVERFLOW ABATEMENT PLAN.
Public Notification:	PUBLIC NOTIFIED THROUGH PERMANENT OVERFLOW SIGNS POSTED ALONG THE CREEK AND TEMPORARY SIGNS AT DISCHARGE SITE TO AVOID CONTACT WITH DISCHARGED CONTENT.

Notifications:

11/14/24 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/14/24 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	08426	4309 PRUITT CT	MORRIS FORMAN	SOUTH FORK BEARGRASS CREEK	GROUND

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3869534		11/14/2024 3:45:00 AM	DAVIS BROWN	AYO II	DOCUMENTED	2/25/2011 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/14/24 02:00 PM	MAIN

Discharge Reporting:

Discharge Amount:	18,450 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	WO#3869822.
Control Zone:	PLACED CAUTION TAPE, TEMPORARY DISCHARGE SIGNS, AND BARRICADE PLACED AROUND THE IMPACTED AREA.
Impact:	SEWAGE/DEBRIS/SOLIDS/PERSONAL HYGIENE PRODUCTS FOUND AROUND MANHOLE.
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE INTEGRATED OVERFLOW ABATEMENT PLAN.
Public Notification:	PUBLIC NOTIFIED THROUGH DOOR CARDS AND TEMPORARY DISCHARGE SIGNS AT THE DISCHARGE SITE TO AVOID CONTACT WITH DISCHARGED CONTENT.

Notifications:

11/14/24 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/14/24 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	08427	4313 PRUITT CT	MORRIS FORMAN	SOUTH FORK BEARGRASS CREEK	GROUND

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3869535		11/14/2024 3:45:00 AM	DAVIS BROWN	AYO II	DOCUMENTED	2/25/2011 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/14/24 03:51 PM	MAIN

Discharge Reporting:

Discharge Amount:	21,780 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	WO#3869823.
Control Zone:	PLACED CAUTION TAPE, TEMPORARY DISCHARGE SIGNS, AND BARRICADE PLACED AROUND THE IMPACTED AREA.
Impact:	SEWAGE/DEBRIS/SOLIDS/PERSONAL HYGIENE PRODUCTS FOUND AROUND MANHOLE.
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE INTEGRATED OVERFLOW ABATEMENT PLAN.
Public Notification:	PUBLIC NOTIFIED THROUGH DOOR CARDS AND TEMPORARY DISCHARGE SIGNS AT THE DISCHARGE SITE TO AVOID CONTACT WITH DISCHARGED CONTENT.

Notifications:

11/14/24 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/14/24 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	08429	4335 PRUITT CT	MORRIS FORMAN	BUECHEL BRANCH	GROUND

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3869536		11/14/2024 3:47:00 AM	DAVIS BROWN	AYO II	DOCUMENTED	4/22/2021 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/14/24 02:00 PM	MAIN

Discharge Reporting:

Discharge Amount:	6,150 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	WO3869824.
Control Zone:	PLACED CAUTION TAPE, TEMPORARY DISCHARGE SIGNS, AND BARRICADE PLACED AROUND THE IMPACTED AREA.
Impact:	SEWAGE/DEBRIS/SOLIDS/PERSONAL HYGIENE PRODUCTS FOUND AROUND MANHOLE.
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE INTEGRATED OVERFLOW ABATEMENT PLAN.
Public Notification:	PUBLIC NOTIFIED THROUGH DOOR CARDS AND TEMPORARY DISCHARGE SIGNS AT THE DISCHARGE SITE TO AVOID CONTACT WITH DISCHARGED CONTENT.

Notifications:

11/14/24 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/14/24 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	08430	4341 PRUITT CT	MORRIS FORMAN	SOUTH FORK BEARGRASS CREEK	GROUND

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3869537		11/14/2024 3:47:00 AM	DAVIS BROWN	AYO II	DOCUMENTED	6/22/2011 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/14/24 02:00 PM	MAIN

Discharge Reporting:

Discharge Amount:	18,450 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	WO#3869826.
Control Zone:	PLACED CAUTION TAPE, TEMPORARY DISCHARGE SIGNS, AND BARRICADE PLACED AROUND THE IMPACTED AREA.
Impact:	SEWAGE/DEBRIS/SOLIDS/PERSONAL HYGIENE PRODUCTS FOUND AROUND MANHOLE.
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE INTEGRATED OVERFLOW ABATEMENT PLAN.
Public Notification:	PUBLIC NOTIFIED THROUGH DOOR CARDS AND TEMPORARY DISCHARGE SIGNS AT THE DISCHARGE SITE TO AVOID CONTACT WITH DISCHARGED CONTENT.

Notifications:

11/14/24 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/14/24 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	08935-SM	1001 BRECKENRIDGE LN	MORRIS FORMAN	MIDDLE FORK BEARGRASS CREEK	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3868773		11/10/2024 10:15:00 AM	DAVIS BROWN		DOCUMENTED	11/29/2001 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/10/24 09:00 PM	MAIN

Discharge Reporting:

Discharge Amount:	600,000 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	NO CLEAN UP PERFORMED – PIPE DISCHARGING UNDERGROUND, DIRECTLY INTO STREAM.
Control Zone:	CONTROL ZONE WAS NOT ESTABLISHED DUE TO THE SIZE OF THE CREEK AND DIFFICULTY ACCESSING DISCHARGE AREAS.
Impact:	NONE OBSERVED OVERFLOW NOTIFICATION RECEIVED FROM REMOTE DISCHARGE ALARM.
Repair:	LOCATION INCLUDED IN IOAP. A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE INTEGRATED OVERFLOW ABATEMENT PLAN.
Public Notification:	PUBLIC NOTIFIED THROUGH PERMANENT OVERFLOW SIGNS TO AVOID DISCHARGED CONTENT.

Notifications:

11/10/24 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/10/24 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	08935-SM	1001 BRECKENRIDGE LN	MORRIS FORMAN	MIDDLE FORK BEARGRASS CREEK	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3869501		11/13/2024 9:15:00 PM	DAVIS BROWN		DOCUMENTED	11/29/2001 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/15/24 02:15 PM	MAIN

Discharge Reporting:

Discharge Amount:	6,000,000 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	NO CLEAN UP PERFORMED – PIPE DISCHARGING UNDERGROUND, DIRECTLY INTO STREAM. LACK OF SYSTEM CAPACITY HEAVY RAIN.
Control Zone:	CONTROL ZONE WAS NOT ESTABLISHED DUE TO THE SIZE OF THE CREEK AND DIFFICULTY ACCESSING DISCHARGE AREAS.
Impact:	NONE OBSERVED OVERFLOW NOTIFICATION RECEIVED FROM REMOTE DISCHARGE ALARM.
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE INTEGRATED OVERFLOW ABATEMENT PLAN.
Public Notification:	PUBLIC NOTIFIED THROUGH PERMANENT OVERFLOW SIGNS TO AVOID DISCHARGED CONTENT.

Notifications:

11/14/24 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/14/24 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0102784	MSD0294	FLOYDS FORK	FLOYDS FORK	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Valve	108247-V	3005 LONG CREEK WAY	FLOYDS FORK	KLEMENZ CREEK	GROUND

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISDW: DRY WEATHER DISCHARGE	3877023		11/20/2024 6:10:00 PM	SOSA RODRIGUEZ	SOSA RODRIGUEZ	REPAIRED - ISSUE RESOLVED	11/20/2024 12:00:00 AM	MECHANICAL FAILURE	UNAUTHORIZED DISCHARGE- WATERS	11/21/24 04:15 AM	

Discharge Reporting:

Discharge Amount:	2,000 GAL
Cause:	MECHANICAL FAILURE (BROKEN ARV).
Clean Up:	CLEANED AND SANITIZED THE IMPACTED AREA.
Control Zone:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	SEWAGE/DEBRIS/SOLIDS/PERSONAL HYGIENE PRODUCTS FOUND AROUND MANHOLE.
Repair:	REPAIRED THE ARV(INSTALLED REPAIR BAND TO STOP DISCHARGE).
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.

Notifications:

11/21/24 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/21/24 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0040126	MSD0411	KSR	CEDAR CREEK	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Main	122738A-V	2040 COX LN	KSR	CEDAR CREEK	GROUND

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3866106		11/6/2024 3:00:00 PM	BROADEN	BROADEN	REPAIRED - ISSUE RESOLVED	11/6/2024 12:00:00 AM	STRUCTURAL FAILURE	UNAUTHORIZED DISCHARGE-WATERS	11/06/24 03:30 PM	

Discharge Reporting:

Discharge Amount:	500 GAL
Cause:	STRUCTURAL FAILURE (FORCE MAIN BREAK).
Clean Up:	MSD CONTRACTOR CLEANED AND SANITIZED THE IMPACTED AREA.
Control Zone:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	SEWAGE/DEBRIS/SOLIDS/PERSONAL HYGIENE PRODUCTS FOUND ON THE GROUND.
Repair:	REPAIRED THE MAIN SEWER; WORK ORDER #3866126.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.

Notifications:

11/7/24 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/7/24 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0106143	MSD0407	OHIO RIVER	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Main	124056-V	2700 MEADOW WOOD CT	OHIO RIVER	POND CREEK	GROUND

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3869742		11/15/2024 9:50:00 AM	MILES	MECHANICAL CREW	REPAIRED - ISSUE RESOLVED	11/15/2024 12:00:00 AM	MECHANICAL FAILURE	UNAUTHORIZED DISCHARGE-WATERS	11/15/24 10:00 AM	

Discharge Reporting:

Discharge Amount:	500 GAL
Cause:	MECHANICAL FAILURE (FORCE MAIN PIPE BROKEN).
Clean Up:	MSD CONTRACTOR CLEANED AND SANITIZED THE IMPACTED AREA.
Control Zone:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	SEWAGE PRODUCTS FOUND IN THE STREAM.
Repair:	REPAIRED THE FORCEMAIN WO# 3869763.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.

Notifications:

11/15/24 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/15/24 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	16649	1726 FRASER DR	MORRIS FORMAN	SOUTH FORK BEARGRASS CREEK	DITCH

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3868671		11/10/2024 8:30:00 AM	DAVIS BROWN		DOCUMENTED	1/24/2002 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/10/24 07:15 PM	MAIN

Discharge Reporting:

Discharge Amount:	450 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	NO CLEAN UP PERFORMED – PIPE DISCHARGING UNDERGROUND, DIRECTLY INTO STREAM.
Control Zone:	CONTROL ZONE WAS NOT ESTABLISHED DUE TO THE SIZE OF THE CREEK AND DIFFICULTY ACCESSING DISCHARGE AREAS.
Impact:	NONE OBSERVED OVERFLOW NOTIFICATION RECEIVED FROM REMOTE DISCHARGE ALARM.
Repair:	LOCATION INCLUDED IN IOAP. A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE INTEGRATED OVERFLOW ABATEMENT PLAN.
Public Notification:	PUBLIC NOTIFIED THROUGH PERMANENT OVERFLOW SIGNS AND DOOR CARDS TO AVOID DISCHARGED CONTENT.

Notifications:

11/10/24 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/10/24 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	16649	1726 FRASER DR	MORRIS FORMAN	SOUTH FORK BEARGRASS CREEK	DITCH

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3869495		11/13/2024 7:45:00 PM	DAVIS BROWN		DOCUMENTED	1/24/2002 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/15/24 04:00 PM	MAIN

Discharge Reporting:

Discharge Amount:	195,840 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	NO CLEAN UP PERFORMED – PIPE DISCHARGING UNDERGROUND, DIRECTLY INTO STREAM. LACK OF SYSTEM CAPACITY HEAVY RAIN.
Control Zone:	CONTROL ZONE WAS NOT ESTABLISHED DUE TO THE SIZE OF THE CREEK AND DIFFICULTY ACCESSING DISCHARGE AREAS.
Impact:	NONE OBSERVED OVERFLOW NOTIFICATION RECEIVED FROM REMOTE DISCHARGE ALARM.
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE INTEGRATED OVERFLOW ABATEMENT PLAN.
Public Notification:	PUBLIC NOTIFIED THROUGH PERMANENT OVERFLOW SIGNS AND DOOR CARDS TO AVOID DISCHARGED CONTENT.

Notifications:

11/14/24 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/14/24 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	16649	1726 FRASER DR	MORRIS FORMAN	SOUTH FORK BEARGRASS CREEK	DITCH

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3876448		11/19/2024 7:00:00 AM	DAVIS BROWN		DOCUMENTED	1/24/2002 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/19/24 10:00 AM	MAIN

Discharge Reporting:

Discharge Amount:	960 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	NO CLEAN UP PERFORMED – PIPE DISCHARGING UNDERGROUND, DIRECTLY INTO STREAM.
Control Zone:	CONTROL ZONE WAS NOT ESTABLISHED DUE TO THE SIZE OF THE CREEK AND DIFFICULTY ACCESSING DISCHARGE AREAS.
Impact:	NONE OBSERVED OVERFLOW NOTIFICATION RECEIVED FROM REMOTE DISCHARGE ALARM.
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE INTEGRATED OVERFLOW ABATEMENT PLAN.
Public Notification:	PUBLIC NOTIFIED THROUGH PERMANENT OVERFLOW SIGNS AND DOOR CARDS TO AVOID DISCHARGED CONTENT.

Notifications:

11/19/24 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/19/24 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	23211	3302 TROUT CREEK DR	MORRIS FORMAN	SOUTH FORK BEARGRASS CREEK	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3869539		11/14/2024 4:50:00 AM	DAVIS BROWN	AYO II	DOCUMENTED	2/22/2000 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/15/24 04:15 AM	MAIN

Discharge Reporting:

Discharge Amount:	70,250 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	WO#3869829.
Control Zone:	PLACED CAUTION TAPE, TEMPORARY DISCHARGE SIGNS, AND BARRICADE PLACED AROUND THE IMPACTED AREA.
Impact:	SEWAGE/DEBRIS/SOLIDS/PERSONAL HYGIENE PRODUCTS FOUND AROUND MANHOLE.
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE INTEGRATED OVERFLOW ABATEMENT PLAN.
Public Notification:	PUBLIC NOTIFIED THROUGH DOOR CARDS AND TEMPORARY DISCHARGE SIGNS AT THE DISCHARGE SITE TO AVOID CONTACT WITH DISCHARGED CONTENT.

Notifications:

11/14/24 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/14/24 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	23212	2001 TERRIL LN	MORRIS FORMAN	SOUTH FORK BEARGRASS CREEK	GROUND

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3869540		11/14/2024 4:55:00 AM	DAVIS BROWN	AYO II	DOCUMENTED	4/4/2008 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/15/24 04:15 AM	MAIN

Discharge Reporting:

Discharge Amount:	35,125 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	WO#3869832.
Control Zone:	PLACED CAUTION TAPE, TEMPORARY DISCHARGE SIGNS, AND BARRICADE PLACED AROUND THE IMPACTED AREA.
Impact:	SEWAGE/DEBRIS/SOLIDS/PERSONAL HYGIENE PRODUCTS FOUND AROUND MANHOLE.
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE INTEGRATED OVERFLOW ABATEMENT PLAN.
Public Notification:	PUBLIC NOTIFIED THROUGH DOOR CARDS AND TEMPORARY DISCHARGE SIGNS AT THE DISCHARGE SITE TO AVOID CONTACT WITH DISCHARGED CONTENT.

Notifications:

11/14/24 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/14/24 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	27012	2408 GRAY FOX RD	MORRIS FORMAN	MIDDLE FORK BEARGRASS CREEK	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3868775		11/10/2024 11:45:00 AM	DAVIS BROWN	MONTGOMERY	DOCUMENTED	3/9/2019 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/10/24 05:05 PM	MAIN

Discharge Reporting:

Discharge Amount:	24,000 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	MAGNITUDE OF STORM RESULTED IN NO DEBRIS REMAINING.
Control Zone:	CAUTION TAPE, TEMPORARY DISCHARGE SIGNS, AND BARRICADE PLACED AROUND THE IMPACTED AREA.
Impact:	MANHOLE DISCHARGING INTO THE CREEK.
Repair:	LOCATION INCLUDED IN IOAP. A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE INTEGRATED OVERFLOW ABATEMENT PLAN.
Public Notification:	PUBLIC NOTIFIED THROUGH PERMANENT OVERFLOW SIGNS TO AVOID DISCHARGED CONTENT.

Notifications:

11/10/24 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/10/24 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	27012	2408 GRAY FOX RD	MORRIS FORMAN	MIDDLE FORK BEARGRASS CREEK	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3869677		11/14/2024 2:50:00 PM	DAVIS BROWN	MONTGOMERY	DOCUMENTED	3/9/2019 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/15/24 06:25 AM	MAIN

Discharge Reporting:

Discharge Amount:	70,125 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	MAGNITUDE OF STORM RESULTED IN NO DEBRIS REMAINING.
Control Zone:	PLACED CAUTION TAPE, TEMPORARY DISCHARGE SIGNS, AND BARRICADE PLACED AROUND THE IMPACTED AREA.
Impact:	SEWAGE/DEBRIS/SOLIDS/PERSONAL HYGIENE PRODUCTS FOUND AROUND MANHOLE.
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE INTEGRATED OVERFLOW ABATEMENT PLAN.
Public Notification:	PUBLIC NOTIFIED THROUGH PERMANENT OVERFLOW SIGNS POSTED ALONG THE CREEK AND TEMPORARY SIGNS AT DISCHARGE SITE TO AVOID CONTACT WITH DISCHARGED CONTENT.

Notifications:

11/15/24 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/15/24 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	27012	2408 GRAY FOX RD	MORRIS FORMAN	MIDDLE FORK BEARGRASS CREEK	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3876422		11/19/2024 7:45:00 AM	DAVIS BROWN	MONTGOMERY	DOCUMENTED	3/9/2019 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/19/24 10:55 AM	MAIN

Discharge Reporting:

Discharge Amount:	135,000 GAL
Cause:	LACK OF SYSTEM LOCATION HEAVY RAIN.
Clean Up:	CLEAN UP NOT REQUIRED. MAGNITUDE OF STORM FLUSHED SOLIDS AND DEBRIS FROM SITE.
Control Zone:	PLACED TEMPORARY SIGNS & BARRICADES POSTED AROUND THE IMPACTED AREA.
Impact:	MANHOLE DISCHARGING INTO THE CREEK.
Repair:	LOCATION INCLUDED IN IOAP.
Public Notification:	PUBLIC NOTIFIED THROUGH TEMP DISCHARGE SIGNS AT THE DISCHARGE SITES & PERMANENT DISCHARGE SIGNS POSTED ALONG THE CREEK.

Notifications:

11/19/24 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/19/24 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	28249	3500 ST EDWARDS DR	MORRIS FORMAN	CHENOWETH RUN	DITCH

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3868766		11/10/2024 9:19:00 AM	DAVIS BROWN	BAILEY	DOCUMENTED	3/12/2006 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/11/24 07:12 AM	MAIN

Discharge Reporting:

Discharge Amount:	65,000 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	WO#3868939.
Control Zone:	CAUTION TAPE, TEMPORARY DISCHARGE SIGNS, AND BARRICADE PLACED AROUND THE IMPACTED AREA.
Impact:	MANHOLE DISCHARGING.
Repair:	LOCATION INCLUDED IN IOAP.A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE INTEGRATED OVERFLOW ABATEMENT PLAN.
Public Notification:	PUBLIC NOTIFIED THROUGH DOOR CARD AND PERMANENT OVERFLOW SIGNS TO AVOID DISCHARGED CONTENT.

Notifications:

11/10/24 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/10/24 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	28249	3500 ST EDWARDS DR	MORRIS FORMAN	CHENOWETH RUN	DITCH

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3869527		11/14/2024 3:38:00 AM	DAVIS BROWN	BAILEY	DOCUMENTED	3/12/2006 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/15/24 04:38 AM	MAIN

Discharge Reporting:

Discharge Amount:	75,000 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	WO#3868939.
Control Zone:	PLACED CAUTION TAPE, TEMPORARY DISCHARGE SIGNS, AND BARRICADE PLACED AROUND THE IMPACTED AREA.
Impact:	SEWAGE/DEBRIS/SOLIDS/PERSONAL HYGIENE PRODUCTS FOUND AROUND MANHOLE.
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE INTEGRATED OVERFLOW ABATEMENT PLAN.
Public Notification:	PUBLIC NOTIFIED THROUGH PERMANENT OVERFLOW SIGNS AND DOOR CARDS TO AVOID DISCHARGED CONTENT.

Notifications:

11/14/24 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/14/24 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	28250	3506 CHARLANE PKY	MORRIS FORMAN	CHENOWETH RUN	DITCH

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3868764		11/10/2024 9:18:00 AM	DAVIS BROWN	BAILEY	DOCUMENTED	1/3/2005 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/11/24 07:10 AM	MAIN

Discharge Reporting:

Discharge Amount:	65,500 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	WO#3868937.
Control Zone:	CAUTION TAPE, TEMPORARY DISCHARGE SIGNS, AND BARRICADE PLACED AROUND THE IMPACTED AREA.
Impact:	MANHOLE DISCHARGING.
Repair:	LOCATION INCLUDED IN IOAP. A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE INTEGRATED OVERFLOW ABATEMENT PLAN.
Public Notification:	PUBLIC NOTIFIED THROUGH DOOR CARD AND PERMANENT OVERFLOW SIGNS TO AVOID DISCHARGED CONTENT.

Notifications:

11/10/24 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/10/24 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	28250	3506 CHARLANE PKY	MORRIS FORMAN	CHENOWETH RUN	DITCH

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3869526		11/14/2024 3:35:00 AM	DAVIS BROWN	BAILEY	DOCUMENTED	1/3/2005 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/15/24 04:36 AM	MAIN

Discharge Reporting:

Discharge Amount:	75,000 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	WO#3868937.
Control Zone:	PLACED CAUTION TAPE, TEMPORARY DISCHARGE SIGNS, AND BARRICADE PLACED AROUND THE IMPACTED AREA.
Impact:	SEWAGE/DEBRIS/SOLIDS/PERSONAL HYGIENE PRODUCTS FOUND AROUND MANHOLE
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE INTEGRATED OVERFLOW ABATEMENT PLAN.
Public Notification:	PUBLIC NOTIFIED THROUGH PERMANENT OVERFLOW SIGNS AND DOOR CARDS TO AVOID DISCHARGED CONTENT.

Notifications:

11/14/24 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/14/24 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	28336	3620 CHARLANE PKY	MORRIS FORMAN	CHENOWETH RUN	DITCH

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3868772		11/10/2024 9:22:00 AM	DAVIS BROWN	BAILEY	DOCUMENTED	8/30/2005 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/11/24 07:17 AM	MAIN

Discharge Reporting:

Discharge Amount:	65,750 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	WO#3868941.
Control Zone:	CAUTION TAPE, TEMPORARY DISCHARGE SIGNS, AND BARRICADE PLACED AROUND THE IMPACTED AREA.
Impact:	MANHOLE DISCHARGING.
Repair:	LOCATION INCLUDED IN IOAP. A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE INTEGRATED OVERFLOW ABATEMENT PLAN.
Public Notification:	PUBLIC NOTIFIED THROUGH DOOR CARD AND PERMANENT OVERFLOW SIGNS TO AVOID DISCHARGED CONTENT.

Notifications:

11/10/24 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/10/24 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	28336	3620 CHARLANE PKY	MORRIS FORMAN	CHENOWETH RUN	DITCH

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3869530		11/14/2024 3:42:00 AM	DAVIS BROWN	BAILEY	DOCUMENTED	8/30/2005 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/15/24 05:02 AM	MAIN

Discharge Reporting:

Discharge Amount:	114,000 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	WO#3868941.
Control Zone:	PLACED CAUTION TAPE, TEMPORARY DISCHARGE SIGNS, AND BARRICADE PLACED AROUND THE IMPACTED AREA.
Impact:	SEWAGE/DEBRIS/SOLIDS/PERSONAL HYGIENE PRODUCTS FOUND AROUND MANHOLE.
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE INTEGRATED OVERFLOW ABATEMENT PLAN.
Public Notification:	PUBLIC NOTIFIED THROUGH PERMANENT OVERFLOW SIGNS AND DOOR CARDS TO AVOID DISCHARGED CONTENT.

Notifications:

11/14/24 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/14/24 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	28340	3620 CHARLANE PKY	MORRIS FORMAN	CHENOWETH RUN	GROUND

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3868771		11/10/2024 9:20:00 AM	DAVIS BROWN	BAILEY	DOCUMENTED	1/3/2005 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/11/24 07:25 AM	MAIN

Discharge Reporting:

Discharge Amount:	33,125 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	WO#3868940.
Control Zone:	CAUTION TAPE, TEMPORARY DISCHARGE SIGNS, AND BARRICADE PLACED AROUND THE IMPACTED AREA.
Impact:	MANHOLE DISCHARGING.
Repair:	LOCATION INCLUDED IN IOAP. A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE INTEGRATED OVERFLOW ABATEMENT PLAN.
Public Notification:	PUBLIC NOTIFIED THROUGH DOOR CARD AND PERMANENT OVERFLOW SIGNS TO AVOID DISCHARGED CONTENT.

Notifications:

11/10/24 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/10/24 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	28340	3620 CHARLANE PKY	MORRIS FORMAN	CHENOWETH RUN	GROUND

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3869529		11/14/2024 3:39:00 AM	DAVIS BROWN	BAILEY	DOCUMENTED	1/3/2005 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/15/24 05:00 AM	MAIN

Discharge Reporting:

Discharge Amount:	152,100 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	WO#3868940.
Control Zone:	PLACED CAUTION TAPE, TEMPORARY DISCHARGE SIGNS, AND BARRICADE PLACED AROUND THE IMPACTED AREA.
Impact:	SEWAGE/DEBRIS/SOLIDS/PERSONAL HYGIENE PRODUCTS FOUND AROUND MANHOLE.
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE INTEGRATED OVERFLOW ABATEMENT PLAN.
Public Notification:	PUBLIC NOTIFIED THROUGH PERMANENT OVERFLOW SIGNS AND DOOR CARDS TO AVOID DISCHARGED CONTENT.

Notifications:

11/14/24 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/14/24 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	28451	3406 CHARLANE PKY	MORRIS FORMAN	CHENOWETH RUN	GROUND

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3868679		11/10/2024 9:17:00 AM	DAVIS BROWN	BAILEY	DOCUMENTED	10/28/2015 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/11/24 07:08 AM	MAIN

Discharge Reporting:

Discharge Amount:	98,250 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	WO#3868936.
Control Zone:	CAUTION TAPE, TEMPORARY DISCHARGE SIGNS, AND BARRICADE PLACED AROUND THE IMPACTED AREA.
Impact:	MANHOLE DISCHARGING.
Repair:	LOCATION INCLUDED IN IOAP. A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE INTEGRATED OVERFLOW ABATEMENT PLAN.
Public Notification:	PUBLIC NOTIFIED THROUGH DOOR CARD AND PERMANENT OVERFLOW SIGNS TO AVOID DISCHARGED CONTENT.

Notifications:

11/10/24 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/10/24 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	28451	3406 CHARLANE PKY	MORRIS FORMAN	CHENOWETH RUN	GROUND

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3869522		11/14/2024 3:34:00 AM	DAVIS BROWN	BAILEY	DOCUMENTED	10/28/2015 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/15/24 04:34 AM	MAIN

Discharge Reporting:

Discharge Amount:	75,000 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	WO#3868936.
Control Zone:	PLACED CAUTION TAPE, TEMPORARY DISCHARGE SIGNS, AND BARRICADE PLACED AROUND THE IMPACTED AREA.
Impact:	SEWAGE/DEBRIS/SOLIDS/PERSONAL HYGIENE PRODUCTS FOUND AROUND MANHOLE.
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE INTEGRATED OVERFLOW ABATEMENT PLAN.
Public Notification:	PUBLIC NOTIFIED THROUGH PERMANENT OVERFLOW SIGNS AND DOOR CARDS TO AVOID DISCHARGED CONTENT.

Notifications:

11/14/24 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/14/24 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	28452	3402 CHARLANE PKY	MORRIS FORMAN	CHENOWETH RUN	DITCH

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3868675		11/10/2024 9:16:00 AM	DAVIS BROWN	BAILEY	DOCUMENTED	11/30/2019 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/11/24 07:05 AM	MAIN

Discharge Reporting:

Discharge Amount:	65,000 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	WO#3868935.
Control Zone:	CAUTION TAPE, TEMPORARY DISCHARGE SIGNS, AND BARRICADE PLACED AROUND THE IMPACTED AREA.
Impact:	MANHOLE DISCHARGING.
Repair:	LOCATION INCLUDED IN IOAP. A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE INTEGRATED OVERFLOW ABATEMENT PLAN.
Public Notification:	PUBLIC NOTIFIED THROUGH DOOR CARD AND PERMANENT OVERFLOW SIGNS TO AVOID DISCHARGED CONTENT.

Notifications:

11/10/24 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/10/24 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	28452	3402 CHARLANE PKY	MORRIS FORMAN	CHENOWETH RUN	DITCH

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3869519		11/14/2024 3:32:00 AM	DAVIS BROWN	BAILEY	DOCUMENTED	11/30/2019 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/15/24 04:32 AM	MAIN

Discharge Reporting:

Discharge Amount:	75,000 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	WO#3868935.
Control Zone:	PLACED CAUTION TAPE, TEMPORARY DISCHARGE SIGNS, AND BARRICADE PLACED AROUND THE IMPACTED AREA.
Impact:	SEWAGE/DEBRIS/SOLIDS/PERSONAL HYGIENE PRODUCTS FOUND AROUND MANHOLE.
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE INTEGRATED OVERFLOW ABATEMENT PLAN.
Public Notification:	PUBLIC NOTIFIED THROUGH PERMANENT OVERFLOW SIGNS AND DOOR CARDS TO AVOID DISCHARGED CONTENT.

Notifications:

11/14/24 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/14/24 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	28453	3402 CHARLANE PKY	MORRIS FORMAN	CHENOWETH RUN	DITCH

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3868673		11/10/2024 9:15:00 AM	DAVIS BROWN		DOCUMENTED	10/28/2015 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/10/24 09:45 PM	MAIN

Discharge Reporting:

Discharge Amount:	93,750 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	WO#3868931.
Control Zone:	CAUTION TAPE, TEMPORARY DISCHARGE SIGNS, AND BARRICADE PLACED AROUND THE IMPACTED AREA.
Impact:	MANHOLE DISCHARGING.
Repair:	LOCATION INCLUDED IN IOAP. A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE INTEGRATED OVERFLOW ABATEMENT PLAN.
Public Notification:	PUBLIC NOTIFIED THROUGH DOOR CARD AND PERMANENT OVERFLOW SIGNS TO AVOID DISCHARGED CONTENT.

Notifications:

11/10/24 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/10/24 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	28453	3402 CHARLANE PKY	MORRIS FORMAN	CHENOWETH RUN	DITCH

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3869517		11/13/2024 8:45:00 PM	DAVIS BROWN	BAILEY	DOCUMENTED	10/28/2015 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/15/24 04:30 AM	MAIN

Discharge Reporting:

Discharge Amount:	238,125 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	WO#3868931.
Control Zone:	PLACED CAUTION TAPE, TEMPORARY DISCHARGE SIGNS, AND BARRICADE PLACED AROUND THE IMPACTED AREA.
Impact:	SEWAGE/DEBRIS/SOLIDS/PERSONAL HYGIENE PRODUCTS FOUND AROUND MANHOLE.
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE INTEGRATED OVERFLOW ABATEMENT PLAN.
Public Notification:	PUBLIC NOTIFIED THROUGH PERMANENT OVERFLOW SIGNS AND DOOR CARDS TO AVOID DISCHARGED CONTENT.

Notifications:

11/14/24 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/14/24 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	40559	1012 ALTA CIR	MORRIS FORMAN	MIDDLE FORK BEARGRASS CREEK	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3868777		11/10/2024 12:15:00 PM	DAVIS BROWN	MONTGOMERY	DOCUMENTED	1/26/2012 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/10/24 05:00 PM	MAIN

Discharge Reporting:

Discharge Amount:	28,500 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	MAGNITUDE OF STORM RESULTED IN NO DEBRIS REMAINING.
Control Zone:	CAUTION TAPE, TEMPORARY DISCHARGE SIGNS, AND BARRICADE PLACED AROUND THE IMPACTED AREA.
Impact:	MANHOLE DISCHARGING.
Repair:	LOCATION INCLUDED IN IOAP. A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE INTEGRATED OVERFLOW ABATEMENT PLAN.
Public Notification:	PUBLIC NOTIFIED THROUGH PERMANENT OVERFLOW SIGNS TO AVOID DISCHARGED CONTENT.

Notifications:

11/11/24 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/11/24 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	40559	1012 ALTA CIR	MORRIS FORMAN	MIDDLE FORK BEARGRASS CREEK	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3869594		11/14/2024 4:50:00 AM	DAVIS BROWN	MONTGOMERY	DOCUMENTED	1/26/2012 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/15/24 06:40 AM	MAIN

Discharge Reporting:

Discharge Amount:	116,250 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	WO#3869853.
Control Zone:	CAUTION TAPE, TEMPORARY DISCHARGE SIGNS, AND BARRICADE PLACED AROUND THE IMPACTED AREA.
Impact:	SEWAGE/DEBRIS/SOLIDS/PERSONAL HYGIENE PRODUCTS FOUND AROUND MANHOLE.
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE INTEGRATED OVERFLOW ABATEMENT PLAN.
Public Notification:	PUBLIC NOTIFIED THROUGH PERMANENT OVERFLOW SIGNS POSTED ALONG THE CREEK AND TEMPORARY SIGNS AT DISCHARGE SITE TO AVOID CONTACT WITH DISCHARGED CONTENT.

Notifications:

11/14/24 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/14/24 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	45796	1011 ALTA CIR	MORRIS FORMAN	MIDDLE FORK BEARGRASS CREEK	DITCH

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3868776		11/10/2024 12:08:00 PM	DAVIS BROWN	MONTGOMERY	DOCUMENTED	5/10/2014 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/10/24 05:08 PM	MAIN

Discharge Reporting:

Discharge Amount:	37,500 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	WO#3868960.
Control Zone:	CAUTION TAPE, TEMPORARY DISCHARGE SIGNS, AND BARRICADE PLACED AROUND THE IMPACTED AREA.
Impact:	MANHOLE DISCHARGING.
Repair:	LOCATION INCLUDED IN IOAP. A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE INTEGRATED OVERFLOW ABATEMENT PLAN.
Public Notification:	PUBLIC NOTIFIED THROUGH PERMANENT OVERFLOW SIGNS TO AVOID DISCHARGED CONTENT.

Notifications:

11/10/24 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/10/24 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	45796	1011 ALTA CIR	MORRIS FORMAN	MIDDLE FORK BEARGRASS CREEK	DITCH

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3876426		11/19/2024 8:06:00 AM	DAVIS BROWN	MONTGOMERY	DOCUMENTED	5/10/2014 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/19/24 11:05 AM	MAIN

Discharge Reporting:

Discharge Amount:	9,000 GAL
Cause:	LACK OF SYSTEM CAPACITY - HEAVY RAIN.
Clean Up:	CLEAN UP NOT REQUIRED. MAGNITUDE OF STORM FLUSHED SOLIDS AND DEBRIS FROM SITE.
Control Zone:	PLACED TEMPORARY SIGNS & BARRICADES POSTED AROUND THE IMPACTED AREA.
Impact:	MANHOLE DISCHARGING INTO THE CREEK.
Repair:	LOCATION INCLUDED IN IOAP.
Public Notification:	PUBLIC NOTIFIED THROUGH TEMP DISCHARGE SIGNS AT THE DISCHARGE SITES & PERMANENT DISCHARGE SIGNS POSTED ALONG THE CREEK.

Notifications:

11/19/24 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/19/24 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Service Line	46602107	2107 LITTLE CREEK CT	MORRIS FORMAN	BROOKLAWN TRIBUTARY	GROUND

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3869564		11/14/2024 5:00:00 AM	DAVIS BROWN	AYO II	DOCUMENTED	4/20/2019 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/15/24 04:15 AM	MAIN

Discharge Reporting:

Discharge Amount:	42,000 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	WO#3869831.
Control Zone:	PLACED CAUTION TAPE, TEMPORARY DISCHARGE SIGNS, AND BARRICADE PLACED AROUND THE IMPACTED AREA.
Impact:	SEWAGE/DEBRIS/SOLIDS/PERSONAL HYGIENE PRODUCTS FOUND AROUND MANHOLE.
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE INTEGRATED OVERFLOW ABATEMENT PLAN.
Public Notification:	PUBLIC NOTIFIED THROUGH DOOR CARDS AND TEMPORARY DISCHARGE SIGNS AT THE DISCHARGE SITE TO AVOID CONTACT WITH DISCHARGED CONTENT.

Notifications:

11/14/24 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/14/24 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	46623	4801 CASSIA CT	MORRIS FORMAN	MUDDY FORK BEARGRASS CREEK	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3868816		11/10/2024 2:20:00 PM	DAVIS BROWN	MONTGOMERY	DOCUMENTED	2/24/2022 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/10/24 05:30 PM	MAIN

Discharge Reporting:

Discharge Amount:	4,750 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	WO#3868994.
Control Zone:	CAUTION TAPE, TEMPORARY DISCHARGE SIGNS, AND BARRICADE PLACED AROUND THE IMPACTED AREA.
Impact:	MANHOLE DISCHARGING.
Repair:	LOCATION INCLUDED IN IOAP SOLUTION FOR THIS LOCATION IS INCLUDED IN THE INTEGRATED OVERFLOW ABATEMENT PLAN.
Public Notification:	PUBLIC NOTIFIED THROUGH PERMANENT OVERFLOW SIGNS TO AVOID DISCHARGED CONTENT.

Notifications:

11/11/24 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/11/24 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	46623	4801 CASSIA CT	MORRIS FORMAN	MUDDY FORK BEARGRASS CREEK	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3869597		11/14/2024 7:22:00 AM	DAVIS BROWN	MONTGOMERY	DOCUMENTED	2/24/2022 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/15/24 08:20 AM	MAIN

Discharge Reporting:

Discharge Amount:	149,800 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	WO#3868994.
Control Zone:	CAUTION TAPE, TEMPORARY DISCHARGE SIGNS, AND BARRICADE PLACED AROUND THE IMPACTED AREA.
Impact:	MANHOLE DISCHARGING.
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE INTEGRATED OVERFLOW ABATEMENT PLAN.
Public Notification:	PUBLIC NOTIFIED THROUGH PERMANENT OVERFLOW SIGNS POSTED ALONG THE CREEK AND TEMPORARY SIGNS AT DISCHARGE SITE TO AVOID CONTACT WITH DISCHARGED CONTENT.

Notifications:

11/14/24 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/14/24 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	47582	201 BULLITT LN	MORRIS FORMAN	MIDDLE FORK BEARGRASS CREEK	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3868814		11/10/2024 1:00:00 PM	DAVIS BROWN	MONTGOMERY	DOCUMENTED	12/5/2011 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/11/24 06:40 AM	MAIN

Discharge Reporting:

Discharge Amount:	26,500 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	WO#3868962.
Control Zone:	CAUTION TAPE, TEMPORARY DISCHARGE SIGNS, AND BARRICADE PLACED AROUND THE IMPACTED AREA.
Impact:	MANHOLE DISCHARGING.
Repair:	LOCATION INCLUDED IN IOAP SOLUTION FOR THIS LOCATION IS INCLUDED IN THE INTEGRATED OVERFLOW ABATEMENT PLAN.
Public Notification:	PUBLIC NOTIFIED THROUGH PERMANENT OVERFLOW SIGNS TO AVOID DISCHARGED CONTENT.

Notifications:

11/11/24 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/11/24 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	47582	201 BULLITT LN	MORRIS FORMAN	MIDDLE FORK BEARGRASS CREEK	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3869595		11/14/2024 5:25:00 AM	DAVIS BROWN	MONTGOMERY	DOCUMENTED	12/5/2011 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/15/24 07:25 AM	MAIN

Discharge Reporting:

Discharge Amount:	117,000 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	WO#3869855
Control Zone:	PLACED CAUTION TAPE, TEMPORARY DISCHARGE SIGNS, AND BARRICADE PLACED AROUND THE IMPACTED AREA.
Impact:	SEWAGE/DEBRIS/SOLIDS/PERSONAL HYGIENE PRODUCTS FOUND AROUND MANHOLE.
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE INTEGRATED OVERFLOW ABATEMENT PLAN.
Public Notification:	PUBLIC NOTIFIED THROUGH PERMANENT OVERFLOW SIGNS POSTED ALONG THE CREEK AND TEMPORARY SIGNS AT DISCHARGE SITE TO AVOID CONTACT WITH DISCHARGED CONTENT.

Notifications:

11/14/24 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/14/24 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	47583	202 OXMOOR LN	MORRIS FORMAN	MIDDLE FORK BEARGRASS CREEK	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3868815		11/10/2024 1:05:00 PM	DAVIS BROWN	MONTGOMERY	DOCUMENTED	2/6/2008 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/11/24 06:49 AM	MAIN

Discharge Reporting:

Discharge Amount:	100,600 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	WO#3868961.
Control Zone:	CAUTION TAPE, TEMPORARY DISCHARGE SIGNS, AND BARRICADE PLACED AROUND THE IMPACTED AREA.
Impact:	MANHOLE DISCHARGING.
Repair:	LOCATION INCLUDED IN IOAP SOLUTION FOR THIS LOCATION IS INCLUDED IN THE INTEGRATED OVERFLOW ABATEMENT PLAN.
Public Notification:	PUBLIC NOTIFIED THROUGH PERMANENT OVERFLOW SIGNS TO AVOID DISCHARGED CONTENT.

Notifications:

11/11/24 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/11/24 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	47583	202 OXMOOR LN	MORRIS FORMAN	MIDDLE FORK BEARGRASS CREEK	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3869596		11/14/2024 5:30:00 AM	DAVIS BROWN	MONTGOMERY	DOCUMENTED	2/6/2008 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/15/24 07:30 AM	MAIN

Discharge Reporting:

Discharge Amount:	156,000 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	WO#3869856.
Control Zone:	PLACED CAUTION TAPE, TEMPORARY DISCHARGE SIGNS, AND BARRICADE PLACED AROUND THE IMPACTED AREA.
Impact:	MANHOLE DISCHARGING.
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE INTEGRATED OVERFLOW ABATEMENT PLAN.
Public Notification:	PUBLIC NOTIFIED THROUGH PERMANENT OVERFLOW SIGNS POSTED ALONG THE CREEK AND TEMPORARY SIGNS AT DISCHARGE SITE TO AVOID CONTACT WITH DISCHARGED CONTENT.

Notifications:

11/14/24 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/14/24 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	47603	8016 SHELBYVILLE RD	MORRIS FORMAN	MIDDLE FORK BEARGRASS CREEK	GROUND

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3869675		11/14/2024 3:00:00 PM	DAVIS BROWN	MONTGOMERY	DOCUMENTED	3/4/2008 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/15/24 08:00 AM	MAIN

Discharge Reporting:

Discharge Amount:	76,500 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	WO#3869854.
Control Zone:	CAUTION TAPE, TEMPORARY DISCHARGE SIGNS, AND BARRICADE PLACED AROUND THE IMPACTED AREA.
Impact:	MANHOLE DISCHARGING.
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE INTEGRATED OVERFLOW ABATEMENT PLAN.
Public Notification:	PUBLIC NOTIFIED THROUGH PERMANENT OVERFLOW SIGNS POSTED ALONG THE CREEK AND TEMPORARY SIGNS AT DISCHARGE SITE TO AVOID CONTACT WITH DISCHARGED CONTENT.

Notifications:

11/15/24 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/15/24 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	49647	4315 PRUITT CT	MORRIS FORMAN	SOUTH FORK BEARGRASS CREEK	GROUND

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3869538		11/14/2024 4:00:00 AM	DAVIS BROWN	AYO II	DOCUMENTED	2/28/2011 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/14/24 04:00 PM	MAIN

Discharge Reporting:

Discharge Amount:	36,000 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	WO#3869827.
Control Zone:	PLACED CAUTION TAPE, TEMPORARY DISCHARGE SIGNS, AND BARRICADE PLACED AROUND THE IMPACTED AREA.
Impact:	SEWAGE/DEBRIS/SOLIDS/PERSONAL HYGIENE PRODUCTS FOUND AROUND MANHOLE.
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE INTEGRATED OVERFLOW ABATEMENT PLAN.
Public Notification:	PUBLIC NOTIFIED THROUGH DOOR CARDS AND TEMPORARY DISCHARGE SIGNS AT THE DISCHARGE SITE TO AVOID CONTACT WITH DISCHARGED CONTENT.

Notifications:

11/14/24 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/14/24 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	51160	3305 INDIAN CREEK CT	MORRIS FORMAN	SOUTH FORK BEARGRASS CREEK	GROUND

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3869563		11/14/2024 5:02:00 AM	DAVIS BROWN	AYO II	DOCUMENTED	4/4/2008 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/15/24 04:15 AM	MAIN

Discharge Reporting:

Discharge Amount:	35,000 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	WO#3869854.
Control Zone:	PLACED CAUTION TAPE, TEMPORARY DISCHARGE SIGNS, AND BARRICADE PLACED AROUND THE IMPACTED AREA.
Impact:	SEWAGE/DEBRIS/SOLIDS/PERSONAL HYGIENE PRODUCTS FOUND AROUND MANHOLE.
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE INTEGRATED OVERFLOW ABATEMENT PLAN.
Public Notification:	PUBLIC NOTIFIED THROUGH DOOR CARDS AND TEMPORARY DISCHARGE SIGNS AT THE DISCHARGE SITE TO AVOID CONTACT WITH DISCHARGED CONTENT.

Notifications:

11/14/24 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/14/24 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	51180	2011 TERRIL LN	MORRIS FORMAN	BROOKLAWN TRIBUTARY	GROUND

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3869562		11/14/2024 4:56:00 AM	DAVIS BROWN	AYO II	DOCUMENTED	12/5/2011 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/15/24 04:15 AM	MAIN

Discharge Reporting:

Discharge Amount:	105,375 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	WO#3869830.
Control Zone:	PLACED CAUTION TAPE, TEMPORARY DISCHARGE SIGNS, AND BARRICADE PLACED AROUND THE IMPACTED AREA.
Impact:	SEWAGE/DEBRIS/SOLIDS/PERSONAL HYGIENE PRODUCTS FOUND AROUND MANHOLE.
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE INTEGRATED OVERFLOW ABATEMENT PLAN.
Public Notification:	PUBLIC NOTIFIED THROUGH DOOR CARDS AND TEMPORARY DISCHARGE SIGNS AT THE DISCHARGE SITE TO AVOID CONTACT WITH DISCHARGED CONTENT.

Notifications:

11/14/24 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/14/24 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	65623	1804 ROUND RIDGE RD	MORRIS FORMAN	MUDDY FORK BEARGRASS CREEK	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3868818		11/10/2024 2:25:00 PM	DAVIS BROWN	MONTGOMERY	QUEUED FOR INVESTIGATION / REPAIR	2/17/2023 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/10/24 05:32 PM	MAIN

Discharge Reporting:

Discharge Amount:	4,750 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	CLEAN UP NOT POSSIBLE – DUE TO THE SIZE OF THE CREEK AND LACK OF ACCESS TO THE DISCHARGE AREAS.
Control Zone:	CONTROL ZONE WAS NOT ESTABLISHED DUE TO THE SIZE OF THE CREEK AND DIFFICULTY ACCESSING DISCHARGE AREAS.
Impact:	MANHOLE DISCHARGING INTO CREEK.
Repair:	LOCATION INCLUDED IN IOAP SOLUTION FOR THIS LOCATION IS INCLUDED IN THE INTEGRATED OVERFLOW ABATEMENT PLAN.
Public Notification:	PUBLIC NOTIFIED THROUGH PERMANENT OVERFLOW SIGNS TO AVOID DISCHARGED CONTENT.

Notifications:

11/11/24 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/11/24 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	65623	1804 ROUND RIDGE RD	MORRIS FORMAN	MUDDY FORK BEARGRASS CREEK	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3869602		11/14/2024 7:25:00 AM	DAVIS BROWN	MONTGOMERY	QUEUED FOR INVESTIGATION / REPAIR	2/17/2023 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/15/24 08:23 AM	MAIN

Discharge Reporting:

Discharge Amount:	149,800 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	CLEAN UP NOT POSSIBLE – DUE TO THE SIZE OF THE CREEK AND LACK OF ACCESS TO THE DISCHARGE AREAS..
Control Zone:	CONTROL ZONE WAS NOT ESTABLISHED DUE TO THE SIZE OF THE CREEK AND DIFFICULTY ACCESSING DISCHARGE AREAS.
Impact:	MANHOLE DISCHARGING.
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE INTEGRATED OVERFLOW ABATEMENT PLAN.
Public Notification:	PUBLIC NOTIFIED THROUGH PERMANENT OVERFLOW SIGNS POSTED ALONG THE CREEK TO AVOID CONTACT WITH DISCHARGED CONTENT.

Notifications:

11/14/24 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/14/24 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0078956	MSD0277	DEREK R. GUTHRIE	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	81440	423 ECHAPPE LN	DEREK R. GUTHRIE	BEE LICK CREEK	GROUND

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3869680		11/14/2024 7:30:00 AM	SMITH		QUEUED FOR INVESTIGATION / REPAIR	11/14/2024 12:00:00 AM	MECHANICAL FAILURE	UNAUTHORIZED DISCHARGE-WATERS	11/14/24 04:36 PM	

Discharge Reporting:

Discharge Amount:	50 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	PIPE DISCHARGING UNDERGROUND.
Control Zone:	PLACED TEMPORARY SIGNS AND BARRICADES AROUND THE IMPACTED AREA.
Impact:	ROADWAY AT THE END OF ECHAPPE LANE HAS BALLONED UPWARD FROM PRESSURE
Repair:	REFERRED TO CREW FOR INSPECTION.
Public Notification:	ADVISED CUSTOMER ON SITE.

Notifications:

11/15/24 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
------------------	--------	---



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0078956	MSD0277	DEREK R. GUTHRIE	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	81443	420 ECHAPPE LN	DEREK R. GUTHRIE	BEE LICK CREEK	DITCH

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3869679		11/14/2024 3:42:00 PM	JACKSON-BRITTLE		DOCUMENTED	9/9/2018 12:00:00 AM	MECHANICAL FAILURE	UNAUTHORIZED DISCHARGE-WATERS	11/14/24 03:30 PM	MAIN

Discharge Reporting:

Discharge Amount:	50 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	NO CLEAN UP PERFORMED – PIPE DISCHARGING UNDERGROUND, DIRECTLY INTO STREAM.
Control Zone:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	NONE OBSERVED.
Repair:	N/A
Public Notification:	ADVISED CUSTOMER ON SITE.

Notifications:

11/15/24 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
------------------	--------	---



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	84155	7913 SHELBYVILLE RD	MORRIS FORMAN	MIDDLE FORK BEARGRASS CREEK	GROUND

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3869599		11/14/2024 5:50:00 AM	DAVIS BROWN	MONTGOMERY	DOCUMENTED	3/10/2011 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/15/24 07:50 AM	MAIN

Discharge Reporting:

Discharge Amount:	156,000 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	WO#3869849.
Control Zone:	PLACED CAUTION TAPE, TEMPORARY DISCHARGE SIGNS, AND BARRICADE PLACED AROUND THE IMPACTED AREA.
Impact:	MANHOLE DISCHARGING.
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE INTEGRATED OVERFLOW ABATEMENT PLAN.
Public Notification:	PUBLIC NOTIFIED THROUGH PERMANENT OVERFLOW SIGNS POSTED ALONG THE CREEK AND TEMPORARY SIGNS AT DISCHARGE SITE TO AVOID CONTACT WITH DISCHARGED CONTENT.

Notifications:

11/14/24 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/14/24 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	90700	8021 CHRISTIAN CT	MORRIS FORMAN	MIDDLE FORK BEARGRASS CREEK	CATCH BASIN

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3869612		11/14/2024 12:45:00 PM	DAVIS BROWN	MONTGOMERY	DOCUMENTED	3/19/2008 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/15/24 07:45 AM	MAIN

Discharge Reporting:

Discharge Amount:	85,425 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	WO#3869842.
Control Zone:	PLACED CAUTION TAPE, TEMPORARY DISCHARGE SIGNS, AND BARRICADE PLACED AROUND THE IMPACTED AREA.
Impact:	MANHOLE DISCHARGING.
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE INTEGRATED OVERFLOW ABATEMENT PLAN.
Public Notification:	PUBLIC NOTIFIED THROUGH DOOR CARDS AND TEMPORARY SIGNS AT DISCHARGE SITE TO AVOID CONTACT WITH DISCHARGED CONTENT.

Notifications:

11/14/24 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/14/24 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Service Line	HU16742029	9000 WESSEX PL	MORRIS FORMAN	MIDDLE FORK BEARGRASS CREEK	GROUND

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISDW: DRY WEATHER DISCHARGE	3863261		11/4/2024 10:50:00 AM	FERRELL		REPAIRED - ISSUE RESOLVED	11/4/2024 12:00:00 AM	OBSTRUCTION-NOT GREASE / ROOTS	UNAUTHORIZED DISCHARGE-WATERS	11/04/24 11:15 AM	MAIN

Discharge Reporting:

Discharge Amount:	10 GAL
Cause:	OBSTRUCTION IN MAIN SEWER / STRUCTURAL DAMAGE.
Clean Up:	MSD PERSONNEL WILL CLEAN AND SANITIZE IMPACTED.
Control Zone:	ADVISED CUSTOMER TO AVOID CONTACT WITH IMPACTED AREA.
Impact:	SEWAGE/WATER IN NEARBY CREEK.
Repair:	REFER TO AREA SUPERVISOR FOR NEEDED REPAIRS.
Public Notification:	ADVISED CUSTOMER BY PHONE.

Notifications:

11/6/24 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
-----------------	--------	---



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	IS021A-SI	1201 OLD CANNONS LN	MORRIS FORMAN	MIDDLE FORK BEARGRASS CREEK	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3868672		11/10/2024 8:30:00 AM	DAVIS BROWN		DOCUMENTED	8/1/1969 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/11/24 12:15 AM	MAIN

Discharge Reporting:

Discharge Amount:	1,900,000 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	NO CLEAN UP PERFORMED – PIPE DISCHARGING UNDERWATER, DIRECTLY INTO STREAM.
Control Zone:	CONTROL ZONE WAS NOT ESTABLISHED DUE TO THE SIZE OF THE CREEK AND DIFFICULTY ACCESSING DISCHARGE AREAS.
Impact:	NONE OBSERVED OVERFLOW NOTIFICATION RECEIVED FROM REMOTE DISCHARGE ALARM.
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE INTEGRATED OVERFLOW ABATEMENT PLAN.
Public Notification:	PUBLIC NOTIFIED THROUGH PERMANENT OVERFLOW SIGNS TO AVOID DISCHARGED CONTENT.

Notifications:

11/10/24 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/10/24 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	IS021A-SI	1201 OLD CANNONS LN	MORRIS FORMAN	MIDDLE FORK BEARGRASS CREEK	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3869503		11/13/2024 8:30:00 PM	DAVIS BROWN		DOCUMENTED	8/1/1969 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/15/24 09:15 PM	MAIN

Discharge Reporting:

Discharge Amount:	8,900,000 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	NO CLEAN UP PERFORMED – PIPE DISCHARGING UNDERGROUND, DIRECTLY INTO STREAM.
Control Zone:	CONTROL ZONE WAS NOT ESTABLISHED DUE TO THE SIZE OF THE CREEK AND DIFFICULTY ACCESSING DISCHARGE AREAS.
Impact:	NONE OBSERVED OVERFLOW NOTIFICATION RECEIVED FROM REMOTE DISCHARGE ALARM.
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE INTEGRATED OVERFLOW ABATEMENT PLAN.
Public Notification:	PUBLIC NOTIFIED THROUGH PERMANENT OVERFLOW SIGNS TO AVOID DISCHARGED CONTENT.

Notifications:

11/14/24 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/14/24 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Manhole	IS021A-SI	1201 OLD CANNONS LN	MORRIS FORMAN	MIDDLE FORK BEARGRASS CREEK	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3876449		11/19/2024 6:00:00 AM	DAVIS BROWN		DOCUMENTED	8/1/1969 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/19/24 05:15 PM	MAIN

Discharge Reporting:

Discharge Amount:	500,000 GAL
Cause:	LACK OF SYSTEM CAPACITY HEAVY RAIN.
Clean Up:	NO CLEAN UP PERFORMED – PIPE DISCHARGING UNDERGROUND, DIRECTLY INTO STREAM. LACK OF SYSTEM CAPACITY HEAVY RAIN.
Control Zone:	CONTROL ZONE WAS NOT ESTABLISHED DUE TO THE SIZE OF THE CREEK AND DIFFICULTY ACCESSING DISCHARGE AREAS.
Impact:	NONE OBSERVED OVERFLOW NOTIFICATION RECEIVED FROM REMOTE DISCHARGE ALARM.
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE INTEGRATED OVERFLOW ABATEMENT PLAN.
Public Notification:	PUBLIC NOTIFIED THROUGH PERMANENT OVERFLOW SIGNS TO AVOID DISCHARGED CONTENT.

Notifications:

11/19/24 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/19/24 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Lift Station	MSD0193-PS	6001 RODES CT	MORRIS FORMAN	MUDDY FORK BEARGRASS CREEK	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3869681		11/14/2024 4:02:00 PM	SOSA RODRIGUEZ	ELECTRICAL CREW	REPAIRED - ISSUE RESOLVED	11/14/2024 12:00:00 AM	ELECTRICAL PROBLEMS AT MSD	UNAUTHORIZED DISCHARGE-WATERS	11/14/24 04:02 PM	

Discharge Reporting:

Discharge Amount:	1,020 GAL
Cause:	ELECTRIC COMPONENT FAILURE.
Clean Up:	NONE POSSIBLE DUE TO MAGNITUDE OF STORM.
Control Zone:	TEMPORARY SIGNS POSTED.
Impact:	NO IMPACT OBSERVED.
Repair:	ELECTRICIAN RETURN STATION BACK TO SERVICE.
Public Notification:	TEMPORARY SIGNS POSTED.

Notifications:

11/15/24 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
------------------	--------	---



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Treatment Plant	MSD0278	4522 ALGONQUIN PKY	MORRIS FORMAN	OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3866040		11/6/2024 3:36:00 AM	SCOTT	BURNS	REPAIRED - ISSUE RESOLVED	9/2/2024 12:00:00 AM	BYPASS AT WQTC	UNAUTHORIZED DISCHARGE-WATERS	11/06/24 04:13 AM	

Discharge Reporting:

Discharge Amount:	18,500 GAL
Cause:	EHW BAR SCREENS BLINDED CAUSE A OVERFLOW FROM CHANNEL
Clean Up:	CLEANED AND SANITIZED THE IMPACTED AREA
Control Zone:	PERMANENT SIGN IN PLACE – NO ADDITIONAL CONTROL ZONE SET UP
Impact:	NO IMPACT OBSERVED - DISCHARGE BELOW RIVER LEVEL
Repair:	RESET BAR SCREENS AND PUT BACK I/S
Public Notification:	PERMANENT SIGN IN PLACE – NO ADDITIONAL CONTROL ZONE SET UP

Notifications:

11/6/24 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
-----------------	--------	---



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0111716	MSD0414	SOUTH OLDHAM	SOUTH FORK HARRODS CREEK	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Treatment Plant	MSD0414	6115 HITT LN	SOUTH OLDHAM	SOUTH FORK HARRODS CREEK	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3868829		11/10/2024 12:00:00 PM	SMITHER	SMITHER	QUEUED FOR INVESTIGATION / REPAIR	4/9/2022 12:00:00 AM	BYPASS AT WQTC	UNAUTHORIZED DISCHARGE-WATERS	11/14/24 11:04 AM	

Discharge Reporting:

Discharge Amount:	1,000 GAL
Cause:	BYPASS AT WASTEWATER TREATMENT PLANT.
Clean Up:	CLEANED AND SANITIZED THE IMPACTED AREA WITH LIME.
Control Zone:	OVERFLOW CONTAINED ON MSD PROPERTY.
Impact:	NO IMPACT OBSERVED.
Repair:	PUT PUMP IN SERVICE THAT WAS LEFT OUT OF SERVICE.
Public Notification:	NONE NEEDED.

Notifications:

11/11/24 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/11/24 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0034151	MSD0506	BCSD HILLVIEW #1	TANYARD BRANCH	

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Treatment Plant	MSD0506	253 LEES LN	BCSD HILLVIEW #1	TANYARD BRANCH	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISDW: DRY WEATHER DISCHARGE	3865951		11/5/2024 12:34:00 PM	SMITHER	SMITHER	DOCUMENTED	1/8/2022 12:00:00 AM	BYPASS AT WQTC	UNAUTHORIZED DISCHARGE- WATERS	11/05/24 01:05 PM	

Discharge Reporting:

Discharge Amount:	500 GAL
Cause:	UPSET AT WASTEWATER TREATMENT PLANT.
Clean Up:	MSD CONTRACTOR CLEANED AND SANITIZED THE IMPACTED AREA.
Control Zone:	OVERFLOW CONTAINED ON MSD PROPERTY.
Impact:	SOLIDS LOSS TO STREAM.
Repair:	MADE PLANT OPERATION ADJUSTMENT (NO SERVICE REQUEST).
Public Notification:	OVERFLOW CONTAINED ON MSD PROPERTY.

Notifications:

11/6/24 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/6/24 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0034151	MSD0506	BCSD HILLVIEW #1	TANYARD BRANCH	

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Treatment Plant	MSD0506	253 LEES LN	BCSD HILLVIEW #1	TANYARD BRANCH	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3868778		11/10/2024 9:25:00 AM	SANTEE	FIELDS	DOCUMENTED	1/8/2022 12:00:00 AM	BYPASS AT WQTC	UNAUTHORIZED DISCHARGE-WATERS	11/10/24 10:15 PM	

Discharge Reporting:

Discharge Amount:	19,250 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	CLEANUP NOT POSSIBLE DUE TO MAGNITUDE OF STORM.
Control Zone:	PERMANENT SIGN IN PLACE – NO ADDITIONAL CONTROL ZONE SET UP.
Impact:	SEWAGE FOUND IN THE DITCH.
Repair:	SITE FOUND DURING RAIN EVENT RECON - WILL BE MONITORED AND EVALUATED FOR REPAIR.
Public Notification:	PERMANENT SIGN IN PLACE – NO ADDITIONAL CONTROL ZONE SET UP.

Notifications:

11/11/24 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/11/24 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0034169	MSD0507	BCSD HILLVIEW #2	BROOKS RUN	

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Treatment Plant	MSD0507	386 NORWOOD WAY	BCSD HILLVIEW #2	BROOKS RUN	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3868054		11/10/2024 8:35:00 AM	SANTEE	FIELDS	DOCUMENTED	12/6/2021 12:00:00 AM	BYPASS AT WQTC	UNAUTHORIZED DISCHARGE-WATERS	11/10/24 10:30 PM	

Discharge Reporting:

Discharge Amount:	25,050 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	CLEANUP NOT POSSIBLE DUE TO MAGNITUDE OF STORM.
Control Zone:	SITE FOUND DURING RAIN EVENT RECON - WILL BE MONITORED AND EVALUATED FOR REPAIR.
Impact:	SEWAGE FOUND IN THE DITCH.
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE INTEGRATED OVERFLOW ABATEMENT PLAN.
Public Notification:	N/A.

Notifications:

11/10/24 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/10/24 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0034177	MSD0508	BCSD HILLVIEW #3	BROOKS RUN	

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Treatment Plant	MSD0508	126 WESTERN RD	BCSD HILLVIEW #3	BROOKS RUN	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3868072		11/10/2024 8:40:00 AM	SANTEE	SPENCER	QUEUED FOR INVESTIGATION / REPAIR	3/28/2023 12:00:00 AM	BYPASS AT WQTC	UNAUTHORIZED DISCHARGE-WATERS	11/10/24 10:15 AM	

Discharge Reporting:

Discharge Amount:	2,375 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	CLEANUP NOT POSSIBLE DUE TO MAGNITUDE OF STORM.
Control Zone:	PERMANENT SIGN IN PLACE – NO ADDITIONAL CONTROL ZONE SET UP.
Impact:	NONE FLOWS OUT WITH EFFLUENT TO STREAM.
Repair:	SITE FOUND DURING RAIN EVENT RECON - WILL BE MONITORED AND EVALUATED FOR REPAIR.
Public Notification:	N/A.

Notifications:

11/10/24 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
------------------	--------	---



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0040126	MSD0411	KSR	CEDAR CREEK	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Lift Station	MSD1243-PS	1815 N STHY 393	KSR	CURRYS FORK	GROUND

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3868827		11/10/2024 6:09:00 PM	BROADEN	BROADEN	QUEUED FOR INVESTIGATION / REPAIR	4/15/2024 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/11/24 08:29 AM	

Discharge Reporting:

Discharge Amount:	550 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	CLEANUP NOT POSSIBLE DUE TO MAGNITUDE OF STORM.
Control Zone:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	SEWAGE FOUND AROUND WET WELL.
Repair:	SITE FOUND DURING RAIN EVENT RECON- WILL MONITOR & EVALUATE FOR REPAIR.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.

Notifications:

11/11/24 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/11/24 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0040126	MSD0411	KSR	CEDAR CREEK	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Lift Station	MSD1243-PS	1815 N STHY 393	KSR	CURRYS FORK	GROUND

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3869494		11/14/2024 10:01:00 AM	SOSA RODRIGUEZ	GENERAL MAINTENANCE	QUEUED FOR INVESTIGATION / REPAIR	4/15/2024 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/14/24 10:09 AM	

Discharge Reporting:

Discharge Amount:	750 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	CLEANUP NOT POSSIBLE DUE TO MAGNITUDE OF STORM.
Control Zone:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	SEWAGE FOUND AROUND WET WELL.
Repair:	SITE FOUND DURING RAIN EVENT RECON- WILL MONITOR & EVALUATE FOR REPAIR.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.

Notifications:

11/14/24 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
------------------	--------	---



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0040126	MSD0411	KSR	CEDAR CREEK	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Lift Station	MSD1243-PS	1815 N STHY 393	KSR	CURRYS FORK	GROUND

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3875818		11/19/2024 6:42:00 AM	PARKER	GENERAL MAINTENANCE	QUEUED FOR INVESTIGATION / REPAIR	4/15/2024 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/19/24 11:03 AM	

Discharge Reporting:

Discharge Amount:	50 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	CLEANUP NOT POSSIBLE DUE TO MAGNITUDE OF STORM.
Control Zone:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	SEWAGE FOUND AROUND WET WELL.
Repair:	SITE FOUND DURING RAIN EVENT RECON- WILL MONITOR & EVALUATE FOR REPAIR.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA

Notifications:

11/19/24 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
------------------	--------	---



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0106143	MSD0407	OHIO RIVER	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Lift Station	MSD1272-PS	13301 STHY 329	OHIO RIVER	HARRODS CREEK	GROUND

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3868062		11/10/2024 9:25:00 AM	BROADEN	BROADEN	QUEUED FOR INVESTIGATION / REPAIR	3/24/2023 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/11/24 08:52 AM	

Discharge Reporting:

Discharge Amount:	150 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	CLEANUP NOT POSSIBLE DUE TO MAGNITUDE OF STORM.
Control Zone:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	SEWAGE FOUND ON THE GROUND.
Repair:	SITE FOUND DURING RAIN EVENT RECON - WILL BE MONITORED AND EVALUATED FOR REPAIR.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.

Notifications:

11/10/24 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/10/24 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0106143	MSD0407	OHIO RIVER	OHIO RIVER	NA

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Lift Station	MSD1272-PS	13301 STHY 329	OHIO RIVER	HARRODS CREEK	GROUND

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3869420		11/13/2024 10:21:00 PM	PARKER	PARKER	QUEUED FOR INVESTIGATION / REPAIR	3/24/2023 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/19/24 07:11 AM	

Discharge Reporting:

Discharge Amount:	150 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	CLEANUP NOT POSSIBLE DUE TO MAGNITUDE OF STORM.
Control Zone:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	SEWAGE FOUND ON THE GROUND.
Repair:	SITE FOUND DURING RAIN EVENT RECON - WILL BE MONITORED AND EVALUATED FOR REPAIR.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.

Notifications:

11/14/24 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/14/24 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0034169	MSD0507	BCSD HILLVIEW #2	BROOKS RUN	

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Lift Station	MSD2013-PS	319 WINSTON CT	BCSD HILLVIEW #2	BROOKS RUN	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3869581		11/14/2024 11:00:00 AM	SOSA RODRIGUEZ	GENERAL MAINTENANCE	DOCUMENTED	12/11/2021 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/15/24 08:46 AM	

Discharge Reporting:

Discharge Amount:	3,960 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	CLEANUP NOT POSSIBLE DUE TO MAGNITUDE OF STORM.
Control Zone:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	SEWAGE/DEBRIS/SOLIDS/PERSONAL HYGIENE PRODUCTS FOUND IN THE STREAM.
Repair:	SITE FOUND DURING RAIN EVENT RECON - WILL BE MONITORED AND EVALUATED FOR REPAIR.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.

Notifications:

11/14/24 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/14/24 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0034177	MSD0508	BCSD HILLVIEW #3	BROOKS RUN	

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Lift Station	MSD2014-PS	169 SUMMERS DR	BCSD HILLVIEW #3	BROOKS RUN	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3869480		11/14/2024 9:00:00 AM	SOSA RODRIGUEZ	GENERAL MAINTENANCE	DOCUMENTED	12/9/2021 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/15/24 10:01 AM	

Discharge Reporting:

Discharge Amount:	13,125 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	CLEANUP NOT POSSIBLE DUE TO ELEVATED CREEK LEVEL.
Control Zone:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	SEWAGE FOUND IN THE STREAM.
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE INTEGRATED OVERFLOW ABATEMENT PLAN.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.

Notifications:

11/14/24 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/14/24 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0094307	MSD0511	WILLABROOK	BROOKS RUN	

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Lift Station	MSD2019-PS	3955 E BLUE LICK RD	WILLABROOK	BROOKS RUN	GROUND

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3868073		11/10/2024 10:32:00 AM	BROADEN	BROADEN	DOCUMENTED	1/1/1992 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/12/24 07:59 AM	

Discharge Reporting:

Discharge Amount:	68,700 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	CLEANUP NOT POSSIBLE DUE TO ELEVATED CREEK LEVEL.
Control Zone:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	NO IMPACT OBSERVED - FACILITY UNDER ELEVATED CREEK LEVEL.
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE INTEGRATED OVERFLOW ABATEMENT PLAN.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.

Notifications:

11/10/24 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/10/24 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0094307	MSD0511	WILLABROOK	BROOKS RUN	

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Lift Station	MSD2019-PS	3955 E BLUE LICK RD	WILLABROOK	BROOKS RUN	GROUND

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3869400		11/13/2024 8:04:00 PM	PARKER	PARKER	DOCUMENTED	1/1/1992 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/14/24 07:52 PM	

Discharge Reporting:

Discharge Amount:	119,600 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	CLEANUP NOT POSSIBLE DUE TO ELEVATED CREEK LEVEL.
Control Zone:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	NO IMPACT OBSERVED - FACILITY UNDER ELEVATED CREEK LEVEL.
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE INTEGRATED OVERFLOW ABATEMENT PLAN.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA

Notifications:

11/14/24 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/14/24 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0034185	MSD0512	PIONEER VILLAGE #1	BROOKS RUN	

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Lift Station	MSD2021-PS	165 OCTAGON AVE	PIONEER VILLAGE #1	BROOKS RUN	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3866031		11/6/2024 8:46:00 AM	PARKER	PARKER	DOCUMENTED	12/21/2022 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/08/24 07:51 AM	

Discharge Reporting:

Discharge Amount:	81,300 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	NO CLEAN UP PERFORMED – PIPE DISCHARGING UNDERWATER, DIRECTLY INTO STREAM.
Control Zone:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	NONE OBSERVED - OUTLETS SUBMERGED.
Repair:	SITE FOUND DURING RAIN EVENT RECON - WILL BE MONITORED AND EVALUATED FOR REPAIR.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.

Notifications:

11/6/24 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/6/24 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0034185	MSD0512	PIONEER VILLAGE #1	BROOKS RUN	

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Lift Station	MSD2021-PS	165 OCTAGON AVE	PIONEER VILLAGE #1	BROOKS RUN	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3868053		11/10/2024 8:21:00 AM	BROADEN	BROADEN	DOCUMENTED	12/21/2022 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/12/24 11:52 AM	

Discharge Reporting:

Discharge Amount:	290,000 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	NO CLEAN UP PERFORMED – PIPE DISCHARGING UNDERWATER, DIRECTLY INTO STREAM.
Control Zone:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	NONE OBSERVED - OUTLETS SUBMERGED.
Repair:	SITE FOUND DURING RAIN EVENT RECON - WILL BE MONITORED AND EVALUATED FOR REPAIR.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.

Notifications:

11/10/24 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/10/24 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION



KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0034185	MSD0512	PIONEER VILLAGE #1	BROOKS RUN	

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Lift Station	MSD2021-PS	165 OCTAGON AVE	PIONEER VILLAGE #1	BROOKS RUN	STREAM

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3869398		11/13/2024 7:45:00 PM	PARKER	PARKER	DOCUMENTED	12/21/2022 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	11/19/24 07:08 AM	

Discharge Reporting:

Discharge Amount:	611,268 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	NO CLEAN UP PERFORMED – PIPE DISCHARGING UNDERWATER, DIRECTLY INTO STREAM.
Control Zone:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	NONE OBSERVED - OUTLETS SUBMERGED.
Repair:	SITE FOUND DURING RAIN EVENT RECON - WILL BE MONITORED AND EVALUATED FOR REPAIR.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.

Notifications:

11/14/24 1:00 AM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
11/14/24 1:00 AM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION