



700 West Liberty Street | Louisville, KY 40203-1911
Phone: 502.540.6000 | LouisvilleMSD.org

March 13, 2024

Crystal Dennis
300 Sower Blvd., 3rd Floor
Frankfort, Kentucky 40601

**RE: Hillview #2 STP, KPDES No: KY00034169
Discharge Monitoring Report for February 2024.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) for the Hillview #2 WQTC, for the month February 2024.

There were no discharges, overflows, or exceedances.

If you have any questions concerning the attached DMR's, please contact me at (502)587-5858.

Sincerely,

Jon Baldrige
Process Supervisor

JOB/ HV#2 2/24.

Cc: V. Teague /B. Tinnell

DMR Copy of Record

Permit			
Permit #:	KY0034169	Permittee:	Hillview Sewer System Plant 2
Major:	No	Permittee Address:	PO Box 818 Hillview, KY 40129
Permitted Feature:	001 External Outfall	Discharge:	001-1 Domestic Wastewater
Facility:	BCSD HILLVIEW #2	Facility Location:	376 NORWOOD WAY HILLVIEW, KY 40229

Report Dates & Status			
Monitoring Period:	From 02/01/24 to 02/29/24	DMR Due Date:	03/28/24
Status:	NetDMR Validated		

Considerations for Form Completion			
---	--	--	--

Principal Executive Officer			
First Name:	James A.	Title:	Executive Director
Last Name:	Parrott	Telephone:	502-540-6000

No Data Indicator (NODI)			
Form NODI:	--		

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type			
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units	
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample						=	7.5					19 - mg/L	0	01/07 - Weekly	GR - GRAB
					Permit Req.						>=	7.0 INST MIN					19 - mg/L		01/07 - Weekly	GR - GRAB
					Value NODI															
00400	pH	1 - Effluent Gross	0	--	Sample						=	6.9			=	7.2	12 - SU	0	01/07 - Weekly	GR - GRAB
					Permit Req.						>=	6.0 MINIMUM			<=	9.0 MAXIMUM	12 - SU		01/07 - Weekly	GR - GRAB
					Value NODI															
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample						=	8.0			=	14.0	19 - mg/L	0	01/07 - Weekly	CP - COMPOS
					Permit Req.						<=	30.0 MO AVG			<=	45.0 MX WK AV	19 - mg/L		01/07 - Weekly	CP - COMPOS
					Value NODI															
00600	Nitrogen, total [as N]	1 - Effluent Gross	0	--	Sample						=	20.3			=	29.9	19 - mg/L	0	01/07 - Weekly	GR - GRAB
					Permit Req.							Req Mon MO AVG			Req Mon DAILY MX	19 - mg/L	01/07 - Weekly		GR - GRAB	
					Value NODI															
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	2	--	Sample						=	2.4			=	8.4	19 - mg/L	0	01/07 - Weekly	CP - COMPOS
					Permit Req.						<=	10.0 MO AVG			<=	15.0 DAILY MX	19 - mg/L		01/07 - Weekly	CP - COMPOS
					Value NODI															
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample						=	2.95			=	4.38	19 - mg/L	0	01/07 - Weekly	GR - GRAB
					Permit Req.							Req Mon MO AVG			Req Mon DAILY MX	19 - mg/L	01/07 - Weekly		GR - GRAB	
					Value NODI															
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.262	=	0.636	03 - MGD								0	01/07 - Weekly	IN - INSTAN
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	03 - MGD							01/07 - Weekly		IN - INSTAN	
					Value NODI															
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample						<	0.01			<	0.01	19 - mg/L	0	01/07 - Weekly	GR - GRAB
					Permit Req.						<=	0.011 MO AVG			<=	0.019 DAILY MX	19 - mg/L		01/07 - Weekly	GR - GRAB
					Value NODI															
51040	E. coli	1 - Effluent Gross	0	--	Sample						=	1.0			=	1.0	13 - #/100mL	0	01/07 - Weekly	GR - GRAB
					Permit Req.						<=	130.0 30DA GEO			<=	240.0 7 DA GEO	13 - #/100mL		01/07 - Weekly	GR - GRAB
					Value NODI															
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample						=	5.0			=	8.0	19 - mg/L	0	01/07 - Weekly	CP - COMPOS
					Permit Req.						<=	15.0 MO AVG			<=	22.5 MX WK AV	19 - mg/L		01/07 - Weekly	CP - COMPOS
					Value NODI															

Submission Note
 If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors
 No errors.

Comments

Attachments		
Name	Type	Size

hilview2.pdf	pdf	38420.0
--------------	-----	---------

Report Last Saved By
Hillview Sewer System Plant 2

User: JON.BALDRIDGE@LOUISVILLEMSD.ORG
Name: Jonathan Baldrige
E-Mail: jon.baldrige@louisvillemmsd.org
Date/Time: 2024-03-18 10:54 (Time Zone: -04:00)

Report Last Signed By

User: JON.BALDRIDGE@LOUISVILLEMSD.ORG
Name: Jonathan Baldrige
E-Mail: jon.baldrige@louisvillemmsd.org
Date/Time: 2024-03-19 09:48 (Time Zone: -04:00)