



700 West Liberty Street | Louisville, KY 40203-1911  
Phone: 502.540.6000 | LouisvilleMSD.org

March 13, 2024

Crystal Dennis  
300 Sower Blvd., 3rd Floor  
Frankfort, Kentucky 40601

**RE: Hillview #3 STP, KPDES No: KY0034177  
Discharge Monitoring Report for February 2024.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) for the Hillview #3 STP, for the month of February 2024.

There were no discharges, overflows, or exceedances.

If you have any questions concerning the attached DMR's, please contact me at (502)540-6717.

Sincerely,

Jon Baldrige  
Process Supervisor

JOB/ HV#3 02/24.

Cc: V. Teague/B. Tinnell

**DMR Copy of Record**

<b>Permit</b>			
Permit #:	KY0034177	Permittee:	Louisville and Jefferson County MSD
Major:	No	Permittee Address:	700 W Liberty St Louisville, KY 40203
Permitted Feature:	001 External Outfall	Discharge:	001-1 Domestic Wastewater
Facility:		Facility Location:	BCSD HILLVIEW #3 12325 WESTERN RD HILLVIEW, KY 40129

<b>Report Dates &amp; Status</b>			
Monitoring Period:	From 02/01/24 to 02/29/24	DMR Due Date:	03/28/24
Status:	NetDMR Validated		

**Considerations for Form Completion**

<b>Principal Executive Officer</b>			
First Name:	James A.	Title:	Executive Director
Last Name:	Parrott	Telephone:	502-540-6000

**No Data Indicator (NODI)**

Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type			
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units	
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample						=	7.1					19 - mg/L	0	01/07 - Weekly	GR - GRAB
					Permit Req.						>=	7.0 INST MIN					19 - mg/L		01/07 - Weekly	GR - GRAB
					Value NODI															
00400	pH	1 - Effluent Gross	0	--	Sample						=	6.5			=	7.1	12 - SU	0	01/07 - Weekly	GR - GRAB
					Permit Req.						>=	6.0 MINIMUM			<=	9.0 MAXIMUM	12 - SU		01/07 - Weekly	GR - GRAB
					Value NODI															
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample						=	9.0		=	12.0	19 - mg/L	0	01/07 - Weekly	CP - COMPOS	
					Permit Req.						<=	30.0 MO AVG		<=	45.0 MX WK AV	19 - mg/L		01/07 - Weekly	CP - COMPOS	
					Value NODI															
00600	Nitrogen, total [as N]	1 - Effluent Gross	0	--	Sample						=	7.45		=	9.9	19 - mg/L	0	01/07 - Weekly	CP - COMPOS	
					Permit Req.							Req Mon MO AVG		Req Mon DAILY MX	19 - mg/L	01/07 - Weekly		CP - COMPOS		
					Value NODI															
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	2	--	Sample						=	5.03		=	9.2	19 - mg/L	0	01/07 - Weekly	CP - COMPOS	
					Permit Req.						<=	10.0 MO AVG		<=	15.0 DAILY MX	19 - mg/L		01/07 - Weekly	CP - COMPOS	
					Value NODI															
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample						=	0.36		=	0.44	19 - mg/L	0	01/07 - Weekly	CP - COMPOS	
					Permit Req.							Req Mon MO AVG		Req Mon DAILY MX	19 - mg/L	01/07 - Weekly		CP - COMPOS		
					Value NODI															
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.171	=	0.535	03 - MGD								0	99/99 - Continuous	RC - Recorder (auto)
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	03 - MGD							99/99 - Continuous		RC - Recorder (auto)	
					Value NODI															
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample						<	0.01		<	0.01	19 - mg/L	0	01/07 - Weekly	GR - GRAB	
					Permit Req.						<=	0.011 MO AVG		<=	0.019 DAILY MX	19 - mg/L		01/07 - Weekly	GR - GRAB	
					Value NODI															
51040	E. coli	1 - Effluent Gross	0	--	Sample						=	1.0		=	1.0	13 - #/100mL	0	01/07 - Weekly	GR - GRAB	
					Permit Req.						<=	130.0 30DA GEO		<=	240.0 7 DA GEO	13 - #/100mL		01/07 - Weekly	GR - GRAB	
					Value NODI															
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample						=	5.0		=	6.0	19 - mg/L	0	01/07 - Weekly	CP - COMPOS	
					Permit Req.						<=	15.0 MO AVG		<=	22.5 MX WK AV	19 - mg/L		01/07 - Weekly	CP - COMPOS	
					Value NODI															

**Submission Note**  
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**  
No errors.

**Comments**

**Attachments**

Name	Type	Size
------	------	------

**Report Last Saved By**

**Louisville and Jefferson County MSD**

User: JON.BALDRIDGE@LOUISVILLEMSD.ORG  
Name: Jonathan Baldrige  
E-Mail: jon.baldrige@louisvillemSD.org  
Date/Time: 2024-03-18 10:55 (Time Zone: -04:00)

**Report Last Signed By**

User: JON.BALDRIDGE@LOUISVILLEMSD.ORG  
Name: Jonathan Baldrige  
E-Mail: jon.baldrige@louisvillemSD.org  
Date/Time: 2024-03-19 09:48 (Time Zone: -04:00)