



700 West Liberty Street | Louisville, KY 40203-1911  
Phone: 502.540.6000 | LouisvilleMSD.org

June 20, 2024

Crystal Dennis  
300 Sower Blvd., 3rd Floor  
Frankfort, Kentucky 40601

**RE: Hillview #3 STP, KPDES No: KY0034177  
Discharge Monitoring Report for May 2024.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) for the Hillview #3 STP, for the month of May 2024.

There were three exceedances for May. Nitrogen, Ammonia Total Daily Max permit limit is 6.0 mg/l sample result was 24.3 mg/l. Nitrogen Ammonia Total monthly average permit limit is 4.0 mg/l sample result was 5.73 mg/l. BOD, carbonaceous maximum weekly average. Permit limit is 22.5. sample result was 24.0. The three exceedances were due to high amounts of flow coming through the plant due to rainfall.

There were no discharges, or overflows.

If you have any questions concerning the attached DMR's, please contact me at (502)540-6717.

Sincerely,

Jon Baldrige  
Process Supervisor

JOB/ HV#3 05/24.

Cc: V. Teague/B. Tinnell



**Submission Note**

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**

Parameter		Monitoring Location	Field	Type	Description	Acknowledge
Code	Name					
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	Quality or Concentration Sample Value 3	Soft	The provided sample value is outside the permit limit. <b>Please verify that the value you have provided is correct.</b>	Yes
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	Quality or Concentration Sample Value 3	Soft	The provided sample value is outside the permit limit. <b>Please verify that the value you have provided is correct.</b>	Yes
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	Quality or Concentration Sample Value 2	Soft	The provided sample value is outside the permit limit. <b>Please verify that the value you have provided is correct.</b>	Yes

**Comments****Attachments**

Name	Type	Size
hill3.pdf	pdf	41417.0

**Report Last Saved By****Louisville and Jefferson County MSD**

User: JON.BALDRIDGE@LOUISVILLEMSD.ORG  
 Name: Jonathan Baldrige  
 E-Mail: jon.baldrige@louisvillemmsd.org  
 Date/Time: 2024-06-20 13:33 (Time Zone: -04:00)

**Report Last Signed By**

User: JON.BALDRIDGE@LOUISVILLEMSD.ORG  
 Name: Jonathan Baldrige  
 E-Mail: jon.baldrige@louisvillemmsd.org  
 Date/Time: 2024-06-20 13:42 (Time Zone: -04:00)