



700 West Liberty Street | Louisville, KY 40203-1911  
Phone: 502.540.6000 | LouisvilleMSD.org

November 12th, 2024

Crystal Dennis  
300 Sower Blvd., 3rd Floor  
Frankfort, Kentucky 40601

**RE: Kentucky State Reformatory STP, KPDES No: KY00400126  
Discharge Monitoring Report for October 2024.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) for the Kentucky State Reformatory STP, for the month October 2024.

There were no overflows, exceedances or bypasses.

If you have any questions concerning the attached DMR's, please contact me at (502) 264-2804.

Sincerely,

Alex Smither  
Process Supervisor

CAS 10/24

Cc: V. Teague, B. Tinnel



					Value NODI														
01119	Copper, total recoverable	1 - Effluent Gross	0	--	Sample = 0.0														
					Permit Req. = 0.0														
					Value NODI = 0.0														
34306	Chlorodibromomethane	1 - Effluent Gross	0	--	Sample = 5.0														
					Permit Req. <= 13.0 MO AVG														
					Value NODI = 5.0														
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample = 0.561														
					Permit Req. = 0.662														
					Value NODI = 0.662														
50050	Flow, in conduit or thru treatment plant	G - Raw Sewage Influent	0	--	Sample = 0.662														
					Permit Req. = 0.773														
					Value NODI = 0.773														
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample = 0.01														
					Permit Req. <= 0.011 MO AVG														
					Value NODI = 0.01														
51040	E. coli	1 - Effluent Gross	0	--	Sample = 1.0														
					Permit Req. <= 130.0 30DA GEO														
					Value NODI = 1.0														
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample = 30.0														
					Permit Req. <= 83.5 MO AVG														
					Value NODI = 30.0														
80082	BOD, carbonaceous [5 day, 20 C]	G - Raw Sewage Influent	0	--	Sample = 133.0														
					Permit Req. = 159.0														
					Value NODI = 133.0														
80091	BOD, carb-5 day, 20 deg C, percent removal	K - Percent Removal	0	--	Sample = 95.5														
					Permit Req. >= 85.0 MO AV MN														
					Value NODI = 95.5														
81011	Solids, suspended percent removal	K - Percent Removal	0	--	Sample = 92.9														
					Permit Req. >= 85.0 MO AV MN														
					Value NODI = 92.9														

**Submission Note**

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**

No errors.

**Comments**

**Attachments**

Name	Type	Size
KSR_COVER_10_24.pdf	pdf	39626.0

**Report Last Saved By**

**Louisville and Jefferson County MSD**

User: ALEX.SMITHER@LOUISVILLEMSD.ORG  
Name: Charles Smither  
E-Mail: alex.smither@louisvillemmsd.org  
Date/Time: 2024-11-12 09:52 (Time Zone: -05:00)

**Report Last Signed By**

User: ALEX.SMITHER@LOUISVILLEMSD.ORG  
Name: Charles Smither  
E-Mail: alex.smither@louisvillemmsd.org  
Date/Time: 2024-11-12 09:52 (Time Zone: -05:00)