



700 West Liberty Street | Louisville, KY 40203-1911  
Phone: 502.540.6000 | LouisvilleMSD.org

June 17th, 2024

Crystal Dennis  
300 Sower Blvd., 3rd Floor  
Frankfort, Kentucky 40601

**RE: Lakewood STP, KPDES No: KY0039870  
Discharge Monitoring Report for May 2024.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) for the Lakewood STP, for the month May 2024.

There were one exceedance and no overflows or bypasses. The exceedance was for weekly max TSS. The weekly max was 16 mg/L with a permit limit of 15 mg/L.

If you have any questions concerning the attached DMR's, please contact me at (502) 264-2804.

Sincerely,

Alex Smither  
Process Supervisor

CAS/LW 5/24

Cc: V. Teague, B. Tinnel



**Submission Note**

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**

Parameter		Monitoring Location	Field	Type	Description	Acknowledge
Code	Name					
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	Quality or Concentration Sample Value 3	Soft	The provided sample value is outside the permit limit. <b>Please verify that the value you have provided is correct.</b>	Yes

**Comments****Attachments**

Name	Type	Size
LAKEWOOD_COVER_5_24.pdf	pdf	35493.0

**Report Last Saved By****Louisville and Jefferson County MSD**

User: ALEX.SMITHER@LOUISVILLEMSD.ORG  
 Name: Charles Smither  
 E-Mail: alex.smither@louisvillemmsd.org  
 Date/Time: 2024-06-17 09:20 (Time Zone: -04:00)

**Report Last Signed By**

User: ALEX.SMITHER@LOUISVILLEMSD.ORG  
 Name: Charles Smither  
 E-Mail: alex.smither@louisvillemmsd.org  
 Date/Time: 2024-06-17 09:20 (Time Zone: -04:00)