



700 West Liberty Street | Louisville, KY 40203-1911
Phone: 502.540.6000 | LouisvilleMSD.org

October 18th, 2024

Crystal Dennis
300 Sower Blvd., 3rd Floor
Frankfort, Kentucky 40601

**RE: Lakewood STP, KPDES No: KY0039870
Discharge Monitoring Report for September 2024.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) for the Lakewood STP, for the month September 2024.

There were two exceedances and no overflows or bypasses. One exceedance was for weekly max TSS. The weekly max was 87 mg/L with a permit limit of 45 mg/L. The other exceedance was monthly average TSS. The monthly average was 64 mg/L with a permit limit of 30 mg/L. We treated the lagoon for algae multiple times and towards the end of the month the numbers were falling to permitted range.

If you have any questions concerning the attached DMR's, please contact me at (502) 264-2804.

Sincerely,

Alex Smither
Process Supervisor

CAS/LW 9/24

Cc: V. Teague, B. Tinnel

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

Parameter		Monitoring Location	Field	Type	Description	Acknowledge
Code	Name					
00530	Solids, total suspended	1 - Effluent Gross	Quality or Concentration Sample Value 2	Soft	The provided sample value is outside the permit limit. Please verify that the value you have provided is correct.	Yes
00530	Solids, total suspended	1 - Effluent Gross	Quality or Concentration Sample Value 3	Soft	The provided sample value is outside the permit limit. Please verify that the value you have provided is correct.	Yes

Comments**Attachments**

Name	Type	Size
LAKWOOD_COVER_9_24.pdf	pdf	41230.0

Report Last Saved By**LaGrange Utilities Commission**

User: ALEX.SMITHER@LOUISVILLEMSD.ORG
 Name: Charles Smither
 E-Mail: alex.smither@louisvillemmsd.org
 Date/Time: 2024-10-18 14:25 (Time Zone: -04:00)

Report Last Signed By

User: ALEX.SMITHER@LOUISVILLEMSD.ORG
 Name: Charles Smither
 E-Mail: alex.smither@louisvillemmsd.org
 Date/Time: 2024-10-18 14:26 (Time Zone: -04:00)