



700 West Liberty Street | Louisville, KY 40203-1911  
Phone: 502.540.6000 | LouisvilleMSD.org

September 24, 2024

Crystal Dennis  
300 Sower Blvd., 3rd Floor  
Frankfort, Kentucky 40601

**RE: Willabrook STP, KPDES No: KY0094307  
Discharge Monitoring Report for August 2024.**

Dear Ms. Dennis:

Attached is the Discharge Monitoring Report (DMR) for the Willabrook STP, for the month of August 2024.

Also attached is overflow report.

There were no exceedances or bypasses to report.

If you have any questions concerning the attached DMR's, please contact me at (502) 540-6717.

Sincerely,

Jon Baldrige  
Process Supervisor

JOB/ Willabrook 8/24.

Cc: V. Teague/B. Tinnell



**Submission Note**

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**

No errors.

**Comments****Attachments**

Name	Type	Size
Willabrookcoverletter.pdf	pdf	192191.0
WillabrookOverflow.pdf	pdf	63183.0

**Report Last Saved By****Louisville and Jefferson County MSD**

User: JON.BALDRIDGE@LOUISVILLEMSD.ORG  
Name: Jonathan Baldrige  
E-Mail: jon.baldrige@louisvillemmsd.org  
Date/Time: 2024-09-24 10:27 (Time Zone: -04:00)

**Report Last Signed By**

User: JON.BALDRIDGE@LOUISVILLEMSD.ORG  
Name: Jonathan Baldrige  
E-Mail: jon.baldrige@louisvillemmsd.org  
Date/Time: 2024-09-24 12:35 (Time Zone: -04:00)



**IMSAST0004  
Overflow Report  
8/1/2024 12:00:00 AM to 8/31/2024 12:00:00 AM**

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Discharge	Region
KY0094307	MSD0511	WILLABROOK	BROOKS RUN	

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Station	Receiving Stream	Discharge To
Sewer Lift Station	MSD2019-PS	3955 E BLUE LICK RD	WILLABROOK	BROOKS RUN	GROUND

Activity Code / Description	WO #	Ref #	Initiated on	Initiated By	Assigned To	Dish Status	Event Date	Problem Desc	Result	Completed	Condition
DISREV:RAIN EVENT DISCHARGE	3825450		8/2/2024 7:45:00 AM	SANTEE	SANTEE	DOCUMENTED	1/1/1992 12:00:00 AM	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATERS	08/03/24 11:24 AM	

**Discharge Reporting:**

Discharge Amount:	30,900 GAL
Cause:	LACK OF SYSTEM CAPACITY.
Clean Up:	CLEANUP NOT POSSIBLE DUE TO ELEVATED CREEK LEVEL.
Control Zone:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	NO IMPACT OBSERVED - FACILITY UNDER ELEVATED CREEK LEVEL.
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE INTEGRATED OVERFLOW ABATEMENT PLAN.
Public Notification:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.

**Notifications:**

8/2/24 1:00 PM	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
8/2/24 1:00 PM	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION