



Louisville and Jefferson County Metropolitan Sewer District  
700 West Liberty Street  
Louisville Kentucky 40203-1911  
502-540-6000  
www.msdlouky.org

September 10, 2012

[Redacted]  
[Redacted] Carroll Avenue  
Louisville, Kentucky 40213

Subject: Integrated Overflow Abatement Plan (IOAP)  
Public Input Meeting August 14, 2012  
Response to Comments

Dear [Redacted],

Thank you for taking the time to submit your comments relative to Camp Taylor Sanitary Sewer Replacement Project. Your comments are summarized below, and your comment form has been attached for reference.

Comment – Sewer backup in front yard after rain event.

Response to comment – MSD recently completed a Sanitary Sewer Evaluation Study (SSES) in Camp Taylor and surrounding neighborhoods to find defects in the sanitary sewers. These defects allow unwanted ground water to enter the sewer lines and cause sewer back-ups during rain events. During the study, significant defects were found in your neighborhood. MSD will complete sewer rehabilitation efforts to correct these defects starting spring 2013 with completion targeted for December 2013.

In addition to the defects found in the public sewers, private property down spout and area yard drain connections were found in your area. When it rains, these connections direct clear water to the sanitary sewers. This additional water reduces the sewer's capacity and can cause sewer back-ups. MSD will work in your neighborhood to get these connections removed but this will begin as a voluntary program. MSD will complete the rehabilitation activities on the public sewers to correct the problems but the success on the private side will depend on individual property owner's participation.

Sincerely,

Brian Bingham  
Regulatory Services Director


Attachment: Comment Form



Beneficial Use of Louisville's Biosolids  
www.louisvillegreen.com



**Sewer Overflow Abatement Public Outreach Meeting**



Date: 8/14/12

**We Want YOU to Share Your Thoughts!**

Check box for answer:

1. To what extent do you better understand what MSD is doing to solve the sewer overflow problems? Would you say it was:  
 To a great extent       To a moderate extent       To a slight extent       Not at all
2. To what extent do you better understand what MSD is doing on the specific projects presented?  
 To a great extent       To a moderate extent       To a slight extent       Not at all
3. To what extent has your awareness increased on how individuals can help reduce sewer overflow problems?  
 To a great extent       To a moderate extent       To a slight extent       Not at all
4. After this meeting, are you more or less likely to do the following:
  - a. NOT Run your dishwasher or washing machine *during a rain event*?  
 More likely       Less likely       No change
  - b. Transfer leftover fats, oils and greases into a metal can/trash?  
 More likely       Less likely       No change

**To Be Completed by the Customer:**

Customer Name (Last, First) \_\_\_\_\_

Address \_\_\_\_\_ Carroll Ave \_\_\_\_\_ Zip Code 40213

Cell Phone \_\_\_\_\_ Work Phone \_\_\_\_\_

**LOCATION OF REQUEST**

Address \_\_\_\_\_ Carroll Ave \_\_\_\_\_ Zip Code 40213

Owner  Tenant  Other

**REQUEST TYPE**

MSD Construction       IOAP Project/Program       Drainage       Sanitary Sewer  
 General MSD concern       \_\_\_\_\_

**REQUEST DESCRIPTION:**

Sewer backup in front yard after rain event

**To Be Completed by an MSD Representative:**

MSD Responder: \_\_\_\_\_ Division: \_\_\_\_\_

**Would you like to receive email notifications for any of the following?**

Future meeting notices       Dry weather sewer overflows       Wet weather sewer overflow warnings

Please provide your email address: \_\_\_\_\_